

RICE Periodic Monitoring Procedure (PMP) Frequency Reduction Guidance

A facility that has achieved and maintained compliance with the PMP may submit a modification request to reduce the frequency of PMP testing (see table below). PMP frequency can only be reduced once. However, if subsequent PMP test results fail to demonstrate compliance with the permit limits, then the frequency of PMP testing shall revert to the Initial Frequency.

Initial Frequency, from Testing and Monitoring	Minimum Duration between PMP Tests	Consecutive PMP Test Results Showing Compliance with Permit Limits	Reduced Frequency
Semiannually	90 calendar days	6 consecutive semiannual test results	Annually
Quarterly	45 calendar days	8 consecutive quarterly test results	Annually
Monthly	15 calendar days	12 consecutive monthly test results	Quarterly