



State of New Jersey

Department of Environmental Protection
Air, Energy and Materials Sustainability

Division of Air Quality

Bureau of Stationary Sources

401 E. State Street, 2nd Floor, P.O. Box 420, Mail Code 401-02
Trenton, NJ 08625-0420

PHILIP D. MURPHY
Governor

SHEILA Y. OLIVER
Lt. Governor

SHAWN M. LATOURETTE
COMMISSIONER

Air Pollution Control Operating Permit Renewal

Permit Activity Number: BOP180001

Program Interest Number: 42247

Mailing Address	Plant Location
DEREK ARMSTEAD MAYOR LINDEN CITY 301 N WOOD AVE Linden, NJ 07036	LINDEN CITY SLF 1451 Lower Rd Linden Union County

Initial Operating Permit Approval Date: August 20, 2009

Operating Permit Approval Date: Draft

Operating Permit Expiration Date: TBD

AUTHORITY AND APPLICABILITY

The New Jersey Department of Environmental Protection (Department) approves and issues this Air Pollution Control Operating Permit under the authority of Chapter 106, P.L. 1967 (N.J.S.A. 26:2C-9.2). This permit is issued in accordance with the air pollution control permit provisions promulgated at Title V of the Federal Clean Air Act, 40 CFR 70, Air Pollution Control Act codified at N.J.S.A. 26:2C and New Jersey State regulations promulgated at N.J.A.C. 7:27-22.

The Department approves this operating permit based on the evaluation of the certified information provided in the permit application that all equipment and air pollution control devices regulated in this permit comply with all applicable State and Federal regulations. The facility shall be operated in accordance with the conditions of this permit. This operating permit supersedes any previous Air Pollution Control Operating Permits issued to this facility by the Department including any general operating permits, renewals, significant modifications, minor modifications, seven-day notice changes or administrative amendments to the permit.

Changes made through this permit activity are provided in the Reason for Application.

PERMIT SHIELD

This operating permit includes a permit shield, pursuant to the provisions of N.J.A.C. 7:27-22.17.

COMPLIANCE SCHEDULES

This operating permit does not include compliance schedules as part of the approved compliance plan.

COMPLIANCE CERTIFICATIONS AND DEVIATION REPORTS

The permittee shall submit to the Department and to United States Environmental Protection Agency (US EPA) periodic compliance certifications, in accordance with N.J.A.C. 7:27-22.19. **The annual compliance certification** is due to the Department and EPA within 60 days after the end of each calendar year during which this permit was in effect. **Semi-annual deviation reports** relating to compliance testing and monitoring are due to the Department within 30 days after the end of the semi-annual period. The schedule and additional details for these submittals are available in Subject Item - FC, of the Facility Specific Requirements of this permit.

ACCESSING PERMITS

The facility's current approved operating permit and any previously issued permits (e.g. superseded, expired, or terminated) are available for download in PDF format at: <https://dep.nj.gov/boss>. After accessing the website, click on "Approved Operating Permits" listed under "Reports" and then type in the Program Interest (PI) Number as instructed on the screen. If needed, the RADIUS file for your permit, containing Facility Specific Requirements (Compliance Plan), Inventories and Compliance Schedules can be obtained by contacting the Helpline number given below. RADIUS software, instructions, and help are available at the Department's website at <https://dep.nj.gov/boss>.

HELPLINE

The Operating Permit Helpline is available for any questions at (609) 633-8248 from 9:00 AM to 4:00 PM Monday to Friday.

RENEWING YOUR OPERATING PERMIT AND APPLICATION SHIELD

The permittee is responsible for submitting a timely and administratively complete operating permit renewal application pursuant to N.J.A.C. 7:27-22.30. Only applications which are timely and administratively complete are eligible for an application shield. The details on the contents of the renewal application, submittal schedule, and application shield are available in Section B - General Provisions and Authorities of this permit.

COMPLIANCE ASSURANCE MONITORING

Facilities that are subject to Compliance Assurance Monitoring (CAM), pursuant to 40 CFR 64, shall develop a CAM Plan for modified equipment as well as existing sources. The rule and guidance on how to prepare a CAM Plan can be found at EPA's website: <https://www.epa.gov/air-emissions-monitoring-knowledge-base/compliance-assurance-monitoring>. In addition, CAM Plans must be included as part of the permit renewal application. Facilities that do not submit a CAM Plan may have their permit applications denied, pursuant to N.J.A.C. 7:27-22.3.

ADMINISTRATIVE HEARING REQUEST

If, in your judgment, the Department is imposing any unreasonable condition of approval, you may contest the Department's decision and request an adjudicatory hearing pursuant to N.J.S.A. 52:14B-1 et seq. and N.J.A.C. 7:27-22.32(a). All requests for an adjudicatory hearing must be received in writing by the Department within 20 calendar days of the date you receive this letter. The request must contain the information specified in N.J.A.C. 7:27-1.32 and the information on the [NJ04 - Administrative Hearing Request Checklist and Tracking Form](https://dep.nj.gov/wp-content/uploads/boss/applications-and-forms/administrative-hearing-request-checklist-and-tracking-form.pdf) available at <https://dep.nj.gov/wp-content/uploads/boss/applications-and-forms/administrative-hearing-request-checklist-and-tracking-form.pdf>.

If you have any questions regarding this permit approval, please call Thaddeus Soley at (609) 940-4463.

Approved by:

Shafi Ahmed

Enclosure

CC: Suilin Chan, United States Environmental Protection Agency, Region 2

Facility Name: LINDEN CITY SLF
Program Interest Number: 42247
Permit Activity Number: BOP180001

TABLE OF CONTENTS

<u>Section A</u>	POLLUTANT EMISSIONS SUMMARY
<u>Section B</u>	GENERAL PROVISIONS AND AUTHORITIES
<u>Section C</u>	STATE-ONLY APPLICABLE REQUIREMENTS
<u>Section D</u>	FACILITY SPECIFIC REQUIREMENTS AND INVENTORIES
	<ul style="list-style-type: none">• FACILITY SPECIFIC REQUIREMENTS – PAGE INDEX• REASON FOR APPLICATION• FACILITY SPECIFIC REQUIREMENTS (COMPLIANCE PLAN)• COMPLIANCE SCHEDULES• FACILITY PROFILE (ADMINISTRATIVE INFORMATION)• INSIGNIFICANT SOURCE EMISSIONS• EQUIPMENT INVENTORY• EQUIPMENT DETAILS• CONTROL DEVICE INVENTORY• CONTROL DEVICE DETAILS• EMISSION POINT INVENTORY• EMISSION UNIT / BATCH PROCESS INVENTORY

Section A

Facility Name: LINDEN CITY SLF
Program Interest Number: 42247
Permit Activity Number: BOP180001

POLLUTANT EMISSIONS SUMMARY

Table 1: Total emissions from all Significant Source Operations¹ at the facility.

Facility's Potential Emissions from all Significant Source Operations (tons per year)										
Source Categories	VOC (total)	NO _x	CO	SO ₂	TSP (total)	PM ₁₀ (total)	PM _{2.5} (total)	Pb	HAPs* (total)	CO ₂ e ²
Emission Units Summary	NA	1.20	3.99	1.03	0.34	0.34	0.34	NA	0.00067	
Batch Process Summary	NA	NA	NA	NA	NA	NA	NA	NA	NA	
Group Summary	NA	NA	NA	NA	NA	NA	NA	NA	NA	
Total Emissions	NA	1.20	3.99	1.03	0.34	0.34	0.34	NA	0.00067	4,543

Table 2: Estimate of total emissions from all Insignificant Source Operations¹ and total emissions from Non-Source Fugitives at the facility.

Emissions from all Insignificant Source Operations and Non-Source Fugitive Emissions (tons per year)									
Source Categories	VOC (total)	NO _x	CO	SO ₂	TSP (total)	PM ₁₀ (total)	PM _{2.5} (total)	Pb	HAPs (total)
Insignificant Source Operations	0.005	0.005	0.005	NA	NA	NA	NA	NA	NA
Non-Source Fugitive Emissions	NA	NA	NA	NA	NA	NA	NA	NA	NA

VOC: Volatile Organic Compounds

NO_x: Nitrogen Oxides

CO: Carbon Monoxide

SO₂: Sulfur Dioxide

N/A: Indicates the pollutant is not emitted or is emitted below the reporting threshold specified in N.J.A.C. 7:27-22, Appendix, Table A and N.J.A.C. 7:27-17.9(a).

TSP: Total Suspended Particulates

Other: Any other air contaminant

regulated under the Federal CAA

PM₁₀: Particulates under 10 microns

PM_{2.5}: Particulates under 2.5 microns

Pb: Lead

HAPs: Hazardous Air Pollutants

CO₂e: Carbon Dioxide equivalent

*Emissions of individual HAPs are provided in Table 3 on the next page.

Emissions of "Other" air contaminants are provided in Table 4 on the next page.

¹ Significant Source Operations and Insignificant Source Operations are defined at N.J.A.C. 7:27-22.1.

² Total CO₂e emissions for the facility.

Section A

Facility Name: LINDEN CITY SLF
Program Interest Number: 42247
Permit Activity Number: BOP180001

POLLUTANT EMISSIONS SUMMARY

Table 3: Summary of Hazardous Air Pollutants (HAP) Emissions from Significant Source Operations ³:

HAP	TPY
Acrylonitrile	0.000675

Table 4: Summary of “Other” air contaminants emissions from Significant Source Operations:

Other Air Contaminant	TPY
Methane	154

³ Do not sum the values below for the purpose of establishing a total HAP potential to emit. See previous page for the allowable total HAP emissions.

Section B

Facility Name: LINDEN CITY SLF
Program Interest Number: 42247
Permit Activity Number: BOP180001

GENERAL PROVISIONS AND AUTHORITIES

1. No permittee shall allow any air contaminant, including an air contaminant detectable by the sense of smell, to be present in the outdoor atmosphere in a quantity and duration which is, or tends to be, injurious to human health or welfare, animal or plant life or property, or which would unreasonably interfere with the enjoyment of life or property. This shall not include an air contaminant that occurs only in areas over which the permittee has exclusive use or occupancy. Requirements relative only to nuisance situations, including odors, are not considered federally enforceable. [N.J.A.C. 7:27-22.16(g)8]
2. Any deviation from operating permit requirements which results in a release of air contaminants shall be reported to the Department as follows:
 - a. If the air contaminants are released in a quantity or concentration which poses a potential threat to public health, welfare or the environment or which might reasonably result in citizen complaints, the permittee shall report the release to the Department:
 - i. Immediately on the Department hotline at 1-(877) 927-6337, pursuant to N.J.S.A. 26:2C-19(e); and
 - ii. As part of the compliance certification required in N.J.A.C. 7:27-22.19(f). However, if the deviation is identified through source emissions testing, it shall be reported through the source emissions testing and monitoring procedures at N.J.A.C. 7:27-22.18(e)3; or
 - b. If the air contaminants are released in a quantity or concentration which poses no potential threat to public health, welfare or the environment and which will not likely result in citizen complaints, the permittee shall report the release to the Department as part of the compliance certification required in N.J.A.C. 7:27-22.19(f), except for deviations identified by source emissions testing reports, which shall be reported through the procedures at N.J.A.C. 7:27-22.18(e)3; or
 - c. If the air contaminants are released in a quantity or concentration which poses no potential threat to public health, welfare or the environment and which will not likely result in citizen complaints, and the permittee intends to assert the affirmative defense afforded by N.J.A.C. 7:27-22.16(l), the violation shall be reported by 5:00 PM of the second full calendar day following the occurrence, or of becoming aware of the occurrence, consistent with N.J.A.C. 7:27-22.16(l). [N.J.A.C. 7:27-22.19(g)1]
3. The permittee shall comply with all conditions of the operating permit including the approved compliance plan. Any non-compliance with a permit condition constitutes a violation of the New Jersey Air Pollution Control Act N.J.S.A. 26:2C-1 et seq., or the CAA, 42 U.S.C. §7401 et seq., or both, and is grounds for enforcement action; for termination, revocation and reissuance, or for modification of the operating permit; or for denial of an application for a renewal of the operating permit. [N.J.A.C. 7:27-22.16(g)1]
4. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of its operating permit. [N.J.A.C. 7:27-22.16(g)2]
5. This operating permit may be modified, terminated, or revoked for cause by the EPA pursuant to 40 CFR 70.7(g) and revoked or reopened and modified for cause by the Department pursuant to N.J.A.C. 7:27-22.25. [N.J.A.C. 7:27-22.16(g)3]

6. The permittee shall furnish to the Department, within a reasonable time, any information that the Department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this operating permit; or to determine compliance with the operating permit. [N.J.A.C. 7:27-22.16(g)4]
7. The filing of an application for a modification of an operating permit, or of a notice of planned changes or anticipated non-compliance, does not stay any operating permit condition. [N.J.A.C. 7:27-22.16(g)5]
8. The operating permit does not convey any property rights of any sort, or any exclusive privilege. [N.J.A.C. 7:27-22.16(g)6]
9. Upon request, the permittee shall furnish to the Department copies of records required by the operating permit to be kept. [N.J.A.C. 7:27-22.16(g)7]
10.
 - a. For emergencies (as defined at 40 CFR 70.6(g)(1)) that result in non-compliance with any promulgated federal technology-based standard such as NSPS, NESHAPS, or MACT, a federal affirmative defense is available, pursuant to 40 CFR 70. To assert a federal affirmative defense, the permittee must use the procedures set forth in 40 CFR 70. The affirmative defense provisions described below may not be applied to any situation that caused the Facility to exceed any federally delegated regulation, including but not limited to NSPS, NESHAP, or MACT.
 - b. For situations other than those covered above, an affirmative defense is available for a violation of a provision or condition of the operating permit only if:
 - i. The violation occurred as a result of an equipment malfunction, an equipment startup or shutdown, or during the performance of necessary equipment maintenance; and
 - ii. The affirmative defense is asserted and established as required by N.J.S.A. 26:2C-19.1 through 19.5 and any implementing rules. [N.J.A.C. 7:27-22.16(l)]
11. In the event of a challenge to any part of this operating permit, all other parts of the permit shall continue to be valid. [N.J.A.C. 7:27-22.16(f)]
12. Each owner and each operator of any facility, source operation, or activity to which this permit applies is responsible for ensuring compliance with all requirements of N.J.A.C. 7:27-22. If the owner and operator are separate persons, or if there is more than one owner or operator, each owner and each operator is jointly and severally liable for any fees due under N.J.A.C. 7:27-22, and for any penalties for violation of N.J.A.C. 7:27-22. [N.J.A.C. 7:27-22.3]
13. The permittee shall ensure that no air contaminant is emitted from any significant source operation at a rate, calculated as the potential to emit, that exceeds the applicable threshold for reporting emissions set forth in the Appendix to N.J.A.C. 7:27-22 or 7:27-17.9(a), unless emission of the air contaminant is authorized by this operating permit. [N.J.A.C. 7:27-22.3(c)]
14. Consistent with the provisions of N.J.A.C. 7:27-22.3(e), the permittee shall ensure that all requirements of this operating permit are met. In the event that there are multiple emission limitations, monitoring, recordkeeping, and/or reporting requirements for a given source operation, the facility must comply with all requirements, including the most stringent.
15. Consistent with the provisions of N.J.A.C. 7:27-22.3(s), Except as otherwise provided in this subchapter, the submittal of any information or application by a permittee including, but not limited to, an application or notice for any change to the operating permit, including any administrative amendment, any minor or significant modification, renewal, a notice of a seven-day notice change, a notice of past or anticipated noncompliance, does not stay any operating permit condition, nor relieve a permittee from the obligation to obtain other necessary permits and to comply with all applicable Federal, State, and local requirements.

16. Applicable requirements derived from an existing or terminated consent decree with EPA will not be changed without advance consultation by the Department with EPA. N.J.A.C. 7:27-22.3(uu).
17. Unless specifically exempted from permitting, temporary mobile equipment for short-term activities may be periodically used at major facilities, on site for up to 90 days if the requirements listed below, (a) through (h) are satisfied.
 - a. The permittee will ensure that the temporary mobile equipment will not be installed permanently or used permanently on site.
 - b. The permittee will ensure that the temporary mobile equipment will not circumvent any State or Federal rules and regulations, even for a short period of time, and the subject equipment will comply with all applicable performance standards.
 - c. The permittee cannot use temporary mobile equipment unless the owner or operator of the subject equipment has obtained and maintains an approved Air Pollution Control Permit, issued pursuant to N.J.A.C. 7:27-8 or 22, prior to bringing the temporary mobile equipment to operate at the major facility.
 - d. The permittee is responsible for ensuring the temporary mobile equipment's compliance with the terms and conditions specified in its approved Air Pollution Control Permit when the temporary mobile equipment operates on the property of the permittee.
 - e. The permittee will ensure that temporary mobile equipment utilized for short-term activities will not operate on site for more than a total of 90 days during any calendar year.
 - f. The permittee will keep on site a list of temporary mobile equipment being used at the facility with the start date, end date, and record of the emissions from all such equipment (amount and type of each air contaminant) no later than 30 days after the temporary mobile equipment completed its job in accordance with N.J.A.C. 7:27-22.19(i)3.
 - g. Emissions from the temporary mobile equipment must be included in the emission netting analysis required of the permittee by N.J.A.C. 7:27-18.7. This information is maintained on site by the permittee and provided to the Department upon request in accordance with existing applicable requirements in the FC Section of its Title V permit.
 - h. Where short-term activities (employing temporary mobile equipment) will reoccur on at least an annual basis, the permittee is required to include such activities (and the associated equipment) within one year of the first use, in its Title V permit through the appropriate modification procedures.
18. Consistent with the provisions of N.J.A.C. 7:27-22.9(c), the permittee shall use monitoring of operating parameters, where required by the compliance plan, as a surrogate for direct emissions testing or monitoring, to demonstrate compliance with applicable requirements.
19. The permittee is responsible for submitting timely and administratively complete operating permit applications:

Administrative Amendments [N.J.A.C. 7:27-22.20(c)];
Seven-Day Notice changes [N.J.A.C. 7:27-22.22(e)];
Minor Modifications [N.J.A.C. 7:27-22.23(e)];
Significant Modifications [N.J.A.C. 7:27-22.24(e)]; and
Renewals [N.J.A.C. 7:27-22.30(b)].
20. The operating permit renewal application consists of a RADIUS application and the application attachment available at the Department's website <https://dep.nj.gov/boss/applications-and-forms/> (Attachment to the RADIUS Operating Permit Renewal Application). Both the RADIUS application and the Application Attachment, along with any other supporting documents must be submitted using the Department's Portal

at: <https://njdeponline.com/>. The application is considered timely if it is received at least 12 months before the expiration date of the operating permit. To be deemed administratively complete, the renewal application shall include all information required by the application form for the renewal and the information required pursuant to N.J.A.C. 7:27-22.30(d). However, consistent with N.J.A.C. 7:27-22.30(c), the permittee is encouraged to submit the renewal application at least 15 months prior to expiration of the operating permit, so that any deficiencies can be identified and addressed to ensure that the application is administratively complete by the renewal deadline. Only renewal applications which are timely and administratively complete are eligible for an application shield.

21. For all source emissions testing performed at the facility, the phrase “worst case conditions without creating an unsafe condition” used in the enclosed compliance plan is consistent with EPA’s National Stack Testing Guidance, dated April 27, 2009, where all source emission testing performed at the facility shall be under the representative (normal) conditions that:
 - i. Represent the range of combined process and control measure conditions under which the facility expects to operate (regardless of the frequency of the conditions); and
 - ii. Are likely to most challenge the emissions control measures of the facility with regard to meeting the applicable emission standards, but without creating an unsafe condition.
22. Consistent with EPA’s National Stack Testing Guidance and Technical Manual 1004, a facility may not stop an ongoing stack test because it would have failed the test unless the facility also ceases operation of the equipment in question to correct the issue. Stopping an ongoing stack test in these instances will be considered credible evidence of emissions non-compliance.
23. Each permittee shall maintain records of all source emissions testing or monitoring performed at the facility and required by the operating permit in accordance with N.J.A.C. 7:27-22.19. Records shall be maintained, for at least five years from the date of each sample, measurement, or report. Each permittee shall maintain all other records required by this operating permit for a period of five years from the date each record is made. At a minimum, source emission testing or monitoring records shall contain the information specified at N.J.A.C. 7:27-22.19(b). [N.J.A.C. 7:27-22.19(a) and N.J.A.C. 7:27-22.19(b)]
24. A Permittee may seek the approval of the Department for a delay in testing required pursuant to this permit by submitting a written request to the appropriate Regional Enforcement Office in accordance with N.J.A.C. 7:27-22.18(k). A Permittee may also seek advanced approval for a longer period for submittal of a source emissions test report required by the permit by submitting a request to the Department’s Regional Enforcement Office in accordance with N.J.A.C. 7:27-22.19. [N.J.A.C. 7:27-22.18(k) and N.J.A.C. 7:27-22.19]
25. Testing every 5 years shall be defined as no later than the end of the 60th month after the first required and each subsequent stack test was completed for the new or modified source.

Section C

Facility Name: LINDEN CITY SLF
Program Interest Number: 42247
Permit Activity Number: BOP180001

STATE-ONLY APPLICABLE REQUIREMENTS

N.J.A.C. 7:27-22.16(b)5 requires the Department to specifically designate as not being federally enforceable any permit conditions based only on applicable State requirements. The applicable State requirements to which this provision applies are listed in the table titled "State-Only Applicable Requirements."

STATE-ONLY APPLICABLE REQUIREMENTS

The following applicable requirements are not federally enforceable:

<u>SECTION</u>	<u>SUBJECT ITEM</u>	<u>ITEM #</u>	<u>REF. #</u>
B	---	1	---
B	---	10b	---
D	FC	---	3
D	FC	---	9

Section D

Facility Name: LINDEN CITY SLF
Program Interest Number: 42247
Permit Activity Number: BOP180001

FACILITY SPECIFIC REQUIREMENTS AND INVENTORIES

FACILITY SPECIFIC REQUIREMENTS PAGE INDEX

<u>Subject Item and Name</u>	<u>Page Number</u>
------------------------------	--------------------

Facility (FC):

FC	1
----	---

Insignificant Sources (IS):

IS NJID	IS Description	
IS1	Cummins/Onan 25 KW Emergency Generator -diesel powered	7
IS2	70 gal diesel tank	11

Groups (GR):

GR NJID	GR Designation	GR Description	
<NO DATA FOUND>			12

Emission Units (U):

U NJID	U Designation	U Description	
U1	MSW Landfill	Landfill Gas collected by 54 Active Vents controlled by Enclosed Flare (CD1) subject to NSPS subpart WWW and MACT AAAA - Closed Landfill in 2003	14

LINDEN CITY SLF (42247)
BOP180001

Date: 8/30/2023

New Jersey Department of Environmental Protection
Reason for Application

Permit Being Modified

Permit Class: BOP **Number:** 220001

Description Linden SLF Five Year Operating Permit Renewal
of Modifications:

BOP180001

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Subject Item: FC

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
1	General Provisions: The permittee shall comply with all applicable provisions of N.J.A.C. 7:27-1. [N.J.A.C. 7:27- 1]	None.	None.	None.
2	Control and Prohibition of Open Burning: The permittee is prohibited from open burning of rubbish, garbage, trade waste, buildings, structures, leaves, other plant life and salvage. Open burning of infested plant life or dangerous material may only be performed with a permit from the Department. [N.J.A.C. 7:27- 2]	None.	None.	Obtain an approved permit: Prior to occurrence of event (prior to open burning). [N.J.A.C. 7:27- 2]
3	Prohibition of Air Pollution: The permittee shall not emit into the outdoor atmosphere substances in quantities that result in air pollution as defined at N.J.A.C. 7:27-5.1. [N.J.A.C. 7:27- 5]	None.	None.	None.
4	Prevention and Control of Air Pollution Control Emergencies: Any person responsible for the operation of a source of air contamination set forth in Table 1 of N.J.A.C. 7:27-12 is required to prepare a written Standby Plan, consistent with good industrial practice and safe operating procedures, and be prepared for reducing the emission of air contaminants during periods of an air pollution alert, warning, or emergency. Any person who operates a source not set forth in Table 1 of N.J.A.C. 7:27-12 is not required to prepare such a plan unless requested by the Department in writing. [N.J.A.C. 7:27-12]	None.	None.	Comply with the requirement: Upon occurrence of event. Upon proclamation by the Governor of an air pollution alert, warning, or emergency, the permittee shall put the Standby Plan into effect. In addition, the permittee shall ensure that all of the applicable emission reduction objectives of N.J.A.C. 7:27-12.4, Table I, II, and III are complied with whenever there is an air pollution alert, warning, or emergency. [N.J.A.C. 7:27-12]
5	Emission Offset Rules: The permittee shall comply with all applicable provisions of Emission Offset Rules. [N.J.A.C. 7:27-18]	None.	None.	None.
6	Emission Statements: The permittee shall comply with all the applicable provisions of N.J.A.C. 7:27-21. [N.J.A.C. 7:27-21]	None.	None.	None.

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
7	Compliance Certification: The permittee shall submit an annual Compliance Certification for each applicable requirement, pursuant to N.J.A.C. 7:27-22.19(f). [N.J.A.C. 7:27-22]	None.	None.	<p>Submit an Annual Compliance Certification: Annually to the Department and to EPA within 60 days after the end of each calendar year during which this permit was in effect. The Compliance Certification shall be certified pursuant to N.J.A.C. 7:27-1.39 by the responsible official and submitted electronically through the NJDEP online web portal. The certification should be printed for submission to EPA.</p> <p>The NJDEP online web portal can be accessed at: http://www.state.nj.us/dep/online/. The Compliance Certification forms and instructions for submitting to EPA are available by selecting Documents and Forms and then Periodic Compliance Certification. [N.J.A.C. 7:27-22]</p>
8	Prevention of Air Pollution from Consumer Products and Architectural Coatings: The permittee shall comply with all applicable provisions of N.J.A.C. 7:27-24 and [N.J.A.C. 7:27-23]	None.	None.	None.
9	Any operation of equipment which causes off-property effects, including odors, or which might reasonably result in citizen's complaints shall be reported to the Department to the extent required by the Air Pollution Control Act, N.J.S.A. 26:2C-19(e). [N.J.S.A. 26: 2C-19(e)]	Other: Observation of plant operations. [N.J.S.A. 26: 2C-19(e)].	Other: Maintain a copy of all information submitted to the Department. [N.J.S.A. 26: 2C-19(e)].	<p>Notify by phone: Upon occurrence of event. A person who causes a release of air contaminants in a quantity or concentration which poses a potential threat to public health, welfare or the environment or which might reasonably result in citizen complaints shall immediately notify the Department. Such notification shall be made by calling the Environmental Action Hotline at (877) 927-6337. [N.J.S.A. 26: 2C-19(e)]</p>
10	Prevention of Significant Deterioration: The permittee shall comply with all applicable provisions of Prevention of Significant Deterioration (PSD). [40 CFR 52.21]	None.	None.	None.

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
11	The permittee shall comply with all applicable provisions of National Emission Standards for Hazardous Air Pollutants (NESHAPS) for Asbestos, Subpart M. [40 CFR 61]	Other: Comply with 40 CFR 61.145 and 61.150 when conducting any renovation or demolition activities at the facility. [40 CFR 61].	Other: Comply with 40 CFR 61.153 when conducting any renovation or demolition activities at the facility. [40 CFR 61].	Comply with the requirement: Upon occurrence of event. The permittee shall comply with 40 CFR 61.153 when conducting any renovation or demolition activities at the facility. [40 CFR 61]
12	Protection of Stratospheric Ozone: 1) If the permittee manufactures, transforms, destroys, imports, or exports a Class I or Class II substance, the permittee is subject to all the requirements as specified at 40 CFR 82, Subpart A; 2) If the permittee performs a service on motor "fleet" vehicles when this service involves an ozone depleting substance refrigerant (or regulated substance) in the motor vehicle air conditioner (MVAC), the permittee is subject to all the applicable requirements as specified at 40 CFR 82, Subpart B. 3) The permittee shall comply with the standards for labeling of products containing or manufactured with ozone depleting substances pursuant to 40 CFR 82, Subpart E. 4). The permittee shall comply with the standards for recycling and emission reductions of Class I and Class II refrigerants or a regulated substitute substance during the service, maintenance, repair, and disposal of appliances pursuant to 40 CFR 82, Subpart F, except as provided for motor vehicle air conditioners (MVACs) in Subpart B. 5) The permittee shall be allowed to switch from any ozone depleting substance to any alternative that is listed in the Significant New Alternative Program (SNAP) promulgated pursuant to 40 CFR 82, Subpart G. [40 CFR 82]	Other: Comply with 40 CFR 82 Subparts A, B, E, F, and G. [40 CFR 82].	Other: Comply with 40 CFR 82 Subparts A, B, E, F, and G. [40 CFR 82].	Comply with the requirement: Upon occurrence of event. The permittee shall comply with 40 CFR 82 Subparts A, B, E, F, and G. [40 CFR 82]

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
13	Deviation Reports: The permittee shall submit to the Department a certified six-month Deviation Report relating to testing and monitoring required by the operating permit. [N.J.A.C. 7:27-22.19(d)3], [N.J.A.C. 7:27-22.19(e)], and [N.J.A.C. 7:27-22.19(c)]	None.	Other: The permittee shall maintain deviation reports for a period of five years from the date each report is submitted to the Department. [N.J.A.C. 7:27-22.19(a)] and [N.J.A.C. 7:27-22.19(e)].	Submit a report: As per the approved schedule. The six-month deviation reports for the period from January 1 through June 30 shall be submitted by July 30 of the same calendar year, and for the period from July 1 through December 31, shall be submitted by January 30 of the following calendar year. The annual compliance certification required by N.J.A.C. 7:27-22.19(f) may also be considered as your six-month Deviation Report for the period from July 1 – December 31, if submitted by January 30 of the following calendar year. The reports shall be certified pursuant to N.J.A.C. 7:27-1.39 by the responsible official and submitted electronically through the NJDEP online web portal. The NJDEP online web portal can be accessed at: http://www.state.nj.us/dep/online/ . The Compliance Certification forms are available by selecting Documents and Forms and then Periodic Compliance Certification. [N.J.A.C. 7:27-22]
14	Used Oil Combustion: No person shall combust used oil except as authorized pursuant to N.J.A.C. 7:27-20. [N.J.A.C. 7:27-20.2]	None.	None.	Comply with the requirement: Prior to occurrence of event (prior to burning used oil) either register with the Department pursuant to N.J.A.C. 7:27-20.3 or obtain a permit issued by the Department pursuant to N.J.A.C. 7:27-8 or 7:27-22, whichever is applicable. [N.J.A.C. 7:27-20.2(d)]
15	Prevention of Accidental Releases: Facilities producing, processing, handling or storing a chemical, listed in the tables of 40 CFR Part 68.130, and present in a process in a quantity greater than the listed Threshold Quantity, shall comply with all applicable provisions of 40 CFR 68. [40 CFR 68]	Other: Comply with 40 CFR 68. [40 CFR 68].	Other: Comply with 40 CFR 68. [40 CFR 68].	Other (provide description): Other. Comply with 40 CFR 68 as described in the Applicable Requirement. [40 CFR 68]

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
16	The Department and its authorized representatives shall have the right to enter and inspect any activity subject to N.J.A.C. 7:27-22, or portion thereof, pursuant to N.J.A.C. 7:27-1.31. [N.J.A.C. 7:27-22.16(g)9]	None.	None.	None.
17	The permittee shall pay fees to the Department pursuant to N.J.A.C. 7:27. [N.J.A.C. 7:27-22.16(g)10]	None.	None.	None.
18	Each permittee shall meet all requirements of the approved source emissions testing and monitoring protocol during the term of the operating permit. Whenever the permittee makes a replacement, modification, change or repair of a certified CEMS or COMS that may significantly affect the ability of the system to accurately measure or record data, the permittee must recertify the CEMS or COMS in accordance with Section V.B. and Appendix E of Technical Manual 1005. The permittee is responsible for any downtime associated with the replacement, modification, change or repair of the CEMS or COMS. [N.J.A.C. 7:27-22.18(j)]	None.	None.	Comply with the requirement: Upon occurrence of event. The permittee is responsible for contacting the Emission Measurement Section to determine the need for recertification and/or to initiate the recertification process. [N.J.A.C. 7:27-22.18(j)]
19	Each process monitor must be operated at all times when the associated process equipment is operating except during service outage time not to exceed 24 hours per calendar quarter. [N.J.A.C. 7:27-22.16(a)]	None.	Recordkeeping by manual logging of parameter or storing data in a computer data system upon occurrence of event. The permittee must keep a service log to document any outage. [N.J.A.C. 7:27-22.16(o)]	None.
20	Continuous recording for process monitors must be at a sufficient frequency and resolution to be able to document compliance or non-compliance in accordance with Technical Manual 1005 for CEMS (TM1005(B)(3)). [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.

BOP180001

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
21	If an operating permit has expired, the conditions of the operating permit, including the requirements for stack testing during the expired permit term, remain enforceable until the operating permit is reissued. [N.J.A.C. 7:27-22.30(j)] and [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.

BOP180001

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Subject Item: IS1 Cummins/Onan 25 KW
Emergency Generator -
diesel powered

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
1	Opacity <= 20 % , exclusive of visible, condensed water vapor, for more than 10 consecutive seconds. [N.J.A.C. 7:27- 3.5]	Opacity: Monitored by visual determination once initially and prior to permit expiration date, based on any consecutive 30-minute period. [N.J.A.C. 7:27-22.16(o)]	None.	None.
2	Sulfur Content in Fuel <= 15 ppmw (0.0015% by weight). [N.J.A.C. 7:27- 9.2(b)]	Sulfur Content in Fuel: Monitored by review of fuel delivery records per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	Sulfur Content in Fuel: Recordkeeping by invoices / bills of lading / certificate of analysis per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	None.
3	Fuel stored in New Jersey that met the applicable maximum sulfur content standard of Tables 1A or 1B of N.J.A.C. 7:27-9.2 at the time it was stored in New Jersey may be used in New Jersey after the operative date of the applicable standard in Table 1B. [N.J.A.C. 7:27- 9.2(b)]	None.	None.	None.

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
4	<p>This emergency generator shall not be used:</p> <p>1. For normal testing and maintenance on days when the Department forecasts air quality anywhere in New Jersey to be "unhealthy for sensitive groups," "unhealthy," or "very unhealthy" as defined in the EPA's Air Quality Index at http://airnow.gov/, as supplemented or amended and incorporated herein by reference, unless required in writing by a Federal or State law or regulation. Procedures for determining the air quality forecasts for New Jersey are available at the Department's air quality permitting web site at http://www.state.nj.us/dep/aqpp/aqforecast; and</p> <p>2. As a source of energy or power after the primary energy or power source has become operable again. If the primary energy or power source is under the control of the owner or operator of the emergency generator, the owner or operator shall make a reasonable, timely effort to repair the primary energy or power source. [N.J.A.C. 7:27-19.2(d)]</p>	None.	None.	None.

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
5	<p>The emergency generator shall be located at the facility and produce mechanical or thermal energy, or electrical power exclusively for use at the facility. This emergency generator shall be operated only:</p> <ol style="list-style-type: none"> 1. During the performance of normal testing and maintenance procedures, as recommended in writing by the manufacturer and/or as required in writing by a Federal or State law or regulation, 2. When there is power outage or the primary source of mechanical or thermal energy fails because of an emergency, or 3. When there is a voltage reduction issued by PJM and posted on the PJM internet website (www.pjm.com) under the "emergency procedures" menu. [N.J.A.C. 7:27-19.1] 	<p>Monitored by hour/time monitor continuously. [N.J.A.C. 7:27-22.16(o)]</p>	<p>Other: The Permittee shall maintain on site and record in a logbook or computer data system, the following information if maximum rated output is 37 kW or greater:</p> <ol style="list-style-type: none"> 1. For each time the emergency generator is specifically operated for testing or maintenance: <ol style="list-style-type: none"> i. The reason for its operation; ii. The date(s) of operation and the start up and shut down time; iii. The total operating time for testing or maintenance based on the generator's hour meter; and iv. The name of the operator; and 2. If a voltage reduction is the reason for the use of the emergency generator, a copy of the voltage reduction notification from PJM or other documentation of the voltage reduction. [N.J.A.C. 7:27-19.11]. 	<p>None.</p>

BOP180001

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
6	Hours of Operation <= 30 hr/yr for testing and maintenance. The limit on the allowable hours for testing and maintenance in accordance with the documentation from manufacturer, the vendor, or the insurance company associated with the engine. [N.J.A.C. 7:27-22.16(a)]	Hours of Operation: Monitored by hour/time monitor continuously. [N.J.A.C. 7:27-22.16(o)]	Hours of Operation: Recordkeeping by manual logging of parameter or storing data in a computer data system upon occurrence of event. The owner or operator shall maintain on site and record the following information: For each time the emergency generator is specifically operated for testing or maintenance: i. The reason for its operation; ii. The date(s) of operation and the start up and shut down time; iii. The total operating time for testing or maintenance based on the generator's hour meter; and iv. The name of the operator. [N.J.A.C. 7:27-19.11]	None.

BOP180001

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Subject Item: IS2 70 gal diesel tank

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
1	Sulfur Content in Fuel <= 15 ppmw (0.0015% by weight). Effective July 1, 2016. [N.J.A.C. 7:27- 9.2(a)]	Sulfur Content in Fuel: Monitored by review of fuel delivery records per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	Sulfur Content in Fuel: Recordkeeping by invoices / bills of lading / certificate of analysis per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	None.
2	Fuel stored in New Jersey that met the applicable maximum sulfur content standard of Tables 1A or 1B of N.J.A.C. 7:27-9.2 at the time it was stored in New Jersey may be used in New Jersey after the operative date of the applicable standard in Table 1B. [N.J.A.C. 7:27- 9.2(a)]	None.	None.	None.

BOP180001

New Jersey Department of Environmental Protection
Facility Specific Requirements

Emission Unit: U1 Landfill Gas collected by 54 Active Vents controlled by Enclosed Flare (CD1) subject to NSPS subpart WWW and MACT AAAA - Closed Landfill in 2003

Subject Item: CD1 ZTOF Enclosed Flare

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
1	The flare shall be designed to reduce the concentration of Non-Methane Organic Compounds by no less than 95%. The flare shall be installed, operated and maintained in accordance with the specifications provided by the manufacturer. [N.J.A.C. 7:27-16.13(a)]	None.	None.	None.
2	The permittee shall inspect the flare before May 1 of each year to verify that the flare continues to be operated in accordance with the manufacturer's specifications for the operation of the flare. [N.J.A.C. 7:27-16.13(c)]	Monitored by visual determination annually. [N.J.A.C. 7:27-22.16(o)]	Recordkeeping by manual logging of parameter or storing data in a computer data system annually before May 1 of each year. The permittee shall record the following: 1. The name of the person conducting the inspection; 2. The date on which the inspection is conducted; 3. An entry indicating which flare was inspected; 4. Any changes or adjustments made to the flare as a result of the inspection; and 5. A statement indicating that the flare is currently being operated in compliance with the manufacturer's specifications. [N.J.A.C. 7:27-16.13(c)]	None.
3	The flare shall reduce the concentration of Non-methane Organic Carbon (NMOC) by no less than 98% or 20 ppmvd @ 3% O ₂ expressed as Hexane. [N.J.A.C. 7:27-22.16(a)]	Monitored by stack emission testing every 5 years (based on completion date of the last stack test), based on each of three Department validated stack test runs. See elsewhere in OS Summary for stack test details. [N.J.A.C. 7:27-22.16(o)]	Recordkeeping by stack test results every 5 years (based on completion date of the last stack test). See elsewhere in OS Summary for stack test details. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule. See elsewhere in OS Summary for stack test details. [N.J.A.C. 7:27-22.16(o)]

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
4	During times when there is not sufficient methane loading to the flare to maintain continuous combustion at the minimum operating temperature, the flare will automatically shut-down when the minimum operating temperature cannot be achieved within a period of 10 consecutive minutes. When the enclosed flare is shut down, the owner or operator shall make sure that the active vent system will also be shut down automatically so that no landfill gas will exit to atmosphere. [N.J.A.C. 7:27-22.16(a)]	Monitored by temperature instrument continuously. [N.J.A.C. 7:27-22.16(o)]	Recordkeeping by manual logging of parameter or storing data in a computer data system upon occurrence of event. Each shut down and start up event shall be recorded. [N.J.A.C. 7:27-22.16(o)]	None.
5	The permittee shall monitor the flare pilot burners by a thermocouple or any equivalent device to ensure the presence of a pilot flame. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
6	The permittee shall install, operate and maintain an automatic system (or equivalent) on the flare to monitor the presence of a flame to ensure maintenance of flare combustion. When flare combustion ceases, there shall be automatic shut-off of the flow of gas to the flare. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.

BOP180001

New Jersey Department of Environmental Protection
Facility Specific Requirements

Emission Unit: U1 Landfill Gas collected by 54 Active Vents controlled by Enclosed Flare (CD1) subject to NSPS subpart WWW and MACT AAAA - Closed Landfill in 2003

Operating Scenario: OS Summary

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
1	Summary of Applicable Federal Regulations: 40 CFR 60 Subpart A 40 CFR 60 Subpart WWW 40 CFR 63 Subpart A 40 CFR 63 MACT AAAA [40 CFR Federal Rules Summary]	None.	None.	None.
2	<p>RENEWAL STACK TESTING SUMMARY The permittee shall conduct a stack test no later than every five years (see General Provisions) from the last stack test using an approved protocol to demonstrate compliance with emission limits for NO_x, CO, SO₂, TSP, PM-10, PM-2.5, Methane, Non-Methane Organic Carbon (NMOC) emission limits, NMOC reduction efficiency, and the following HAP: Acrylonitrile as specified in the compliance plan for U1 OS Summary and for U1 OS1.</p> <p>Testing must be conducted at worst-case permitted operating conditions with regard to meeting the applicable emission standards, but without creating an unsafe condition. [N.J.A.C. 7:27-22.16(a)]</p>	Other: Monitoring as required under the applicable operating scenario(s). [N.J.A.C. 7:27-22.16(o)].	Other: Recordkeeping as required under the applicable operating scenario(s). [N.J.A.C. 7:27-22.16(o)].	<p>Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule Submit a stack test protocol to the Emission Measurement Section (EMS) at Mail Code: 09-01, PO Box 420, Trenton, NJ 08625 no later than 12 months prior to the expiration of the approved operating permit. The protocol and test report must be prepared and submitted on a CD using the Electronic Reporting Tool (ERT), unless another format is approved by EMS. The ERT program can be downloaded at: http://www.epa.gov/ttnchie1/ert. Within 30 days of protocol approval or no less than 60 days prior to the testing deadline, whichever is later, the permittee must contact EMS at 609-984-3443 to schedule a mutually acceptable test date.</p> <p>A full stack test report must be submitted to EMS and a certified summary test report must be submitted to the Regional Enforcement Office within 45 days after performing the stack test pursuant to N.J.A.C. 7:27-22.19(d). The test results must be certified by a licensed professional engineer or certified industrial hygienist. [N.J.A.C. 7:27-22.18(e)] and. [N.J.A.C. 7:27-22.18(h)]</p>

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
3	NOx (Total) <= 1.2 tons/yr . [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
4	CO <= 3.99 tons/yr . [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
5	SO2 <= 1.03 tons/yr. Based on maximum LFG flow to flare (below). [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
6	TSP <= 0.34 tons/yr . [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
7	PM-10 (Total) <= 0.34 tons/yr. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
8	PM-2.5 (Total) <= 0.34 tons/yr. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
9	HAPs (Total) <= 0.00067 tons/yr. Permittee's maximum annual emission limit (total emissions from all stacks). [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
10	Acrylonitrile <= 0.00067 tons/yr. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
11	Methane <= 154.4 tons/yr , emission limit of Uncollected (fugitive) methane from the landfill (146.12 tpy) and uncombusted methane from the flare (8.28 tpy.). [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
12	Methane <= 35.3 lb/hr. Maximum emission rate of uncollected (fugitive) methane from the landfill (33.4 lb/hr) and uncombusted methane from the flare (1.89 lb/hr.). [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
13	Reduced Sulfur Compounds <= 160 ppmvd @ 7% O2 as sulfur at maximum permitted LFG flow to flare. [N.J.A.C. 7:27-22.16(a)]	Reduced Sulfur Compounds: Monitored by gas sampling quarterly: once per quarter; quarters shall begin on January 1, April 1, July 1, and October 1 of each year. [N.J.A.C. 7:27-22.16(o)]	Reduced Sulfur Compounds: Recordkeeping by certified lab analysis results upon occurrence of event. Calculate total reduced sulfur compounds and retain calculations in file. [N.J.A.C. 7:27-22.16(o)]	Submit a report: Within 60 days of sampling. The report shall be submitted to the regional enforcement office. [N.J.A.C. 7:27-22.16(o)]

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
14	The annual emission rates of all HAPs, excluding Acrylonitrile, are less than the respective reporting thresholds specified in N.J.A.C. 7:27-17.9. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
15	The Permittee shall sample and analyze the landfill gas (including: Methane, Ammonia, Non-Methane Hydrocarbons including: Acetone (2-Propanone), Ethanol, 1,2,4-Trimethyl Benzene, 1,3,5- Trimethyl, Cyclohexane, Tetrahydrofuran, 4- Ethyl Toluene, Heptane, and Propylene (Propene); Sulfur compounds including Hydrogen Sulfide; Chlorinated compounds including: Chloromethane, Chlorodifluoromethane, Dichlorofluoromethane (Freon 21), Freon 12 (Dichlorodifluoromethane), Trichlorofluoromethane (Freon 11), and cis-1,2- Dichloroethylene; and HAPs including: 2- Butanone, Carbon Disulfide, o- Xylene, Toluene, Vinyl Chloride, Benzene, Chlorobenzene, Ethyl Benzene, m-/p- Xylenes, Hexane, 2,2,4- Trimethylpentane, and 1,4- Dichlorobenzene) and shall determine the heating value of gas. [N.J.A.C. 7:27-22.16(a)]	Monitored by gas sampling quarterly: once per quarter; quarters shall begin on January 1, April 1, July 1, and October 1 of each year. [N.J.A.C. 7:27-22.16(o)]	Recordkeeping by certified lab analysis results quarterly: once per quarter; quarters shall begin on January 1, April 1, July 1, and October 1 of each year. [N.J.A.C. 7:27-22.16(o)]	Submit a report: Within 60 days of sampling. The report shall be submitted to the regional enforcement office. [N.J.A.C. 7:27-22.16(o)]
16	The permittee shall analyse the landfill gas for methane, carbon dioxide, oxygen, temperature and static pressure and shall determine the heating value of the gas at the time of adjustment of each control valve on each vent. Adjustment as required at 40 CFR 60 Subpart WWW [40 CFR 60.753] & [N.J.A.C. 7:27-22.16(a)]	Monitored by gas sampling each month during operation, based on an instantaneous determination using a handheld instrument. [N.J.A.C. 7:27-22.16(o)]	Recordkeeping by manual logging of parameter or storing data in a computer data system each month during operation at each vent. [N.J.A.C. 7:27-22.16(o)]	None.

New Jersey Department of Environmental Protection
Facility Specific Requirements

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
17	Other Gaseous Fuel Usage <= 150 SCFM , total landfill gas flow to the enclosed flare. [N.J.A.C. 7:27-22.16(a)]	Other Gaseous Fuel Usage: Monitored by gas flow rate instrument continuously to the enclosed flare - monitored in scfm. The flow rate monitoring system shall: (1) correct and report from actual to standard cubic feet; (2) have an overall accuracy of 0.5% of the upper range value or the best accuracy available; (3) be installed and operated in accordance with the instructions of the manufacturer; and (4) be equipped with a totalizer to continuously monitor the cumulative amount of landfill gas directed to the flare in scf. [N.J.A.C. 7:27-22.16(o)]	Other Gaseous Fuel Usage: Recordkeeping by strip chart or data acquisition (DAS) system continuously. [N.J.A.C. 7:27-22.16(o)]	None.
18	All requests, reports, applications, submittals, and other communications to the Administrator pursuant to Part 60 shall be submitted in duplicate to the Regional Office of US Environmental Protection Agency. Submit information to: Region II, Director, Air and Waste Management Division, US Environmental Protection Agency, 21st Floor, 290 Broadway, New York, NY 10007. [40 CFR 60.4(a)]	None.	None.	Submit a report: As per the approved schedule to EPA Region II. [40 CFR 60.4(a)]
19	Copies of all information submitted to EPA pursuant to 40 CFR Part 60, must also be submitted to the appropriate Regional Enforcement Office of NJDEP. [40 CFR 60.4(b)]	None.	None.	Submit a report: As per the approved schedule to the appropriate Regional Enforcement Office of NJDEP. [40 CFR 60.4(b)]
20	The owner or operator subject to the provisions of 40 CFR Part 60 shall furnish the Administrator written notification or, if acceptable to both the Administrator and the owner or operator of a source, electronic notification, of the date of construction or reconstruction of an affected facility as defined under 40 CFR Part 60 Subpart A. Notification shall be postmarked no later than 30 days after such date. [40 CFR 60.7(a)(1)]	None.	None.	Submit notification: Upon occurrence of event to EPA Region II and the appropriate Regional Enforcement Office of NJDEP. [40 CFR 60.7(a)(1)]

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
21	The owner or operator subject to the provisions of 40 CFR Part 60 shall furnish the Administrator written notification or, if acceptable to both the Administrator and the owner or operator of a source, electronic notification, of the actual date of initial startup of an affected facility postmarked within 15 days after such date. [40 CFR 60.7(a)(3)]	None.	None.	Submit notification: Upon occurrence of event to EPA Region II and the appropriate Regional Enforcement Office of NJDEP. [40 CFR 60.7(a)(3)]
22	The owner or operator shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility, any malfunction of air pollution control equipment or any periods during which continuous monitoring system or monitoring device is inoperative. [40 CFR 60.7(b)]	None.	Recordkeeping by manual logging of parameter upon occurrence of event. The records should be kept in a permanent form suitable for inspections. [40 CFR 60.7(b)]	None.
23	The owner or operator shall maintain a file, suitable for inspection, of all monitoring measurements as indicated in Recordkeeping Requirement column. [40 CFR 60.7(f)]	None.	Other: The file shall include all measurements (including continuous monitoring system, monitoring device, and performance testing measurements), all continuous monitoring system performance evaluations, all continuous monitoring system or monitoring device calibration checks, all adjustments/maintenance performed on these systems or devices, and all other information required by 40 CFR Part 60 recorded in a permanent form suitable for inspection. [40 CFR 60.7(f)].	None.
24	The owner or operator shall conduct performance tests and data reduced in accordance with the test methods and procedures contained in each applicable subpart, unless otherwise specified and approved by the Administrator. [40 CFR 60.8(b)]	None.	None.	None.

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
25	Performance tests shall be conducted under conditions the Administrator specifies to the plant operator based on representative performance of the affected facility. Operations during periods of startup, shutdown and malfunction shall not constitute representative conditions for the purpose of the performance test nor shall emissions in excess of the level of the applicable emission limit be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)]	None.	None.	None.
26	The owner or operator shall provide the Administrator at least 30 days prior notice of any performance test and shall provide adequate performance testing facilities as specified in 40 CFR Part 60.8(e). [40 CFR 60.8(d)]	None.	None.	None.
27	Unless otherwise specified in the applicable subpart, each performance test shall consist of three separate runs using the applicable test method. [40 CFR 60.8(f)]	None.	None.	None.
28	Compliance with NSPS standards specified in this permit, other than opacity, shall be determined only by performance tests established by 40 CFR 60.8, unless otherwise specified in NSPS. [40 CFR 60.11(a)]	None.	None.	None.
29	The owner or operator shall demonstrate compliance with NSPS opacity standards specified in 40 CFR Part 60. [40 CFR 60.11(b)]	Other: Monitoring and demonstration of compliance shall be by Method 9. For purposes of determining initial compliance, the minimum total time of observations shall be 3 hours for the performance test.[40 CFR 60.11(b)].	Other: The owner or operator shall maintain records of opacity of emissions based on approval of alternative method. [40 CFR 60.11(e)(2)].	Submit a report: At a common schedule agreed upon by the operator and the Administrator. The owner or operator shall submit to the Administrator for approval an alternative method to demonstrate compliance and data shall be submitted based on alternative approved method. [40 CFR 60.11(e)(2)]
30	The NSPS opacity standard shall apply at all times except during periods of startup, shutdown, malfunctions and as otherwise specified in this permit. [40 CFR 60.11(c)]	None.	None.	None.

U1 Landfill Gas collected by 54 Active Vents controlled by Enclosed Flare (..

BOP180001

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
31	At all times, including periods of start-up, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, opacity observations, review of operation and maintenance procedures, and inspection of the source. [40 CFR 60.11(d)]	None.	None.	None.
32	No owner or operator subject to NSPS standards in Part 60, shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere. [40 CFR 60.12]	None.	None.	None.
33	Flares shall be designed for, and operated with, no visible emissions, except for periods not to exceed a total of 5 minutes during any 2 consecutive hours. [40 CFR 60.18(c)(1)]	Monitored by visual determination once initially, based on a 2 hour period. Compliance shall be determined using Method 22 [40 CFR 60.18(f)(1)]	None.	None.
34	Flares shall be operated with a flame present at all times. [40 CFR 60.18(c)(2)]	Monitored by temperature instrument continuously, based on an instantaneous determination. The owner or operator may also use any other equivalent device to detect the presence of a flare pilot flame. [40 CFR 60.18(f)(2)]	None.	None.

BOP180001

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
35	The net heating value, Ht, [as calculated using the equation in 40 CFR Part 60.18(f)(3)] of the gas being combusted in a non-assisted flare shall be 200 Btu/SCF or greater. [40 CFR 60.18(c)(3)]	Monitored by calculations once initially. The net heating value of the gas being combusted in a flare shall be calculated using the equation in 40 CFR Part 60.18(f)(3). [40 CFR 60.18(f)(3)]	None.	None.
36	Steam assisted or non-assisted flare shall be designated and operated with an exit velocity, V actual, being less than 60 ft/sec. [40 CFR 60.18(c)(4)(i)]	Monitored by calculations once initially. The actual exit velocity, V actual, of the flare shall be determined by dividing volumetric flowrate (as determined by Reference Methods 2, 2A, 2C or 2D) by the unobstructed cross sectional area of the flare tip. [40 CFR 60.18(f)(4)]	None.	None.
37	Owners or operators of flares used to comply with the provisions of 40 CFR Part 60 Subpart A, shall monitor these control devices to ensure that they are operated and maintained in conformance with their designs. Applicable subparts will provide provisions stating how the owner or operator shall monitor the Flare as a control device. [40 CFR 60.18(d)]	Other: The owner or operator shall monitor the flare as specified in the applicable subpart(s) of 40 CFR Part 60. [40 CFR 60.18(d)].	None.	None.
38	Flares used to comply with the provisions of 40 CFR Part 60 Subpart A, shall be operated at all times when emissions may be vented to them. [40 CFR 60.18(e)]	None.	None.	None.
39	Changes in time periods for submittal of information and postmark deadlines set forth in this subpart, may be made only upon approval by the Administrator and shall follow procedures outlined in 40 CFR Part 60.19. [40 CFR 60.19]	None.	None.	None.
40	This facility is subject to NSPS 40 CFR 60 Subpart WWW since the provisions of this subpart apply to each municipal solid waste landfill that commenced construction, reconstruction, or modification on or after May 30, 1991, but before July 18, 2014. [40 CFR 60.750(a)]			

BOP180001

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
41	The owner or operator shall route all the collected gas to either: (1) an open flare designed and operated in accordance with the parameters established in 40 CFR 60.18 except as noted in 40 CFR 60.754(e); or (2) a control system designed and operated to reduce NMOC by 98 weight percent; or (3) an enclosed combustor designed and operated to reduce NMOC by 98% or to 20 ppmvd or less at 3% oxygen (as hexane); or (4) a treatment system that processes the collected gas for subsequent sale or use. [All emissions from any atmospheric vent from the gas treatment system shall be subject to the requirements of 1, 2, or 3 above.] [40 CFR 60.752(b)(2)(iii)]	None.	Other: Each owner or operator shall keep up-to-date, readily accessible records for the life of the control equipment the percent reduction of NMOC determined as specified in 40 CFR 60.752(b)(2)(iii)(B) achieved by the control device as measured during the initial performance test or compliance determination using the test methods specified in 40 CFR 60.754(d) and the average combustion temperature measured at least every 15 minutes and averaged over the same time period of the performance test. Records of the control device vendor specifications shall be maintained until removal.[40 CFR 60.758(b)].	None.
42	The control device shall be operated within the parameter ranges established during the initial or most recent performance test. The operating parameters to be monitored are specified in 40 CFR 60.756. [40 CFR 60.752(b)(2)(iii)]	None.	None.	None.

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
43	<p>The collection and control system may be capped or removed provided that all the conditions of 40 CFR 60.752 paragraphs (b)(2)(v) (A), (B), and (C) of this section are met:</p> <p>(A) The landfill shall be a closed landfill as defined in 40 CFR 60.751 of this subpart. A closure report shall be submitted to the Administrator as provided in 40 CFR 60.757(d);</p> <p>(B) The collection and control system shall have been in operation a minimum of 15 years; and</p> <p>(C) Following the procedures specified in 40 CFR 60.754(b), the calculated NMOC gas produced by the landfill shall be less than 50 megagrams per year on three successive test dates. The test dates shall be no less than 90 days apart, and no more than 180 days apart. [40 CFR 60.752(b)(2)(v)]</p>	None.	None.	None.
44	<p>The owner or operator shall operate the collection system with negative pressure at each wellhead except under the following conditions: (1) A fire or increased well temperature. The owner or operator shall record instances when positive pressure occurs in efforts to avoid a fire.; (2) A decommissioned well. A well may experience a static positive pressure after shut down to accommodate for declining flows. All design changes shall be approved by the Administrator. [40 CFR 60.753(b)]</p>	<p>Other: The owner or operator shall measure gauge pressure in the gas collection header at each individual well, monthly after the initial start-up of the enclosed flare.[40 CFR 60.756(a)(1)].</p>	<p>Recordkeeping by manual logging of parameter or storing data in a computer data system each month during operation. Record gauge pressure in the gas collection header at each individual well. Also, the owner or operator shall record instances when positive pressure occurs in efforts to avoid a fire. These records shall be submitted with the annual reports as provided in 40 CFR 60.757(f)(1). [40 CFR 60.753(b)] &. [40 CFR 60.758(c)]</p>	<p>Comply with the requirement: As per the approved schedule. If a positive pressure exists, action shall be initiated to correct the exceedance within 5 calendar days, except for the two conditions allowed under 40 CFR 60.753(b). If negative pressure cannot be achieved without excess air infiltration within 15 calendar days of the first measurement, the gas collection system shall be expanded to correct the exceedance within 120 days of the initial measurement of positive pressure. Any attempted corrective measure shall not cause exceedances of other operational or performance standards. Instances of positive pressure in efforts to avoid a fire shall be submitted with the annual reports as provided in 40 CFR 60.757(f)(1). [40 CFR 60.753(b)] &. [40 CFR 60.755(a)(3)]</p>

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
45	The owner or operator shall operate each interior wellhead in the collection system with a landfill gas temperature less than 55 deg C (131 deg F) and with either a nitrogen level less than 20 percent or an oxygen level less than 5 percent. [40 CFR 60.753(c)]	Other: Monitoring shall occur monthly after the initial start-up of the enclosed flare. The temperature shall be determined by a temperature instrument. The nitrogen level shall be determined using Method 3C. The oxygen shall be determined by an oxygen meter using Method 3A or 3C except that: (i) The span shall be set so that the regulatory limit is between 20 and 50 percent of the span; (ii) A data recorder is not required; (iii) Only two calibration gases are required, a zero and span, and ambient air may be used as the span; (iv) A calibration error check is not required; and (v) The allowable sample bias, zero drift, and calibration drift are +/- 10 percent. [40 CFR 60.753(c)] & [40 CFR 60.755(a)(5)] & [40 CFR 60.756(a)].	Recordkeeping by manual logging of parameter or storing data in a computer data system upon occurrence of event. Record nitrogen concentration or oxygen concentration, and temperature at each interior wellhead in the collection system monthly. [40 CFR 60.758(c)]	Comply with the requirement: As per the approved schedule If a well exceeds one of these operating parameters, action shall be initiated to correct the exceedance within 5 calendar days. If correction of the exceedance cannot be achieved within 15 calendar days of the first measurement, the gas collection system shall be expanded to correct the exceedance within 120 days of the initial exceedance. Any attempted corrective measure shall not cause exceedances of other operational or performance standards. [40 CFR 60.755(a)(5)]
46	Operate the collection system so that the methane concentration is less than 500 parts per million above background at the surface of the landfill. To determine if this level is exceeded, the owner or operator shall conduct surface testing around the perimeter of the collection area and along a pattern that traverses the landfill at 30 meter intervals and where visual observations indicate elevated concentrations of landfill gas, such as distressed vegetation and cracks or seeps in the cover. The owner or operator may establish an alternative traversing pattern that ensures equivalent coverage. A surface monitoring design plan shall be developed that includes a topographical map with the monitoring route and the rationale for any site-specific deviations from the 30 meter intervals. Areas with steep slopes or other dangerous areas may be excluded from the surface testing. [40 CFR 60.753(d)]	None.	None.	Comply with the requirement: Upon occurrence of event. If monitoring demonstrates that the operational requirements in paragraphs (b), (c), or (d) of this section 753 are not met, corrective action shall be taken as specified in 40 CFR 60.755(a)(3) through (5) or 40 CFR 60.755(c) below. If corrective actions are taken as specified in 40 CFR 60.755, the monitored exceedance is not a violation of the operational requirements in this section. [40 CFR 60.753(g)]

BOP180001

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
47	The owner or operator shall operate the collection system such that all collected gases are vented to a control system designed and operated in compliance with 40 CFR 60.752(b)(2)(iii). In the event the collection or control system is inoperable, the gas mover system shall be shut down and all valves in the collection and control system contributing to venting of the gas to the atmosphere shall be closed within 1 hour. [40 CFR 60.753(e)]	None.	None.	Comply with the requirement: As per the approved schedule. In the event the collection or control system is inoperable, the gas mover system shall be shut down and all valves in the collection and control system contributing to venting of the gas to the atmosphere shall be closed within 1 hour. [40 CFR 60.753(e)]
48	For the performance test required in 40 CFR 60.752(b)(2)(iii)(B), Method 25, 25C, or Method 18 of appendix A of this part as approved by NJDEP Bureau of Technical Services must be used to determine compliance with the 98 weight-percent efficiency or the 20 ppmv outlet concentration level, unless another method to demonstrate compliance has been approved by the Administrator as provided by 40 CFR 60.752(b)(2)(i)(B). Method 3 or 3A shall be used to determine oxygen for correcting the NMOC concentration as hexane to 3 percent. In cases where the outlet concentration is less than 50 ppm NMOC as carbon (8 ppm NMOC as hexane), Method 25A should be used in place of Method 25. If using Method 18 of appendix A of this part, the minimum list of compounds to be tested shall be those published in the most recent Compilation of Air Pollutant Emission Factors (AP-42). [40 CFR 60.754(d)]	None.	None.	None.

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
49	<p>The owner or operator shall operate the collection system so that the methane concentration is < 500 ppm above background at the surface of the landfill. To determine if this level is exceeded, the owner or operator shall monitor surface concentrations of methane along the entire perimeter of the collection area & along a pattern that traverses the landfill at 30 meter intervals & where visual observations indicate elevated concentrations of landfill gas, such as distressed vegetation & cracks or seeps in the cover. A surface monitoring design plan shall be developed that includes a topographical map with the monitoring route & the rationale for any site-specific deviations from the 30 meter intervals. Areas with steep slopes or other dangerous areas may be excluded from the surface testing. Any reading of 500 ppm or more above background at any location shall be recorded as a monitored exceedance & the actions specified in (i) through (v) in the Submittal/Action Requirement shall be taken. As long as the specified actions are taken, the exceedance is not a violation of the operational requirements of 40 CFR 60.753(d). Any closed landfill that has no monitored exceedances of the operational standard in three consecutive quarterly monitoring periods may skip to annual monitoring. [40 CFR 60.755(c)]</p>	<p>Monitored by periodic emission monitoring quarterly: once per quarter; quarters shall begin on January 1, April 1, July 1, and October 1 of each year, based on an instantaneous determination. The owner or operator shall monitor surface concentrations of methane using an organic vapor analyzer, flame ionization detector, or other portable monitor meeting the specifications provided in 40 CFR 60.755(d). The background concentration shall be determined by moving the probe inlet upwind and downwind outside the boundary of the landfill at a distance of at least 30 meters from the perimeter wells. Surface emission monitoring shall be performed in accordance with section 4.3.1 of Method 21 of appendix A of 40 CFR 60, except that the probe inlet shall be placed within 5 to 10 centimeters of the ground. Monitoring shall be performed during typical meteorological conditions. The owner or operator shall implement a program to monitor for cover integrity and implement cover repairs as necessary on a monthly basis. [40 CFR 60.755(c)]</p>	<p>Methane concentration at the surface of the landfill. Recordkeeping by manual logging of parameter or storing data in a computer data system upon occurrence of event. [40 CFR 60.755(c)]</p>	<p>Comply with the requirement: As per the approved schedule (i) The location of each monitored exceedance shall be marked & recorded; (ii) Cover maintenance or adjustments to the vacuum of the adjacent wells to increase the gas collection in the vicinity of each exceedance shall be made & the location shall be remonitored within 10 calendar days of detecting the exceedance; (iii) If the remonitoring of the location shows a second exceedance, additional corrective action shall be taken & the location shall be monitored again within 10 days of the second exceedance. If the remonitoring shows a third exceedance for the same location, the action in (v) shall be taken, & no further monitoring of that location is required until the action in (v) has been taken; (iv) Any location that initially showed an exceedance but has a methane concentration less than 500 ppm methane above background at the 10-day remonitoring specified in (ii) or (iii) shall be remonitored 1 month from the initial exceedance. If the 1-month remonitoring shows a concentration less than 500 ppm above background, no further monitoring of that location is required until the next quarterly monitoring period. If the 1-month remonitoring shows an exceedance, the actions in (iii) or (v) shall be taken; (v) For any location where monitored methane concentration equals or exceeds 500 ppm above background three times within a quarterly period, a new well or other collection device shall be installed within 120 calendar days of the initial exceedance. [40 CFR 60.755(c)(4)]</p>

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
50	Each owner or operator shall calibrate, maintain, and operate according to the manufacturer's specifications, a temperature monitoring device equipped with a continuous recorder and having a minimum accuracy of +/- 1 percent of the temperature being measured expressed in degrees Celsius or +/- 0.5 degrees Celsius, whichever is greater. [40 CFR 60.756(b)(1)]	None.	None.	None.
51	Each owner or operator shall calibrate, maintain, and operate according to the manufacturer's specifications, a device that records flow to or bypass of the control device. The owner or operator shall install, calibrate, and maintain a gas flow rate measuring device that shall record the flow to the control device at least every 15 minutes. [40 CFR 60.756(b)(2)]	Monitored by gas flow rate instrument each quarter hour during operation. [40 CFR 60.756(b)(2)(i)]	Recordkeeping by data acquisition system (DAS) / electronic data storage each quarter hour during operation. [40 CFR 60.756(b)(2)(i)]	None.

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
52	Each owner or operator of a landfill seeking to comply with 40 cfr 60.752(b)(2) using an active collection system designed in accordance with 40 cfr 60.752(b)(2)(ii) shall submit to the Administrator annual reports of the recorded information in (1) through (6) under Submittal/Action Requirement. For enclosed combustion devices and flares, reportable exceedances are defined under §60.758(c). [40 CFR 60.757(f)]	None.	None.	<p>Submit a report: Semi-annually on January 31 and July 31 of each year , in accordance with 40 CFR 63.1980.</p> <p>Submit to the Administrator reports of the recorded information in (1) through (6) below.</p> <p>(1) Value and length of time for exceedance of applicable parameters monitored under 40 CFR 60.756(a), (b), (c), and (d).</p> <p>(2) Description and duration of all periods when the gas stream is diverted from the control device through a bypass line or the indication of bypass flow as specified under 40 CFR 60.756.</p> <p>(3) Description and duration of all periods when the control device was not operating for a period exceeding 1 hour and length of time the control device was not operating.</p> <p>(4) All periods when the collection system was not operating in excess of 5 days.</p> <p>(5) The location of each exceedance of the 500 parts per million methane concentration as provided in 40 CFR 60.753(d) and the concentration recorded at each location for which an exceedance was recorded in the previous month.</p> <p>(6) The date of installation and the location of each well or collection system expansion added pursuant to paragraphs (a)(3), (b), and (c)(4) of 40 CFR 60.755. [40 CFR 60.757(f)]</p>

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
53	<p>Minimum Operating Temperature at the Exit of the Combustion Section: may be no lower than 50 degrees F less than temperature during last stack test, or NLT 1500 F per U1, OS1, Ref #10 whichever is higher.</p> <p>Each owner or operator shall keep for 5 years up-to-date, readily accessible continuous records of the equipment operating parameters specified to be monitored in 40 CFR 60.756 as well as up-to-date, readily accessible records for periods of operation during which the parameter boundaries established during the most recent performance test are exceeded. The following constitute exceedances that shall be recorded and reported under 40 CFR 60.757(f): (i) For enclosed combustors except for boilers and process heaters with design heat input capacity of 44 megawatts (150 million British thermal unit per hour) or greater, all 3-hour periods of operation during which the average combustion temperature was more than 28 deg C (50 deg F) below the average combustion temperature during the most recent performance test at which compliance with 40 CFR 60.752(b)(2)(iii) was determined; and (ii) For boilers or process heaters, whenever there is a change in the location at which the vent stream is introduced into the flame zone as required under 40 CFR 60.758(b)(3). [40 CFR 60.758(c)]</p>	<p>Minimum Operating Temperature at the Exit of the Combustion Section: Monitored by temperature instrument every 15 minutes, based on a 3 hour block average , i.e., the average combustion temperature measured at least every 15 minutes and averaged over the same time period of the performance test. [40 CFR 60.758(b)(2)]</p>	<p>Minimum Operating Temperature at the Exit of the Combustion Section: Recordkeeping by manual logging of parameter or storing data in a computer data system each quarter hour during operation. See Applicable Requirement. [40 CFR 60.758(c)]</p>	<p>Submit a report: Semi-annually on January 31 and July 31 of each year. See reporting details above. [40 CFR 60.757(f)]</p>
54	<p>Each owner or operator shall keep up-to-date, readily accessible continuous records of the indication of flow to the control device or the indication of bypass flow or records of monthly inspections of car-seals or lock-and-key configurations used to seal bypass lines, specified under 40 CFR 60.756. [40 CFR 60.758(c)(2)]</p>	<p>None.</p>	<p>Other: See Applicable Requirement.[40 CFR 60.758(c)(2)].</p>	<p>None.</p>

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
55	Each owner or operator shall keep for at least 5 years up-to-date, readily accessible records of all collection and control system exceedances of the operational standards in 40 CFR 60.753, the reading in the subsequent month whether or not the second reading is an exceedance, and the location of each exceedance. [40 CFR 60.758(e)]	None.	Other: See Applicable Requirement.[40 CFR 60.758(e)].	None.
56	No owner or operator subject to the provisions of 40 CFR 63 may operate any affected source in violation of the requirements of 40 CFR 63. No owner or operator subject to the provisions of 40 CFR 63 shall fail to keep records, notify, report, or revise reports as required under 40 CFR 63. [40 CFR 63.4(a)]	None.	None.	None.
57	For equipment subject to MACT, no owner or operator subject to the provisions of MACT Subpart A in 40 CFR 63 shall build, erect, install, or use any article, machine, equipment, or process to conceal an emission that would otherwise constitute noncompliance with a relevant standard. Such concealment includes, but is not limited to: (1) The use of diluents to achieve compliance with a relevant standard based on the concentration of a pollutant in the effluent discharged to the atmosphere; and (2) The use of gaseous diluents to achieve compliance with a relevant standard for visible emissions. [40 CFR 63.4(b)]	None.	None.	None.
58	The owner and operator must not use fragmentation or phasing of reconstruction activities (i.e., intentionally dividing reconstruction into multiple parts for purposes of avoiding new source requirements) to avoid becoming subject to new source requirements. [40 CFR 63.4(c)]	None.	None.	None.

BOP180001

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
59	The owner or operator must operate and maintain any affected source at all times, including periods of startup, shutdown, and malfunction, including associated APC equipment and monitoring equipment for minimizing emissions to the levels required by the relevant standards, i.e., meet the emission standard or comply with the startup, shutdown, and malfunction plan. [40 CFR 63.6(e)(1)(i)]	None.	None.	None.
60	Malfunctions must be corrected as soon as practicable after their occurrence. To the extent that an unexpected event arises during a startup, shutdown, or malfunction, an owner or operator must comply by minimizing emissions during such a startup, shutdown, and malfunction event consistent with safety and good air pollution control practices. [40 CFR 63.6(e)(1)(ii)]	None.	None.	None.
61	The owner or operator of an affected source must develop a written startup, shutdown, and malfunction plan that describes, in detail, procedures for operating and maintaining the source during periods of startup, shutdown, and malfunction; and a program of corrective action for malfunctioning process, air pollution control, and monitoring equipment used to comply with the relevant standard. The startup, shutdown, and malfunction plan does not need to address any scenario that would not cause the source to exceed an applicable emission limitation in the relevant standard. This plan must be developed by the owner or operator by the source's compliance date for that relevant standard. [40 CFR 63.6(e)(3)(i)]	None.	Other: The owner or operator must maintain at the affected source a current startup, shutdown, and malfunction plan and make the plan available upon request for inspection after the initial start-up of the enclosed flare. In addition, the owner or operator must maintain each previous version of the plan for a period of 5 years after the revision of the plan.[40 CFR 63.6(e)(3)(v)].	None.

BOP180001

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
62	During periods of startup, shutdown, and malfunction, the owner or operator of an affected source must operate and maintain such source, including APC and monitoring equipment, in accordance with the procedures specified in the startup, shutdown and malfunction plan developed under paragraph 40 CFR 63.6(e)(3)(i). [40 CFR 63.6(e)(3)(ii)]	None.	None.	None.

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
63	When actions taken by the owner or operator during a startup or shutdown (and the startup or shutdown causes the source to exceed any applicable emission limitation in the relevant emission standards), or malfunction (including actions taken to correct a malfunction) are consistent with the procedures specified in the affected source's startup, shutdown, and malfunction plan, the owner or operator must keep records for that event which demonstrate that the procedures specified in the plan were followed. These records may take the form of a "checklist," or other effective form of recordkeeping that confirms conformance with the startup, shutdown, and malfunction plan and describes the actions taken for that event. In addition, the owner or operator must keep records of these events as specified in 40 CFR 63.10(b), including records of the occurrence and duration of each startup or shutdown (if the startup or shutdown causes the source to exceed any applicable emission limitation in the relevant emission standards), or malfunction of operation and each malfunction of the air pollution control and monitoring equipment. Furthermore, the owner or operator shall confirm that actions taken during the relevant reporting period during periods of startup, shutdown, and malfunction were consistent with the affected source's startup, shutdown and malfunction plan in the semiannual (or more frequent) startup, shutdown, and malfunction report required in 40 CFR 63.10(d)(5). [40 CFR 63.6(e)(3)(iii)]	None.	Other: Maintain readily accessible records, pursuant to 40 CFR 63.10(b) after the initial start-up of the enclosed flare.[40 CFR 63.10(b)].	Submit a report: As per the approved schedule , pursuant to 40 CFR 63.10(d)(5). [40 CFR 63.10(d)(5)]

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
64	If an action taken by the owner or operator during a startup, shutdown, or malfunction (including an action taken to correct a malfunction) is not consistent with the procedures specified in the affected source's startup, shutdown, and malfunction plan, and the source exceeds any applicable emission limitation in the relevant emission standard, then the owner or operator must record the actions taken for that event and must report such actions within 2 working days after commencing actions inconsistent with the plan, followed by a letter within 7 working days after the end of the event, in accordance with 40 CFR 63.10(d)(5) (unless the owner or operator makes alternative reporting arrangements, in advance, with the Administrator). [40 CFR 63.6(e)(3)(iv)]	None.	Recordkeeping by other recordkeeping method (provide description) annually Maintain readily accessible records, pursuant to 40 CFR 63.10(b).. [40 CFR 63.6(e)(3)(iv)]	Submit a report: As per the approved schedule , pursuant to 40 CFR 63.10(d)(5). [40 CFR 63.10(d)(5)]
65	The owner or operator must maintain at the affected source a current startup, shutdown, and malfunction plan and must make the plan available upon request for inspection and copying by the Administrator, pursuant to 40 CFR 63.6(e)(3)(v). [40 CFR 63.6(e)(3)(v)]	None.	Other: Maintain readily accessible records, pursuant to 40 CFR 63.6(e)(3)(v) after the initial start-up of the enclosed flare.[40 CFR 63.6(e)(3)(v)].	None.
66	The owner or operator may periodically revise the startup, shutdown, and malfunction plan for the affected source as necessary to satisfy the requirements of this part or to reflect changes in equipment or procedures at the affected source, pursuant to 40 CFR 63.6(e)(3)(viii). [40 CFR 63.6(e)(3)(viii)]	None.	None.	Submit a report: Upon occurrence of event. Each startup, shutdown, and malfunction plan revision must be reported,pursuant to 40 CFR 63.10(d)(5). [40 CFR 63.6(e)(3)(viii)]

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
67	The non-opacity emission standards set forth in this part shall apply at all times except during periods of startup, shutdown, and malfunction, and as otherwise specified in an applicable subpart. If a startup, shutdown, or malfunction of one portion of an affected source does not affect the ability of particular emission points within other portions of the affected source to comply with the non-opacity emission standards set forth in this part, then that emission point must still be required to comply with the non-opacity emission standards and other applicable requirements. [40 CFR 63.6(f)(1)]	None.	None.	None.
68	This landfill is an area source in accordance with MACT Subpart AAAA since it is a landfill that accepted waste since November 8, 1987. [40 CFR 63.1935(a)]			
69	The owner or operator shall demonstrate compliance in the same way it is determined for 40 CFR Part 60, Subpart WWW, including performance testing, monitoring of the collection system, continuous parameter monitoring, and other credible evidence. In addition, continuous parameter monitoring data, collected under 40 CFR 60.756(b)(1) [closed flare] and (c)(1) [open flare] of Subpart WWW, are used to demonstrate compliance with the operating conditions for control systems. If a deviation occurs, you have failed to meet the control device operating conditions described in this subpart and have deviated from the requirements of this subpart. Finally, you must develop a written SSM plan according to the provisions in 40 CFR 63.6(e)(3). A copy of the SSM plan must be maintained on site. Failure to write or maintain a copy of the SSM plan is a deviation from the requirements of this subpart. [40 CFR 63.1960]	Other: Monitored by continuous parameter monitoring, pursuant to 40 CFR 60.756[40 CFR 63.1960].	Other: Maintain a current copy of the SSM plan on site and other records after the initial start-up of the enclosed flare as required by 40 CFR 63.1980. [40 CFR 63.1960] and.[40 CFR 63.1980].	Comply with the requirement: As per the approved schedule. [40 CFR 63.1980]

**New Jersey Department of Environmental Protection
Facility Specific Requirements**

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
70	<p>For the purposes of the landfill monitoring and SSM plan requirements, deviations (as defined in 40 CFR 63.1990) include the items in paragraphs (a) through (c) of this section.</p> <p>(a) A deviation occurs when the control device operating parameter boundaries described in 40 CFR 60.758(c)(1) of subpart WWW are exceeded.</p> <p>(b) A deviation occurs when 1 hour or more of the hours during the 3-hour block averaging period (refer to 40 CFR 63.1975) does not constitute a valid hour of data. A valid hour of data must have measured values for at least three 15-minute monitoring periods within the hour.</p> <p>(c) A deviation occurs when a SSM plan is not developed, implemented, or maintained on site. [40 CFR 63.1965]</p>	<p>Other: Averages are calculated in the same way as they are calculated in 40 CFR part 60, subpart WWW, except that the data collected during the following events are not to be included in any average computed under this subpart:</p> <p>(a) Monitoring system breakdowns, repairs, calibration checks, and zero (low-level) and high-level adjustments.</p> <p>(b) Startups.</p> <p>(c) Shutdowns.</p> <p>(d) Malfunctions.[40 CFR 63.1975].</p>	None.	<p>Submit a report: Upon occurrence of event. The report shall consist of a telephone call or facsimile and shall be submitted within 2 working days after commencing action, followed by a letter delivered or postmarked within 7 working days after the end of the event. [40 CFR 63.10(d)(5)(ii)]</p>
71	<p>The owner or operator shall submit the annual report described in 40 CFR 60.757(f) every 6 months to the Administrator. For enclosed combustion devices and flares, reportable exceedances are defined under 40 CFR 60.758(c). [40 CFR 63.1980(a)]</p>	None.	None.	<p>Submit a report: As per the approved schedule. The biannual reports shall include the recorded information delineated above at 40 CFR 60.757(f). [40 CFR 63.1980(a)]</p>

BOP180001

New Jersey Department of Environmental Protection
Facility Specific Requirements

Emission Unit: U1 Landfill Gas collected by 54 Active Vents controlled by Enclosed Flare (CD1) subject to NSPS subpart WWW and MACT AAAA - Closed Landfill in 2003

Operating Scenario: OS1 1 through 54 Active Vents emissions controlled by flare

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
1	NOx (Total) <= 0.27 lb/hr . [N.J.A.C. 7:27-22.16(e)]	NOx (Total): Monitored by stack emission testing every 5 years (based on completion date of the last stack test), based on each of three Department validated stack test runs. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]	NOx (Total): Recordkeeping by stack test results upon occurrence of event. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]
2	CO <= 0.91 lb/hr . [N.J.A.C. 7:27-22.16(e)]	CO: Monitored by stack emission testing every 5 years (based on completion date of the last stack test), based on each of three Department validated stack test runs. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]	CO: Recordkeeping by stack test results upon occurrence of event. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]
3	The maximum concentration limit for CO <= 100 ppmvd @ 7% O ₂ . [N.J.A.C. 7:27-22.16(e)]	CO: Monitored by calculations initial calculations only. [N.J.A.C. 7:27-22.16(o)]	CO: Recordkeeping by manual logging of parameter or storing data in a computer data system initial calculations only. Maintain records of initial calculations for CO<= 100 ppmvd@ 7% O ₂ , to be made available to the Department on request. [N.J.A.C. 7:27-22.16(o)]	None.
4	SO ₂ <= 0.24 lb/hr . [N.J.A.C. 7:27-22.16(a)]	SO ₂ : Monitored by stack emission testing every 5 years (based on completion date of the last stack test), based on each of three Department validated stack test runs. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]	SO ₂ : Recordkeeping by stack test results upon occurrence of event. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]
5	TSP <= 0.08 lb/hr . [N.J.A.C. 7:27-22.16(e)]	TSP: Monitored by stack emission testing every 5 years (based on completion date of the last stack test), based on each of three Department validated stack test runs. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]	TSP: Recordkeeping by stack test results upon occurrence of event. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]

New Jersey Department of Environmental Protection
Facility Specific Requirements

Ref.#	Applicable Requirement	Monitoring Requirement	Recordkeeping Requirement	Submittal/Action Requirement
6	PM-10 (Total) \leq 0.08 lb/hr . [N.J.A.C. 7:27-22.16(e)]	PM-10 (Total): Monitored by stack emission testing every 5 years (based on completion date of the last stack test), based on each of three Department validated stack test runs. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]	PM-10 (Total): Recordkeeping by stack test results upon occurrence of event. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]
7	PM-2.5 (Total) \leq 0.08 lb/hr . [N.J.A.C. 7:27-22.16(a)]	PM-2.5 (Total): Monitored by stack emission testing every 5 years (based on completion date of the last stack test), based on each of three Department validated stack test runs. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]	PM-2.5 (Total): Recordkeeping by stack test results upon occurrence of event. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]
8	Methane \leq 1.89 lb/hr. [N.J.A.C. 7:27-22.16(a)]	Methane: Monitored by stack emission testing every 5 years (based on completion date of the last stack test), based on each of three Department validated stack test runs. See the stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Methane: Recordkeeping by stack test results upon occurrence of event. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule. See the stack testing requirements in OS Summary. [N.J.A.C. 7:27-22.16(o)]
9	Minimum Operating Temperature at the Exit of the Combustion Section \geq 1,500 degrees F. The flare shall be designed to operate at no less than the minimum operating temperature except during periods of start-up and shut-down. [N.J.A.C. 7:27-22.16(e)]	Minimum Operating Temperature at the Exit of the Combustion Section: Monitored by temperature instrument continuously. The permittee shall install, operate and maintain an alarm or other operational warning system, properly shielded from direct contact with the flame. The alarm shall be designed to sound at any time flare temperature is detected to be less than the permitted operating temperature. [N.J.A.C. 7:27-22.16(o)]	Minimum Operating Temperature at the Exit of the Combustion Section: Recordkeeping by strip chart or data acquisition (DAS) system continuously. [N.J.A.C. 7:27-22.16(o)]	None.

LINDEN CITY SLF (42247)
BOP180001

Date: 8/30/2023

New Jersey Department of Environmental Protection
Facility Profile (General)

Facility Name (AIMS): Linden City Sanitary Landfill

Facility ID (AIMS): 42247

Street 1451 LOWER RD
Address: LINDEN, NJ 07036

Mailing 700 LOWER RD
Address: LINDEN, NJ 07036

County: Union
Location Off Lower Road
Description: Block 581, Lots 11.03 & 17

State Plane Coordinates:	
X-Coordinate:	2,117,000
Y-Coordinate:	644,550
Units:	Feet
Datum:	NAD27
Source Org.:	DEP-Program
Source Type:	Digital Image

Industry:	
Primary SIC:	9511
Secondary SIC:	
NAICS:	

New Jersey Department of Environmental Protection
Facility Profile (General)

Contact Type: Air Permit Information Contact

Organization: CME Associates

Org. Type: Other

Name: Behram Turan

NJ EIN:

Title: Principal

Phone: (732) 951-2101 x

Mailing Address: 3759 U. S. Highway 1 South

Fax: (732) 951-2106 x

Suite 100

Other: (103) 000-0000 x

Monmouth Junction, NJ 08852

Type:

Email: bturan@cmeusa1.com

Contact Type: Consultant

Organization: CME Associates

Org. Type: Partnership

Name: Behram, Turan

NJ EIN: 22348443500

Title: Principal

Phone: (732) 951-2101 x

Mailing Address: 3759 U.S. HWY 1 S

Fax: (732) 951-2106 x

Suite 100

Other: () - x

Monmouth Junction, NJ 08852

Type:

Email: bturan@CMEUSA1.com

Contact Type: Fees/Billing Contact

Organization: Linden Engineering

Org. Type: Municipal

Name: Joseph Chrobak

NJ EIN:

Title: Senior Engineer

Phone: (908) 474-8473 x

Mailing Address: 301 North Wood Avenue

Fax: (908) 486-0725 x

Linden, NJ 07036

Other: () - x

Type:

Email: jchrobak@linden-nj.gov

**New Jersey Department of Environmental Protection
Facility Profile (General)**

Contact Type: On-Site Manager

Organization: Linden Department of Public Works

Org. Type: Municipal

Name: Dave Martinez

NJ EIN: 22600203200

Title:

Phone: (908) 474-8666 x

Mailing Address: 700 Lower Road

Fax: () - x

Linden, NJ 07036

Other: () - x

Type:

Email: dmartinez@linden-nj.org

Contact Type: Owner (Current Primary)

Organization: City of Linden

Org. Type: Municipal

Name:

NJ EIN: 22600203200

Title:

Phone: (908) 474-8473 x

Mailing Address: City Hall

Fax: () - x

301 North Wood Ave.

Other: () - x

Linden, NJ 07036

Type:

Email:

Contact Type: Responsible Official

Organization: Linden Engineering

Org. Type: Municipal

Name: Joseph Chrobak

NJ EIN:

Title: Senior Engineer

Phone: (908) 474-8473 x

Mailing Address: 301 North Wood Avenue

Fax: (908) 486-0725 x

Linden, NJ 07036

Other: () - x

Type:

Email: jchrobak@linden-nj.gov

LINDEN CITY SLF (42247)
BOP180001

Date: 8/30/2023

New Jersey Department of Environmental Protection
Insignificant Source Emissions

IS NJID	Source/Group Description	Equipment Type	Location Description	Estimate of Emissions (tpy)								
				VOC (Total)	NOx	CO	SO	TSP	PM-10	Pb	HAPS (Total)	Other (Total)
IS1	Cummins/Onan 25 KW Emergency Generator - diesel powered	Emergency Generator	Leachate Pumping Station	0.005	0.005	0.005	0.000	0.000	0.000	0.000	0.00000485	
IS2	70 gal diesel tank	Storage Vessel	Leachate Pumping Station	0.000								
Total				0.005	0.005	0.005	0.000	0.000	0.000	0.000	0.00000485	0.000

LINDEN CITY SLF (42247)

BOP180001

Date: 8/30/2023

**New Jersey Department of Environmental Protection
Equipment Inventory**

Equip. NJID	Facility's Designation	Equipment Description	Equipment Type	Certificate Number	Install Date	Grand- Fathered	Last Mod. (Since 1968)	Equip. Set ID
E1	MSW Landfill	54 Active Vents	Landfill	PCP070002	1/1/2004	No	8/25/2004	

42247 LINDEN CITY SLF BOP180001 E1 (Landfill)
Print Date: 5/2/2023

Solid Waste Facility
Permit Number: 134264

Year Opened: 1946

Solid Waste Facility Permit
Issuance Date: 7/1/93

Expected Year of Closure: 2000

Actual Year of Closure: 2000

Total Design Area (acres): 54.0

Total Design Capacity
(million megagrams): 2.5

Active Area (acres): 0.0

Capped Area (acres): 54.0

Is the Landfill Lined? ☐ Yes ☒ No

Was the site used for the
disposal of Hazardous
Waste? ☐ Yes ☒ No

Was there ever co-disposal
of Industrial Waste or
reason to believe that the
Waste Stream into the
Landfill contained large
Waste or volatile
compounds from
commercial sources?
☐ Yes ☒ No

Maximum Estimated Landfill
Gas Generation Rate during
the life of the Landfill (ft³/yr):
379279520

Model used to estimate
Landfill Gas Production: Pump Test

Is there a Landfill Gas
Pre-Treatment System? ☐ Yes ☒ No

Method of Landfill Gas
Pre-Treatment:

Design Capacity of Landfill
Gas Collection System (acfm): 523.0

Overall Collection Efficiency(%): 85.0

Landfill Gas Mover/Blower
size (hp): 7.5

Number of Extraction Wells: 54

Extraction Well Diameter (ft): 2.0

Extraction Well Depth (ft): 68.7

Extraction Well Overlap (%): 5.0

Extraction Well Operating
Vacuum (in. H₂O): 30.0

Have you attached Actual
Landfill Gas Analysis? ☐ Yes ☒ No

Have you attached a layout
(plan view) of the wells and
header piping? ☐ Yes ☒ No

Have you attached a waste

42247 LINDEN CITY SLF BOP180001 E1 (Landfill)
Print Date: 5/2/2023

deposition history (provide
tons deposited for each
operating year)?

<input type="radio"/>	Yes	<input checked="" type="radio"/>	No
-----------------------	-----	----------------------------------	----

Comments:

Pollutant	Concentration	Units
Amines		
CO2	4534.99	tons/yr
Chlorides	0	tons/yr
H2S	0.0283	tons/yr
Mercaptans	0.01277	tons/yr
Mercury	0.00002	tons/yr
Methane	8.28	tons/yr
Non-Methane Hydrocarbons	0.1	tons/yr
Greenhouse gases as CO2e	4543.25	tons/yr

LINDEN CITY SLF (42247)
BOP180001

Date: 8/30/2023

New Jersey Department of Environmental Protection
Control Device Inventory

CD NJID	Facility's Designation	Description	CD Type	Install Date	Grand- Fathered	Last Mod. (Since 1968)	CD Set ID
CD1	Encl Flare	ZTOF Enclosed Flare	Flare	3/1/2023	No		

42247 LINDEN CITY SLF BOP180001 CD1 (Flare)

Print Date: 5/2/2023

Make:	ZTOF Enlosed Flare
Manufacturer:	John Zink Hamworthy
Model:	ZTOF Enlosed Flare
Type:	Enclosed
Minimum Residence Time (sec):	0.70
Maximum Rated Gross Heat Input (MMBtu/hr):	4.10
Auxilliary Fuel:	
Description:	
Method of Pilot Flame Monitoring:	
Monitoring Location:	Remote
Automatic Gas Shutoff After Loss of Flame?	<input checked="" type="radio"/> Yes <input type="radio"/> No
Automatic Reignition After Loss of Flame?	<input checked="" type="radio"/> Yes <input type="radio"/> No
Minimum Gas Flow Rate (acfm):	178.8
Minimum Operating Temperature (°F):	1,400.0
Minimum Heat Content at Burner Tip (Btu/ft³):	275.00
Flare Operation Type:	Continuous
Does Flare have smokeless design?	<input checked="" type="radio"/> Yes <input type="radio"/> No
Is Flare equipped with flame retainer?	<input type="radio"/> Yes <input checked="" type="radio"/> No
Is Flare equipped with flame arrestor?	<input checked="" type="radio"/> Yes <input type="radio"/> No
Is Flare equipped with LEL monitor?	<input type="radio"/> Yes <input checked="" type="radio"/> No
Flare Stack Diameter (inches):	48.00
Lower Heat Content of source gas (BTU/scf):	275
Lower Heat Content of Supplemental Fuel (BTU/scf):	
Destruction and Removal Efficiency (%):	98.00
How was Efficiency determined?	Vendor specifications.
Maximum Number of Sources Using this Apparatus as a Control Device (Include Permitted and Non-Permitted Sources):	54
Alternative Method to Demonstrate Control Apparatus is Operating Properly:	Temperature Monitoring
Have you attached data from recent performance testing?	<input type="radio"/> Yes <input checked="" type="radio"/> No
Have you attached any manufacturer's data or specifications in support of the feasibility and/or effectiveness of this control apparatus?	

42247 LINDEN CITY SLF BOP180001 CD1 (Flare)

Print Date: 5/2/2023

☒ Yes ☐ No

Have you attached a diagram showing
the location and/or configuration of this
control apparatus?

☐ Yes ☒ No

Comments:

LINDEN CITY SLF (42247)
BOP180001

Date: 8/30/2023

New Jersey Department of Environmental Protection
Emission Points Inventory

PT NJID	Facility's Designation	Description	Config.	Equiv. Diam. (in.)	Height (ft.)	Dist. to Prop. Line (ft)	Exhaust Temp. (deg. F)			Exhaust Vol. (acfm)			Discharge Direction	PT Set ID
							Avg.	Min.	Max.	Avg.	Min.	Max.		
PT1	Encl FLare	ZTOF Enclosed FLare	Round	48	20	1,470	1,600.0	1,400.0	1,800.0	536.4	178.8	536.4	Up	

LINDEN CITY SLF (42247)
BOP180001

Date: 8/30/2023

New Jersey Department of Environmental Protection
Emission Unit/Batch Process Inventory

U 1 MSW Landfill Landfill Gas collected by 54 Active Vents controlled by Enclosed Flare (CD1) subject to NSPS subpart WWW and MACT AAAA - Closed
Landfill in 2003

UOS NJID	Facility's Designation	UOS Description	Operation Type	Signif. Equip.	Control Device(s)	Emission Point(s)	SCC(s)	Annual Oper. Hours		VOC Range	Flow (acfm)		Temp. (deg F)	
								Min.	Max.		Min.	Max.	Min.	Max.
OS1	MSW Landfill	1 through 54 Active Vents emissions controlled by flare	Normal - Steady State	E1	CD1 (P)	PT1	5-01-004-10	0.0	8,760.0	B	178.8	536.4	1,400.0	1,800.0