


Electric Transmission & Distribution SF₆ Coalition




New Jersey Clean Air Council Annual Public Hearing
April 10, 2019

Billy J Lao

General Manager – DILO Company Inc. & DILO Direct
Coalition Member

IEEE Chair for SF₆ Gas handling group & Member of K group (regarding SF₆)



Presentation Topics


1. SF₆ Gas
2. History (GIE)
3. Safety
4. Why SF₆ gas is an excellent solution for GIE
5. Overview of SF₆ reporting regulations
 - a. EPA
 - b. CARB
 - c. MASS DEP
 - d. Others
6. What's being done to reduce emissions
 - a. SF₆ handling practices
 - b. Alternative Solutions




NEMA SF₆ Gas Coalition

SF₆ Gas

History




- Discovered in 1901 by Henri Moissan and Paul LaBeau
- Characteristics:
 - **Manmade** – not naturally occurring
 - **Undetectable** – colorless, odorless, tasteless
 - **Stable** – Chemically inert
 - **Dielectric** – excellent arc quenching capabilities
 - Thermally Stable / heat trapping
 - Excellent re-association / self-healing after arcing event



Properties

- **Heavy** – 5 times heavier than air
- **Compressible** – liquifies at approx. 250psi at 68°F
- **Asphyxiant** – displaces atmospheric oxygen
 - OSHA maximum exposure limit 1,000 PPM
- **Unmatched dielectric strength** – 2.5x better than air
- **Arc quenching capabilities** – 100x better than air
- **Thermally stable** – high breakdown temperature
- **Self-healing** – molecules will recombine after heat source is removed




NEMA SF₆ Gas Coalition

GIE History



GIE History


- The time line as described by me!



Fluorinated nitrile
(Novec 4710 fluid) + CO2




GIE History



I have heard it called a pickle barrel breaker!

GIE History




- The first patents on the use of SF₆ as an interrupting medium were filed in Germany in 1938 by Vitaly Grosse ([AEG](#)) and independently later in the United States in July 1951 by H. J. Lingal, T. E. Browne and A. P. Storm ([Westinghouse](#)).
- The first industrial application of SF₆ for current interruption dates to 1953. High-voltage 15 kV to 161 kV load switches were developed with a breaking capacity of 600 A. The first high-voltage SF₆ circuit breaker built in 1956 by Westinghouse, could interrupt 5 kA under 115 kV, but it had six interrupting chambers in series per pole.

SF₆ Gas in GIE – How it works



The world's first 800 kV GIS - Joshua Falls, VA – 1980 - DELL ALSTHOM

Safety




Safety


- Harmless in the presence of air (5x heavier than air)
 - Will displace air / asphyxiation
- Will decompose at temperatures > 350 F
 - Breaker operations
 - Welding
 - Running engines / heaters / open flames
 - Smoking
 - Temperature during drawing up to 700 C (1292 F)
 - Source: <http://www.physlink.com/education/askexperts/ae1.cfm>




At very high temperatures, or in the presence of an electric arc which can reach 15,000°C (27000°F), SF₆ can be slowly decomposed. Decomposition by-products include lower fluorides of sulfur, which are hydrolysable (change), yielding SO₂ and HF.




Electric Transmission & Distribution SF₆ Coalition





Why SF₆ gas is an excellent solution for GIE





SF₆ Gas in GIE – How it works





1 – Breaker Open





4 – Breaker Opening / Commutation





2 – Breaker closing





5 – Breaker Opening / Arc Quenching




3 – Breaker closed



6 – Breaker Open



Electric Transmission & Distribution SF₆ Coalition




Overview of SF₆ reporting regulations



Overview of SF₆ reporting regulations

SF₆ = Global Warming gas

- Not an ozone-depleting gas
- SF₆ – Global warming potential (GWP) = 24,000
- CO₂ – Global warming potential (GWP) = 1
- SF₆ - estimated lifespan = 3,200 years
- CO₂ - estimated lifespan = 90 years
- 1 Pound SF₆ = 11 Tons CO₂



Overview of SF₆ reporting regulations




EPA considerations

- Began investigating SF₆ - 1997
- 2012 - Mandatory reporting
 - for name plate capacity of 17,820 lbs
- EPA's online reporting tool
 - <https://ghgreporting.epa.gov>
- Additional information
 - www.epa.gov/electricpower-SF6



Overview of SF₆ reporting regulations




SF ₆ Emissions Reduction Partnership for Electric Power Systems		
Annual Reporting Form		
Name: EH&S Manager Name	Company Name:	Customer Name
Title: EH&S Manager	Report Year: 2015	
Phone: (555)555-5555	Date Completed: Mar-16	
Change in Inventory (SF₆ contained in cylinders, <u>not</u> electrical equipment)		
Inventory (in cylinders, <u>not</u> equipment)	AMOUNT (lbs.)	Comments
1. Beginning of Year	5,844.08	
2. End of Year	6,040.10	
A. Change in Inventory (1 - 2)	(196.02)	
Purchases/Acquisitions of SF₆		
	AMOUNT (lbs.)	Comments
3. SF ₆ purchased from producers or distributors in cylinders	2,070.00	
4. SF ₆ provided by equipment manufacturers with/inside equipment	8,357.00	
5. SF ₆ returned to the site after off-site recycling	-	
B. Total Purchases/Acquisitions (3+4+5)	10,427.00	
Sales/Disbursements of SF₆		
	AMOUNT (lbs.)	Comments
6. Sales of SF ₆ to other entities, including gas left in equipment that is sold	-	
7. Returns of SF ₆ to supplier	343.20	
8. SF ₆ sent to destruction facilities	-	
9. SF ₆ sent off-site for recycling	3,551.80	
C. Total Sales/Disbursements (6+7+8+9)	3,895.00	
Change in Nameplate Capacity		
	AMOUNT (lbs.)	Comments
10. Total nameplate capacity (proper full charge) of <u>new</u> equipment	910.00	
11. Total nameplate capacity (proper full charge) of <u>retired</u> or <u>sold</u> equipment	1,170.00	
D. Change in Capacity (10 - 11)	(260.00)	
Total Annual Emissions		
	lbs. SF ₆	Tonnes CO ₂ equiv. (lbs. SF ₆ x 22,800/2205)
E. Total Emissions (A+B-C-D)	6,595.98	68,203.33
Emission Rate (optional)		
	AMOUNT (lbs.)	Comments
Total Nameplate Capacity at End of Year	48,872.00	
	PERCENT (%)	
F. Emission Rate (Emissions/Capacity)	13.5%	



EPA Reporting is required every calendar year (due March/April of the following year).

What is required reporting


- Nameplate capacity of:
 - equipment containing SF₆ at the beginning of the year
 - new equipment purchased during the year; and
 - equipment retired during the year.
- Transmission miles (length of lines carrying voltages at or above 34.5 kV).
- SF₆ sales and purchases.
- SF₆ sent off site for destruction
- SF₆ sent off site for recycling.
- SF₆ returned to site after recycling.
- SF₆ stored in containers at the beginning and end of the year.
- SF₆ with or inside new equipment purchased during the year.
- SF₆ with or inside equipment sold to other entities.
- SF₆ returned to suppliers.



Overview of SF₆ reporting regulations




Overview of SF₆ reporting regulations




Not many reporters to the EPA in NJ.

However the trend illustrates a drastic drop in emissions through the history of the GHGR Tool.


Electric Utilities Territory Map



<http://www.njcleanenergy.com>



Overview of SF₆ reporting regulations




The annual average SF₆ emission rate of Partners has decreased drastically since 1999. In the past five years, the emission rate has halved, from over 4 percent to just below 2 percent. Overall, the annual average SF₆ emission rate for the Partnership is down approximately 87 percent from the 1999 baseline emission rate of 14.2 percent to 1.9 percent in 2013.


<https://www.epa.gov/f-gas-partnership-programs/electric-power-systems-partnership>

Responsible practices and processes, improvement in reporting accuracy and technological improvements with GIE & recovery systems and measuring equipment have contributed to great improvements.

Figure 2-1: Gross U.S. Greenhouse Gas Emissions by Gas (MMT CO₂ Eq.)



REF: Draft Greenhouse Gas Emissions Inventory Report – Released for 2019



Overview of SF₆ reporting regulations


State Regulations - Subarticle 3.1, Regulation for Reducing Sulfur Hexafluoride Emissions from Gas Insulated Switchgear sections 95350 to 95359, title 17, California Code of Regulations.

- CARB – California Air Resources Board
- Goal – lower annual emissions to no more than 1% by 2020


- Entity Name (Company, Corporation, Entity or agency)
 - CARB ID as assigned
 - Record location (site or plant name of reporting origination) - Street Address, City, Zip Code, State
 - Name of the individual preparing the report - Telephone, email
- Emission Reporting
 - Reporting Year
 - Annual SF₆ Gas emissions in pounds
 - User Emissions LBS = (Decrease in SF₆ inventory)+ (Acquisitions of SF₆) – (Disbursements of SF₆) – (Net Increase of Nameplate SF₆ Capacity of Active & Owned GIS Equipment)
 - Annual SF₆ emissions in %
 - User Emissions % = Emissions (LBS) ÷ Cavg
 - Cavg = The average number of days a GIS is installed the reporting year.
 - GIS Serial Number, Type (bus, breaker, switch), Seal type (Hermetically Sealed or Not), MFG, MFG Date.
 - Cylinder ID (Serial Number)
 - Container size (capacity in lbs.)
 - Location of storage of each cylinder - Street address, City, Zip Code and State
 - SF₆ Gas in each container.




Overview of SF₆ reporting regulations



Maximum Annual SF ₆ Emission Rate	
Calendar Year Maximum Allowable SF ₆ Emission Rate	
2011	10%
2012	9%
2013	8%
2014	7%
2015	6%
2016	5%
2017	4%
2018	3%
2019	2%
2020 and each calendar year thereafter	1%



Overview of SF₆ reporting regulations




MassDEP

- Massachusetts Department of Environmental Protection
- (GHG) –reporting rule
 - 40CFR part 98 and 310 CMR 7.71, et seq., respectively
- Control of Emissions from (GIS)
- NEW equipment purchased by MA after Jan. 1 2015, may not exceed a 1% emission rate.
- Must comply with declining all emissions to 1% or less by 2020

Maximum Annual SF ₆ Emission Rate	
Calendar Year	Maximum Allowable SF ₆ Emission Rate
2013	3.5%
2014	3.5%
2015	3.5%
2016	3.0%
2017	2.5%
2018	2.0%
2019	1.5%
2020, and each calendar year thereafter	1.0%




Overview of SF₆ reporting regulations



Oregon Department of Environmental Quality

- Chapter 340, Division 215 GREENHOUSE GAS REPORTING REQUIREMENTS
- Investor Owned & Consumer Owned Utilities, electricity service suppliers and other electricity suppliers (with some specific exceptions for each type (consumer or investor owned) consumer-owned utilities) required to register and report under OAR 340-215-0030(6)
- Investor owned utilities and electricity service suppliers must determine SF₆ emissions from transmission and distribution equipment, they own or operate pursuant to methodologies included in 40 CFR Part 98, Subpart DD with a modification to delineate emissions for Oregon. While EPA's protocols require reporting of the total emissions for all equipment owned or operated by the company, each company must estimate the emissions associated with their provision of electricity to Oregonians in their report to DEQ. Each company must do this by calculating the SF₆ emissions based upon the portion of electricity they supply to Oregon end users. Companies must do this by first calculating the total SF₆ emissions from all their transmission and distribution equipment pursuant to 40 CFR Part 98, Subpart DD, and then multiplying these emissions by the ratio of the amount of electricity the utility supplied to Oregon end users compared to the total electricity the utility supplied within its jurisdiction.



Overview of SF₆ reporting regulations

Washington State

- Washington State Department of Ecology & Wash Environmental Council
- City of Seattle
- Puget Sound Clean Air Agency

All have adopted and/or reference policies and regulations as set by the EPA.

In some cases Carbon Taxes are issued to SF₆ gas emissions based on calculations set by these policies and regulations. Each agency or local Environmental Agency enforces the policies and regulations as applicable to each region.

The state and the regional agencies are reviewing their policies. However, they have been reporting a significant reduction in emissions and improved management.



Overview of SF₆ reporting regulations


EMERGENT GAS LOSS Rule & Regulation:

- EPA
 - CARB
 - MassDEP
 - Others
- a) A GIS owner may request emissions from an emergency event to be exempted from the calculation of the maximum allowable emission rate if it is demonstrated to the Executive Officer's satisfaction that the release of SF₆:
- (1) Could not have been prevented by the exercise of prudence, diligence, and care; and
 - (2) Was beyond the control of the GIS owner.

Each agency may have additional requirements:

- Location
- Event description
- Equipment model, Type, Serial Number and MFG
- Amount of SF₆ gas emission





Electric Transmission & Distribution SF₆ Coalition


What's being done to reduce emissions

- SF₆ handling practices
- Alternative Solutions



Processes & Actions for SF₆ emission Reduction

- What has been done:
 - Improved Accountability and Documentation
 - Training of field personnel to ensure zero loss during any gas handling event
 - Traceability of events including Emergent Loss events, leaking GIE, Repair/Replacement of leaking GIE.
 - Technological advancement of recovery equipment which allows for zero emission practices.
 - Scale calibration and Mass Flow Meter implementation
 - Self Sealing fittings that are zero emission
 - Improved leak detection processes
 - Cylinder accountability
 - MFG improvements of GIE with <1% annual leakage rates




Processes & Actions for SF₆ emission Reduction

Recovery Preparations

Prior to starting the recovery process, the following steps and tests should be performed:


- **Adequate sized recovery system:** guarantees the most amount of gas can be recovered in a reasonable amount of time
- **Testing the SF₆ for arc by-products:** to determine the need for filtration and personnel protective equipment (PPE)
- **Testing the SF₆ for moisture:** to determine the need for additional filtration
- **Testing the SF₆ for purity (Volume Percentage):** to determine the need for makeup SF₆ and possibly additional storage
- **Connecting procedures:** properly testing all hoses and fittings to eliminate potential emissions or contamination
- **Proper Storage:** ensure that a large enough storage vessel or an adequate number of in-test DOT cylinders are available
- **Weighing device:** ensure that a properly calibrated weighing device is used to prevent overfilling storage and that all the gas has been removed from GIE





Processes & Actions for SF₆ emission Reduction


- **Understanding residual pressure**
 - Stopping the recovery process at 0 PSIG on a vessel with an operating pressure of 90 PSIG will leave 14% of the SF₆ behind
 - If the equipment was opened, the remaining gas would be permanently lost to the atmosphere.




Processes & Actions for SF₆ emission Reduction

All breakers are filled based on the required density per the application.

The use of a Mass Flow Meter during filling and/or calibrated cylinder weigh scales allow the operator to account for all the gas moved from a cylinder to a GIE or from GIE to a cylinder.





Alternative solutions

	SF ₆	Fluorinated nitrile (Novec 4710 fluid) + CO ₂	Fluoroketone (Novec 5110) + CO ₂ or N ₂	Synthetic Air (80% N ₂ + 20% O ₂)
CO ₂ equivalent	~ 22,800	~ 380	< 1	0
Carrier gas	Pure or variable with N ₂ , CF ₄	~ 90% CO ₂	~ 90% CO ₂ with N ₂ or O ₂	Not applicable
Boiling point	-64° C	~ -25° C	+5° C	< -183° C
Mean residence time in the atmosphere	3,200 years	30 years	16 days	-

Source: CIGRE Paper B3-108 CIGRE Conference 2016; Data sheet 3M™ Novec™ 4710 / Novec™ 5110 *)


Note:

These are only examples of current alternatives being considered & tested. The market is evolving & continuing to add options for different voltages & fault duty.

- Fault duty & continuous current must be considered.

	CO ₂ equivalent	Carrier Gas	Boiling Point	Mean residence time in the atmosphere
Reconditioned SF₆ Gas	~22,800	Pure or with N ₂ , CF ₄	-64° C	3,200 years

A positive alternative that currently meets all the requirements & lowers overall footprint & contribution of emissions worldwide.



Alternative solutions

Conclusion to Technical Paper from Nov 2002 at the **International Conference on SF₆ and the Environment: Emission and Reduction Strategies EPA workshop**, Technical Paper & Case Study by Solvay Fluor, AGA Gas and AEP.

Inventory Management

- Inventory control a must for ReUse Program
 - Control and track every pound of used SF₆
 - Retain ownership until confirmation that gas was introduced in production stream, and
 - Empty cylinders returned to point of origin and final weight recorded

Summary

- Viable program for reclaiming used SF₆ gas
- Logistics of the program tailored for US
 - Working with partners like AGA Gas
 - Currently working on other cases with AEP for reclaiming used gas

“The beneficial impact of the SF₆ Re-Use program on global warming is evident”

Conclusion

Every pound of SF₆ taken back for reclaiming and therefore not released in the atmosphere is equivalent to an emissions savings of 22,500 pounds of CO₂

“Another less evident, but equally beneficial impact to the environment as a result of the program is that the toxic decomposition products found in used SF₆ gas are also not released.”

The SF₆ ReUse Program A Case Study

Daniel Lauzon Solvay Fluorides, Inc.
Todd Morris AGA Gas, Inc.
David McCreary American Electric Power
Michael Pittroff Solvay Fluor und
Derivate GmbH

November 21-22, 2002
San Diego, CA

Electric Transmission & Distribution SF₆ Coalition



- THANK YOU for the opportunity to present!
- New Jersey Clean Air Council Annual Public Hearing

Q&A

**I AM GIVING FREE
BAD
ADVICE
TODAY!
ASK ME ANYTHING!**