

2023



State of New Jersey
Department of Community Affairs
Bureau of Fire Code Enforcement
101 South Broad St, P.O. BOX 809
Trenton, NJ 08625-0809

www.dep.nj.gov
C/O Tom McCann
McCann's at the Meadow

4185 ATLANTIC AVE
07727-3713
Farmingdale, NJ 07727
United States of America

Type: FIRE Order to Pay Penalties
Issue Date: 10/12/2023
Invoice#: 5490813
Invoice Year: 2023
Due Date: 10/12/2023

General Information:

Pursuant to Section 10 of the Uniform Fire Safety Act (N.J.S.A. 52:27D-201) you are in violation for failure to pay annual your Life Hazard Use registration fee. Therefore, you are hereby ORDERED to pay annual Life Hazard Use registration fee(s) AND fee penalty pursuant to N.J.A.C. 5:70-2.12 in the amount of \$641.00 within 30 days of receipt of this Order.

BUSINESS ADDRESS:
McCann's at the Meadow
4185 Atlantic Avenue
WALL TWP, MONMOUTH COUNTY

Be advised that the Act states: "The owner of a life hazard use or high-rise structure shall pay the annual fee within 30 days of the day on which it is demanded by the department or the local enforcing agency. " Having failed to comply, a PENALTY has been assessed pursuant to N.J.A.C. 5:70-2.12 which states; "Failure to pay the required annual registration fee after having been ordered to do so – an amount equal to the unpaid registration fee for each registration may be assessed." Payment of the fee and/or judgment after imposition of the penalty shall not absolve the owner from responsibility for the penalty nor shall payment of the penalty be deemed to absolve the owner from the obligation to pay the fee. If you believe that the content of the billing information is incorrect, you may provide documentation supporting a bill modification; however, providing such documentation does not alleviate your obligation to pay the remaining balance of the Order within the stated timeframe.

Payment Information: Payments may be made online at the Division of Fire Safety's website (<http://www.nj.gov/dca/divisions/dfs/>) under the **DCA Service Portal** link. All payments made by mail should include check and stub. The stub should clearly indicate the payment amount. If you have any questions or concerns regarding this bill, please call (609) 633-6132 before the due date.

Correspondence: All correspondence regarding this bill should be emailed to bfcecodeadmin@dca.nj.gov or mailed to the address noted before the due date. Do not mail correspondence with payment, as this will delay delivery.

Correspondence Address:
Bureau of Fire Code Enforcement
PO Box 809
Trenton, NJ 08625-0809

ID	ASSESSMENT DESCRIPTION	AMOUNT CHARGED	
1427268	FIRE Order to Pay Penalties	\$641.00	
5456245	FIRE Registration Renewal Fee	\$641.00	
TOTAL INVOICE CHARGES ASSESSED			\$1,282.00
TOTAL INVOICE CHARGES PAID			\$0.00
TOTAL INVOICE BALANCE			\$1,282.00

Detach and return ONLY this portion with your check made payable to Treasurer, State of New Jersey. Please write your Registration # on your check.

Invoice #: 5490813

BFCE

www.dep.nj.gov
C/O Tom McCann
McCann's at the Meadow
4185 ATLANTIC AVE
07727-3713
Farmingdale, NJ 07727
United States of America

Registration #: 1352-049979.001

Payment Amount _____
Current Charge: \$1,282.00

Mail payment to:
State of New Jersey
DCA BFCE - DORES
P.O. Box 663
Trenton, NJ 08646-0663B

Please pay this amount by:
10/12/2023

CAF90005490813001352049979001400001282000

ADMINISTRATIVE APPEAL RIGHTS:

The owner of the premises or of the use, or an authorized agent of the owner MAY CONTEST THIS ORDER at an Administrative Hearing. The request for a hearing must be made in writing within 15 days (24 hours for imminent hazards) after receipt of this order. Request may be made online at the Division of Fire Safety's website <https://www.nj.gov/dca/divisions/dfs> under the DCA Service Portal link or addressed to:

Department of Community Affairs
Hearing Coordinator
P0 Box 809
Trenton, New Jersey 08625-0809

In accordance with N.J.A.C. 5:70-2.19 an appeal shall be signed by a proper party and shall include:

- a) The date of the act, which is the subject of the appeal.
- b) The name and status of the person submitting the appeal.
- c) The specific violations of other act claimed to be in error; and
- d) A concise statement of the basis for the appeal

You are advised that only matters deemed to be CONTESTED CASES, as defined by the Administrative Procedures Act, will be scheduled for a Hearing. If a hearing is scheduled, you will be notified in advance of the time and place. At a hearing a corporation may be represented only by a licensed attorney, unless approval is given by the Office of Administrative Law. If you elect to submit an appeal online, you will be asked to supply your **Registration Number**, which is **1352-049979.001** and **Invoice Number**, which is **5490813**. Please enter these fields when requesting your appeal.



State of New Jersey
Department of Community Affairs
BUREAU OF FIRE CODE ENFORCEMENT
P O BOX 809
Trenton, NJ 08625-0809

FIRE SAFETY PERMIT

Permit #: 10000752

Fire Pit Table 1

Business Name: 4185 Atlantic Avenue
Business Owner: C/O BILLY EPP
Owner's Phone: [REDACTED]
Owner's Mailing Address: 4185 ATLANTIC AVENUE
WALL, NJ
07727

Permit Type: 1E05 - Open flame/cooking for entertaining or recreation.
Permit Description: N.J.A.C. 5:70-2.7(a)3v: Type 1 The use of any open flame or flame-producing device, in connection with any public gathering, for purposes of entertainment, amusement, or recreation

Permit Fee: Type 1 \$54.00
Type 2 \$214.00
Type 3 \$427.00
Type 4 \$641.00

Date of Event: 4/1/2023

Expiration Date: 12/1/2023

Dana Foster, Inspector

Rain Date: -

Louis Kilmer, Bureau Chief
Bureau of Fire Code Enforcement

Name of Premises: 4185 Atlantic Avenue
State Facility: Yes

06-12-2023

Location of Event: 4185 Atlantic Avenue
WALL TWP, MONMOUTH COUNTY

Date of Approval

Approval is contingent on adherence with any attached conditions.

This permit must be posted in a conspicuous location at the above address.



State of New Jersey
Department of Community Affairs
BUREAU OF FIRE CODE ENFORCEMENT
P O BOX 809
Trenton, NJ 08625-0809

FIRE SAFETY PERMIT

Permit #: 10000752

The applicant agrees to comply with the following Fire Safety Permit Application Conditions:

1. Application for a permit required by this Code shall be made to the fire official in such form and detail as the fire official shall prescribe. Applications for permits shall be accompanied by plans or drawings as required by the fire official for evaluation of the application. Additional information may be required by the Fire Official for the evaluation of the application.
2. Before a permit is issued, the fire official or the fire official's designated representative shall make or cause to be made such inspections or tests as necessary to assure that the use and activity for which application is made complies with the provisions of this Code.
3. A permit shall constitute permission to maintain, store or handle materials, or to conduct processes which produce conditions hazardous to life or property, or to install equipment used in connection with such activities in accordance with the provisions of this Code. Such permissions shall not be construed as authority to violate, cancel or set aside any of the provisions of this Code.
4. Plans approved by the fire official are approved with the intent they comply in all respects to this Code. Any omission or error on the plans does not relieve the applicant of complying with all applicable requirements of this Code.
5. The fire official may revoke a permit or approval issued under the provisions of this Code if upon inspection any violation of the Code exists, or if conditions of a permit have been violated, or if there has been any false statement or misrepresentation as to material fact in the application, data or plans on which the permit or approval was based.
6. A permit shall remain in effect until revoked, or for one year unless a shorter period of time is otherwise specified. Permits shall not be transferable and any change in use, operation or tenancy shall require a new permit.

Exceptions:

- a. A type 1 permit for welding or cutting shall be effective throughout the local enforcing agency's jurisdiction and shall be issued on an annual basis;
- b. A Type 1 permit for use of a commercial farm building as a place of public assembly shall be issued for each event; and
- c. A Type 1 permit for group overnight stays shall be required for each non-consecutive overnight stay.
- d. A Type I permit for the temporary use of any building as a special amusement building shall be issued for each event.



State of New Jersey
Department of Community Affairs
BUREAU OF FIRE CODE ENFORCEMENT
P O BOX 809
Trenton, NJ 08625-0809

FIRE SAFETY PERMIT

Permit #: 10000752

Fire Pit Table 2

Business Name: 4185 Atlantic Avenue
Business Owner: C/O BILLY EPP
Owner's Phone: [REDACTED]
Owner's Mailing Address: 4185 ATLANTIC AVENUE
WALL, NJ
07727

Permit Type: 1E05 - Open flame/cooking for entertaining or recreation.
Permit Description: N.J.A.C. 5:70-2.7(a)3v: Type 1 The use of any open flame or flame-producing device, in connection with any public gathering, for purposes of entertainment, amusement, or recreation

Permit Fee: Type 1 \$54.00
Type 2 \$214.00
Type 3 \$427.00
Type 4 \$641.00

Date of Event: 4/1/2023

Expiration Date: 12/1/2023

Dana Foster, Inspector

Rain Date: -

Louis Kilmer, Bureau Chief
Bureau of Fire Code Enforcement

Name of Premises: 4185 Atlantic Avenue
State Facility: Yes

06-12-2023

Date of Approval

Location of Event: 4185 Atlantic Avenue
WALL TWP, MONMOUTH COUNTY

Approval is contingent on adherence with any attached conditions.

This permit must be posted in a conspicuous location at the above address.



State of New Jersey
Department of Community Affairs
BUREAU OF FIRE CODE ENFORCEMENT
P O BOX 809
Trenton, NJ 08625-0809

FIRE SAFETY PERMIT

Permit #: 10000752

The applicant agrees to comply with the following Fire Safety Permit Application Conditions:

1. Application for a permit required by this Code shall be made to the fire official in such form and detail as the fire official shall prescribe. Applications for permits shall be accompanied by plans or drawings as required by the fire official for evaluation of the application. Additional information may be required by the Fire Official for the evaluation of the application.
2. Before a permit is issued, the fire official or the fire official's designated representative shall make or cause to be made such inspections or tests as necessary to assure that the use and activity for which application is made complies with the provisions of this Code.
3. A permit shall constitute permission to maintain, store or handle materials, or to conduct processes which produce conditions hazardous to life or property, or to install equipment used in connection with such activities in accordance with the provisions of this Code. Such permissions shall not be construed as authority to violate, cancel or set aside any of the provisions of this Code.
4. Plans approved by the fire official are approved with the intent they comply in all respects to this Code. Any omission or error on the plans does not relieve the applicant of complying with all applicable requirements of this Code.
5. The fire official may revoke a permit or approval issued under the provisions of this Code if upon inspection any violation of the Code exists, or if conditions of a permit have been violated, or if there has been any false statement or misrepresentation as to material fact in the application, data or plans on which the permit or approval was based.
6. A permit shall remain in effect until revoked, or for one year unless a shorter period of time is otherwise specified. Permits shall not be transferable and any change in use, operation or tenancy shall require a new permit.

Exceptions:

- a. A type 1 permit for welding or cutting shall be effective throughout the local enforcing agency's jurisdiction and shall be issued on an annual basis;
- b. A Type 1 permit for use of a commercial farm building as a place of public assembly shall be issued for each event; and
- c. A Type 1 permit for group overnight stays shall be required for each non-consecutive overnight stay.
- d. A Type I permit for the temporary use of any building as a special amusement building shall be issued for each event.



State of New Jersey
Department of Community Affairs
BUREAU OF FIRE CODE ENFORCEMENT
P O BOX 809
Trenton, NJ 08625-0809

FIRE SAFETY PERMIT

Permit #: 10000752

Fire Pit Table 3

Business Name: 4185 Atlantic Avenue
Business Owner: C/O BILLY EPP
Owner's Phone: [REDACTED]
Owner's Mailing Address: 4185 ATLANTIC AVENUE
WALL, NJ
07727

Permit Type: 1E05 - Open flame/cooking for entertaining or recreation.
Permit Description: N.J.A.C. 5:70-2.7(a)3v: Type 1 The use of any open flame or flame-producing device, in connection with any public gathering, for purposes of entertainment, amusement, or recreation

Permit Fee: Type 1 \$54.00
Type 2 \$214.00
Type 3 \$427.00
Type 4 \$641.00

Date of Event: 4/1/2023

Expiration Date: 12/1/2023

Dana Foster, Inspector

Rain Date: -

Louis Kilmer, Bureau Chief
Bureau of Fire Code Enforcement

Name of Premises: 4185 Atlantic Avenue
State Facility: Yes

06-12-2023

Location of Event: 4185 Atlantic Avenue
WALL TWP, MONMOUTH COUNTY

Date of Approval

Approval is contingent on adherence with any attached conditions.

This permit must be posted in a conspicuous location at the above address.



State of New Jersey
Department of Community Affairs
BUREAU OF FIRE CODE ENFORCEMENT
P O BOX 809
Trenton, NJ 08625-0809

FIRE SAFETY PERMIT

Permit #: 10000752

The applicant agrees to comply with the following Fire Safety Permit Application Conditions:

1. Application for a permit required by this Code shall be made to the fire official in such form and detail as the fire official shall prescribe. Applications for permits shall be accompanied by plans or drawings as required by the fire official for evaluation of the application. Additional information may be required by the Fire Official for the evaluation of the application.
2. Before a permit is issued, the fire official or the fire official's designated representative shall make or cause to be made such inspections or tests as necessary to assure that the use and activity for which application is made complies with the provisions of this Code.
3. A permit shall constitute permission to maintain, store or handle materials, or to conduct processes which produce conditions hazardous to life or property, or to install equipment used in connection with such activities in accordance with the provisions of this Code. Such permissions shall not be construed as authority to violate, cancel or set aside any of the provisions of this Code.
4. Plans approved by the fire official are approved with the intent they comply in all respects to this Code. Any omission or error on the plans does not relieve the applicant of complying with all applicable requirements of this Code.
5. The fire official may revoke a permit or approval issued under the provisions of this Code if upon inspection any violation of the Code exists, or if conditions of a permit have been violated, or if there has been any false statement or misrepresentation as to material fact in the application, data or plans on which the permit or approval was based.
6. A permit shall remain in effect until revoked, or for one year unless a shorter period of time is otherwise specified. Permits shall not be transferable and any change in use, operation or tenancy shall require a new permit.

Exceptions:

- a. A type 1 permit for welding or cutting shall be effective throughout the local enforcing agency's jurisdiction and shall be issued on an annual basis;
- b. A Type 1 permit for use of a commercial farm building as a place of public assembly shall be issued for each event; and
- c. A Type 1 permit for group overnight stays shall be required for each non-consecutive overnight stay.
- d. A Type I permit for the temporary use of any building as a special amusement building shall be issued for each event.



State of New Jersey
Department of Community Affairs
BUREAU OF FIRE CODE ENFORCEMENT
P O BOX 809
Trenton, NJ 08625-0809

FIRE SAFETY PERMIT

Permit #: 10000752

Fire Pit Table 4

Business Name: 4185 Atlantic Avenue
Business Owner: C/O BILLY EPP
Owner's Phone: [REDACTED]
Owner's Mailing Address: 4185 ATLANTIC AVENUE
WALL, NJ
07727

Permit Type: 1E05 - Open flame/cooking for entertaining or recreation.
Permit Description: N.J.A.C. 5:70-2.7(a)3v: Type 1 The use of any open flame or flame-producing device, in connection with any public gathering, for purposes of entertainment, amusement, or recreation

Permit Fee: Type 1 \$54.00
Type 2 \$214.00
Type 3 \$427.00
Type 4 \$641.00

Date of Event: 4/1/2023

Expiration Date: 12/1/2023

Dana Foster, Inspector

Rain Date: -

Louis Kilmer, Bureau Chief
Bureau of Fire Code Enforcement

Name of Premises: 4185 Atlantic Avenue
State Facility: Yes

06-12-2023

Location of Event: 4185 Atlantic Avenue
WALL TWP, MONMOUTH COUNTY

Date of Approval

Approval is contingent on adherence with any attached conditions.

This permit must be posted in a conspicuous location at the above address.



State of New Jersey
Department of Community Affairs
BUREAU OF FIRE CODE ENFORCEMENT
P O BOX 809
Trenton, NJ 08625-0809

FIRE SAFETY PERMIT

Permit #: 10000752

The applicant agrees to comply with the following Fire Safety Permit Application Conditions:

1. Application for a permit required by this Code shall be made to the fire official in such form and detail as the fire official shall prescribe. Applications for permits shall be accompanied by plans or drawings as required by the fire official for evaluation of the application. Additional information may be required by the Fire Official for the evaluation of the application.
2. Before a permit is issued, the fire official or the fire official's designated representative shall make or cause to be made such inspections or tests as necessary to assure that the use and activity for which application is made complies with the provisions of this Code.
3. A permit shall constitute permission to maintain, store or handle materials, or to conduct processes which produce conditions hazardous to life or property, or to install equipment used in connection with such activities in accordance with the provisions of this Code. Such permissions shall not be construed as authority to violate, cancel or set aside any of the provisions of this Code.
4. Plans approved by the fire official are approved with the intent they comply in all respects to this Code. Any omission or error on the plans does not relieve the applicant of complying with all applicable requirements of this Code.
5. The fire official may revoke a permit or approval issued under the provisions of this Code if upon inspection any violation of the Code exists, or if conditions of a permit have been violated, or if there has been any false statement or misrepresentation as to material fact in the application, data or plans on which the permit or approval was based.
6. A permit shall remain in effect until revoked, or for one year unless a shorter period of time is otherwise specified. Permits shall not be transferable and any change in use, operation or tenancy shall require a new permit.

Exceptions:

- a. A type 1 permit for welding or cutting shall be effective throughout the local enforcing agency's jurisdiction and shall be issued on an annual basis;
- b. A Type 1 permit for use of a commercial farm building as a place of public assembly shall be issued for each event; and
- c. A Type 1 permit for group overnight stays shall be required for each non-consecutive overnight stay.
- d. A Type I permit for the temporary use of any building as a special amusement building shall be issued for each event.



State of New Jersey
Department of Community Affairs
BUREAU OF FIRE CODE ENFORCEMENT
P O BOX 809
Trenton, NJ 08625-0809

FIRE SAFETY PERMIT

Permit #: 10000752

Fire Pit Table 5

Business Name: 4185 Atlantic Avenue
Business Owner: C/O BILLY EPP
Owner's Phone: [REDACTED]
Owner's Mailing
Address: 4185 ATLANTIC AVENUE
WALL, NJ
07727

Permit Type: 1E05 - Open flame/cooking for entertaining or recreation.
Permit Description: N.J.A.C. 5:70-2.7(a)3v: Type 1 The use of any open flame or flame-producing device, in connection with any public gathering, for purposes of entertainment, amusement, or recreation

Permit Fee: Type 1 \$54.00
Type 2 \$214.00
Type 3 \$427.00
Type 4 \$641.00

Date of Event: 4/1/2023

Expiration Date: 12/1/2023

Dana Foster, Inspector

Rain Date: -

Louis Kilmer, Bureau Chief
Bureau of Fire Code Enforcement

Name of Premises: 4185 Atlantic Avenue
State Facility: Yes

06-12-2023

Location of Event: 4185 Atlantic Avenue
WALL TWP, MONMOUTH COUNTY

Date of Approval

Approval is contingent on adherence with any attached conditions.

This permit must be posted in a conspicuous location at the above address.



State of New Jersey
Department of Community Affairs
BUREAU OF FIRE CODE ENFORCEMENT
P O BOX 809
Trenton, NJ 08625-0809

FIRE SAFETY PERMIT

Permit #: 10000752

The applicant agrees to comply with the following Fire Safety Permit Application Conditions:

1. Application for a permit required by this Code shall be made to the fire official in such form and detail as the fire official shall prescribe. Applications for permits shall be accompanied by plans or drawings as required by the fire official for evaluation of the application. Additional information may be required by the Fire Official for the evaluation of the application.
2. Before a permit is issued, the fire official or the fire official's designated representative shall make or cause to be made such inspections or tests as necessary to assure that the use and activity for which application is made complies with the provisions of this Code.
3. A permit shall constitute permission to maintain, store or handle materials, or to conduct processes which produce conditions hazardous to life or property, or to install equipment used in connection with such activities in accordance with the provisions of this Code. Such permissions shall not be construed as authority to violate, cancel or set aside any of the provisions of this Code.
4. Plans approved by the fire official are approved with the intent they comply in all respects to this Code. Any omission or error on the plans does not relieve the applicant of complying with all applicable requirements of this Code.
5. The fire official may revoke a permit or approval issued under the provisions of this Code if upon inspection any violation of the Code exists, or if conditions of a permit have been violated, or if there has been any false statement or misrepresentation as to material fact in the application, data or plans on which the permit or approval was based.
6. A permit shall remain in effect until revoked, or for one year unless a shorter period of time is otherwise specified. Permits shall not be transferable and any change in use, operation or tenancy shall require a new permit.

Exceptions:

- a. A type 1 permit for welding or cutting shall be effective throughout the local enforcing agency's jurisdiction and shall be issued on an annual basis;
- b. A Type 1 permit for use of a commercial farm building as a place of public assembly shall be issued for each event; and
- c. A Type 1 permit for group overnight stays shall be required for each non-consecutive overnight stay.
- d. A Type I permit for the temporary use of any building as a special amusement building shall be issued for each event.



State of New Jersey
Department of Community Affairs
P. O. Box 809
Trenton, NJ 08625-0809
609-633-6132

Page 1 of 7

NOTICE OF VIOLATION AND ORDERS OF THE COMMISSIONER

Business Name:	McCann's at the Meadow	Registration #:	1352-049979.001	Inspector:	Dana Foster
Inspection Date:	6/8/2023	Inspection Type:	Annual		
Notice #:	40238921	Issuance Date:	8/4/2023		

Business	Business Owner	Property Owner	On Site Contact
McCann's at the Meadow 4185 Atlantic Avenue WALL TWP, MONMOUTH COUNTY 07727 Registration #: 1352-049979.001	www.dep.nj.gov C/O Tom McCann 4185 ATLANTIC AVE 07727-3713 Farmingdale, NJ 07727 United States of America 7324494100	www.dep.nj.gov Tom McCann 4185 ATLANTIC AVE 07727-3713 Farmingdale, NJ 07727 United States of America 7324494100	

USE GROUP	USE CODE	USE CODE DESCRIPTION
Eating/Drinking	McCann's Taven - Main Dinning Area: BD05	Eating/drinking establishment 100-199 people.

YOU ARE HEREBY NOTIFIED THAT an inspection at the above referenced property by the New Jersey Division of Fire Safety disclosed violations of the Uniform Fire Code (N.J.A.C. 5:70-1 et seq.), promulgated pursuant to the New Jersey Uniform Fire Safety Act (N.J.S.A. 52:27D-192 et seq.). The violations are specified on the accompanying "fire code violations" page(s).

YOU ARE HEREBY ORDERED by the COMMISSIONER to correct the violations listed on the accompanying "violations" page(s) within the timeframe, or by the date specified. If a reinspection discloses that violations have not been corrected, you will be subject to penalties of up to \$5,000.00 per violation per day or as otherwise authorized by the Act and Department Regulations. IN ADDITION, the ACT imposes liability on the owner for the actual costs of fire suppression where a violation directly or indirectly results in a fire.

Kimberly K. Holmes
Acting Commissioner, Department of Community Affairs

By: Louis B. Kilmer, Bureau Chief, Bureau of Fire Code Enforcement
Division of Fire Safety

I hereby acknowledge receipt of a copy of this NOTICE OF VIOLATION and ORDER TO CORRECT.

Signature

William Epp

Printed Name

Business Manager

Title

8/4/2023

Date



State of New Jersey
Department of Community Affairs
P. O. Box 809
Trenton, NJ 08625-0809
609-633-6132

Page 2 of 7

NOTICE OF VIOLATION AND ORDERS OF THE COMMISSIONER

Business Name:	McCann's at the Meadow	Registration #:	1352-049979.001	Inspector:	Dana Foster
Inspection Date:	6/8/2023	Inspection Type:	Annual		
Notice #:	40238921	Issuance Date:	8/4/2023		



State of New Jersey
Department of Community Affairs
P. O. Box 809
Trenton, NJ 08625-0809
609-633-6132

Page 3 of 7

NOTICE OF VIOLATION AND ORDERS OF THE COMMISSIONER

Business Name:	McCann's at the Meadow	Registration #:	1352-049979.001	Inspector:	Dana Foster
Inspection Date:	6/8/2023	Inspection Type:	Annual		
Notice #:	40238921	Issuance Date:	8/4/2023		

VIOLATIONS

ID	Bldg #	Item Description	Violation Location	Code Requirement	Corrective Action	Abate By	Status
3160	Mc Cann's <1>1	Other	1719324 - \$414.00 - 7-31-2001	N.J.A.C. 5:70-2.2(e): (e) Subsequent owners or those succeeding to control over the premises shall be responsible for correcting unabated violations and for the payment of outstanding fees and/or penalties whether or not they have requested a certificate of fire code status.	Subsequent owners are responsible for correcting previously issued violations, and payment of previously issued fees and/or penalties.	9/3/2023	Cited
	Mc Cann's <1>1	Other	1719325 - \$414.00 - 7-30-2002	N.J.A.C. 5:70-2.2(e): (e) Subsequent owners or those succeeding to control over the premises shall be responsible for correcting unabated violations and for the payment of outstanding fees and/or penalties whether or not they have requested a certificate of fire code status.	Subsequent owners are responsible for correcting previously issued violations, and payment of previously issued fees and/or penalties.	9/3/2023	Cited
	Mc Cann's <1>1	Other	2140074 - \$497.00 - 08-30-2016	N.J.A.C. 5:70-2.2(e): (e) Subsequent owners or those succeeding to control over the premises shall be responsible for correcting unabated violations and for the payment of outstanding fees and/or penalties whether or not they have requested a certificate of fire code status.	Subsequent owners are responsible for correcting previously issued violations, and payment of previously issued fees and/or penalties.	9/3/2023	Cited



State of New Jersey
Department of Community Affairs
P. O. Box 809
Trenton, NJ 08625-0809
609-633-6132

Page 4 of 7

NOTICE OF VIOLATION AND ORDERS OF THE COMMISSIONER

Business Name:	McCann's at the Meadow	Registration #:	1352-049979.001	Inspector:	Dana Foster
Inspection Date:	6/8/2023	Inspection Type:	Annual		
Notice #:	40238921	Issuance Date:	8/4/2023		

ID	Bldg #	Item Description	Violation Location	Code Requirement	Corrective Action	Abate By	Status
	Mc Cann's <1>1	Other	4156325 - \$2000.00- 11-30-2020	N.J.A.C. 5:70-2.2(e): (e) Subsequent owners or those succeeding to control over the premises shall be responsible for correcting unabated violations and for the payment of outstanding fees and/or penalties whether or not they have requested a certificate of fire code status.	Subsequent owners are responsible for correcting previously issued violations, and payment of previously issued fees and/or penalties.	9/3/2023	Cited
	Mc Cann's <1>1	Other	4156326 - \$1000.00 - 11-30-2020	N.J.A.C. 5:70-2.2(e): (e) Subsequent owners or those succeeding to control over the premises shall be responsible for correcting unabated violations and for the payment of outstanding fees and/or penalties whether or not they have requested a certificate of fire code status.	Subsequent owners are responsible for correcting previously issued violations, and payment of previously issued fees and/or penalties.	9/3/2023	Cited
	Mc Cann's <1>1	Other	2573690 - \$54.00- 10-12-2021	N.J.A.C. 5:70-2.2(e): (e) Subsequent owners or those succeeding to control over the premises shall be responsible for correcting unabated violations and for the payment of outstanding fees and/or penalties whether or not they have requested a certificate of fire code status.	Subsequent owners are responsible for correcting previously issued violations, and payment of previously issued fees and/or penalties.	9/3/2023	Cited
	Mc Cann's <1>1	Other	4161700 - \$1500.00 - 01-04-2023	N.J.A.C. 5:70-2.2(e): (e) Subsequent owners or those succeeding to control over the	Subsequent owners are responsible for	9/3/2023	Cited



State of New Jersey
Department of Community Affairs
P. O. Box 809
Trenton, NJ 08625-0809
609-633-6132

Page 5 of 7

NOTICE OF VIOLATION AND ORDERS OF THE COMMISSIONER

Business Name:	McCann's at the Meadow	Registration #:	1352-049979.001	Inspector:	Dana Foster
Inspection Date:	6/8/2023	Inspection Type:	Annual		
Notice #:	40238921	Issuance Date:	8/4/2023		

ID	Bldg #	Item Description	Violation Location	Code Requirement	Corrective Action	Abate By	Status
				premises shall be responsible for correcting unabated violations and for the payment of outstanding fees and/or penalties whether or not they have requested a certificate of fire code status.	correcting previously issued violations, and payment of previously issued fees and/or penalties.		
3175	Mc Cann's <1>1	Other	Need a permit for fire pits in outside bar area	N.J.A.C. 5:70-2.7(a)3v: (a) Permits shall be required and obtained from the local enforcement agency for the activities specified in this section, except where they are an integral part of a process or activity by reason of which the use is required to be registered and regulated as a life hazard use. Permits shall at all times be kept in the premises designated therein and shall at all times be subject to inspection by the fire official.v. The use of any open flame or flame-producing device, in connection with any public gathering, for purposes of entertainment, amusement, or recreation;	Responsible party must comply with the violated provision(s) of the Code. [N.J.A.C. 5:70-2.7(a)3v]		Abated

ADMINISTRATIVE APPEAL RIGHTS

The owner of the premises or of the use, or an authorized agent of the owner MAY CONTEST THIS ORDER at an Administrative Hearing. The request for a hearing must be made in writing within 15 days after receipt of this order. Request may be made online at the Division or Fire Safety's website <https://nj.gov/dca/divisions/dfs/> under the DCA Service Portal link or addressed to:

Department of Community Affairs
Hearing Coordinator



State of New Jersey
Department of Community Affairs
P. O. Box 809
Trenton, NJ 08625-0809
609-633-6132

Page 6 of 7

NOTICE OF VIOLATION AND ORDERS OF THE COMMISSIONER

Business Name:	McCann's at the Meadow	Registration #:	1352-049979.001	Inspector:	Dana Foster
Inspection Date:	6/8/2023	Inspection Type:	Annual		
Notice #:	40238921	Issuance Date:	8/4/2023		

PO Box 809
Trenton, New Jersey 08625-0809

In accordance with N.J.A.C. 5:70-2.19 an appeal shall be signed by a proper party and shall include:

- a) The date of the act, which is the subject of the appeal.
- b) The name and status of the person submitting the appeal.
- c) The specific violations or other act claimed to be in error; and
- d) A concise statement of the basis for the appeal

You are advised that only matters deemed to be **CONTESTED CASES**, as defined by the Administrative Procedures Act, will be scheduled for a Hearing. If a hearing is scheduled, you will be notified in advance of the time and place. At a hearing a corporation may be represented only by a licensed attorney, unless approval is given by the Office of Administrative Law. If you elect to submit an appeal online, you will be asked to supply your Registration Number, which is 1352-049979.001, and Notice Number, which is 40238921. Please enter these fields when requesting your appeal.

EXTENSIONS

If a specified time has been given to abate a violation, **YOU MAY REQUEST AN EXTENSION OF TIME** by submitting a written request to the Division of Fire Safety. This request may be made online at the Division of Fire Safety's website <https://nj.gov/dca/divisions/dfs/> under the DCA Services Portal link. To be considered, the request must be made before the compliance date specified and must set forth the work accomplished, the work remaining, the reason why an extension of time is necessary and the date by which all work will be completed. **TAKE NOTICE THAT**, pursuant to N.J.A.C. 5:70-2.10(d) 2 an application for an extension shall be deemed to constitute an admission that the notice of violation is factually and procedurally correct and that the violations do or did exist. In addition, the request for an extension constitutes a waiver of the right to a hearing as to those violations for which an extension is applied.

PENALTIES

Pursuant to N.J.A.C. 5:70-2.12, a violation of the Code is punishable by monetary penalties of not more than \$5,000 per day for each violation. Each day a violation continues is an additional, separate violation except while an appeal is pending.

ALSO TAKE NOTICE THAT, pursuant to N.J.A.C. 5:70-2.12A, when an owner has been given notice of the existence of a violation and has not abated the violation, that owner shall, in addition to being liable to the penalty provided for by N.J.A.C. 5:70-2.12, be liable to a dedicated penalty in the like amount.

Pursuant to N.J.A.C. 5:70-2.12(e), a violation that is recurring justifies imposition of an immediate penalty without the necessity for an interval in which corrections can be made. A violation shall be deemed to be a recurring violation if a notice has been served within two years from the date that a previous notice was served and the violation, premises and responsible party are substantially the same.



State of New Jersey
Department of Community Affairs
P. O. Box 809
Trenton, NJ 08625-0809
609-633-6132

Page 7 of 7

NOTICE OF VIOLATION AND ORDERS OF THE COMMISSIONER

Business Name:	McCann's at the Meadow	Registration #:	1352-049979.001	Inspector:	Dana Foster
Inspection Date:	6/8/2023	Inspection Type:	Annual		
Notice #:	40238921	Issuance Date:	8/4/2023		

Claims arising out of penalty assessments can be compromised or settled if it shall be likely to result in compliance. Moreover, no such disposition can be finalized while the violation continues to exist.

Any penalties assessed are in addition to others previously assessed. Penalties must be paid in full within 30 days after an order to pay. If full payment is not made within 30 days, the matter will be referred to the Office of the Attorney General for summary collection pursuant to "The Penalty Enforcement Law of 1999," P.L.1999, C. 274 (C. 2A: 58-1 et seq.).

NOTICE

If you require guidance or advice concerning your legal rights, obligations or the course of action you should follow, consult your own advisor.

Attachments to Invoice #40238921



State of New Jersey
Department of Community Affairs
BUREAU OF FIRE CODE ENFORCEMENT
P O BOX 809
Trenton, NJ 08625-0809

Owner: FOUR ATLANTIC SERVICES LLC

Registration #: 1352049979.1

Property Interest Name: McCann's at the Meadow

Type: FIRE Registration
Renewal Fee
Issue Date: 8/30/2016

Address: 4185 ATLANTIC AVE
Farmingdale, NJ 07727

Bill #: 2140074

Due Date: 9/29/2016

General Information:

The Life Hazard Use Registration Fee(s) listed below are outstanding. Each Life Hazard Use as defined by N.J.A.C 5:70-2.4 is assessed an annual registration fee in accordance with the Uniform Fire Safety Act (N.J.S.A. 52:27D-201e). You are hereby **ORDERED TO PAY** the outstanding fees within thirty (30) days of 8/30/2016 pursuant to N.J.S.A. 52:27D-201d. Failure to pay the required amount within the time specified will result in a penalty equal to the unpaid fee for each registration, pursuant to N.J.S.A 52:27D-210c and N.J.A.C. 5:70-2.12(b) 8ii. Furthermore, the clerk of the Superior Court may issue a Docketed Judgment in Superior Court against the business as set forth in N.J.S.A. 52:27 D – 201g.

BUSINESS ADDRESS:

McCann's at the Meadow
4185 Atlantic Avenue
WALL TWP, MONMOUTH COUNTY

Payment Information: Payments may be made online at the Division of Fire Safety's website <https://www.nj.gov/dca/divisions/dfs> under the DCA Service Portal link. All payments made by mail should include check and stub. The stub should clearly indicate the payment amount. If you have any questions or concerns regarding this bill, please call **609-633-6132** before the due date.

Correspondence: All correspondence regarding this bill should be emailed to bfcecodeadmin@dca.nj.gov or mailed to the address noted before the due date. Do not mail correspondence with payment, as this will delay delivery.

Correspondence Address:

Bureau of Fire Code Enforcement
P O BOX 809
Trenton, NJ 08625-0809

TOTAL INVOICE CHARGES ASSESSED	\$497.00
TOTAL INVOICE CHARGES PAID	\$0.00
TOTAL INVOICE BALANCE	\$497.00

Detach and return ONLY this portion with your check made payable to Treasurer, State of New Jersey. Please write your Registration # on your check.

BFCE

FOUR ATLANTIC SERVICES LLC

Bill #: 2140074

Issue Date: 8/30/2016

McCann's at the Meadow
4185 ATLANTIC AVE
Farmingdale, NJ 07727

Reg #: 1352-049979.001

Amount Due: \$497.00

Mail Payment to:
State of New Jersey
DCA BFCE -- DORES
P.O. Box 663
Trenton, NJ 08646-0663

Please pay this amount by: 9/29/2016

CAF90002140074001352049979001400000497005

REGISTRATION NUMBER	USE CODE	ASSESSMENT DESCRIPTION	FEE	AMOUNT CHARGED
		FIRE Registration Renewal Fee	\$497.00	\$497.00



State of New Jersey
Department of Community Affairs
Bureau of Fire Code Enforcement
101 South Broad St, P.O. BOX 809
Trenton, NJ 08625-0809

www.dep.nj.gov
McCann's at the Meadow

4185 ATLANTIC AVE
07727-3713
Farmingdale, NJ 07727
United States of America

Type: FIRE Inspection Violation Penalty
Issue Date: 11/30/2020
Invoice#: 4156325
Invoice Year: 2020
Due Date: 12/30/2020

General Information:

Pursuant to Section 10 of the Uniform Fire Safety Act (N.J.S.A. 52:27D-201) you are in violation for failure to pay annual your Life Hazard Use registration fee. Therefore, you are hereby ORDERED to pay annual Life Hazard Use registration fee(s) AND fee penalty pursuant to N.J.A.C. 5:70-2.12 in the amount of \$2,000.00 within 30 days of receipt of this Order.

BUSINESS ADDRESS:
McCann's at the Meadow
4185 Atlantic Avenue
WALL TWP, MONMOUTH COUNTY

Be advised that the Act states: "The owner of a life hazard use or high-rise structure shall pay the annual fee within 30 days of the day on which it is demanded by the department or the local enforcing agency. " Having failed to comply, a PENALTY has been assessed pursuant to N.J.A.C. 5:70-2.12 which states; "Failure to pay the required annual registration fee after having been ordered to do so – an amount equal to the unpaid registration fee for each registration may be assessed." Payment of the fee and/or judgment after imposition of the penalty shall not absolve the owner from responsibility for the penalty nor shall payment of the penalty be deemed to absolve the owner from the obligation to pay the fee. If you believe that the content of the billing information is incorrect, you may provide documentation supporting a bill modification; however, providing such documentation does not alleviate your obligation to pay the remaining balance of the Order within the stated timeframe.

Payment Information: Payments may be made online at the Division of Fire Safety's website (<http://www.nj.gov/dca/divisions/dfs/>) under the **DCA Service Portal link**. All payments made by mail should include check and stub. The stub should clearly indicate the payment amount. If you have any questions or concerns regarding this bill, please call (609) 633-6132 before the due date.

Correspondence: All correspondence regarding this bill should be emailed to bfcecodeadmin@dca.nj.gov or mailed to the address noted before the due date. Do not mail correspondence with payment, as this will delay delivery.

Correspondence Address:
Bureau of Fire Code Enforcement
PO Box 809
Trenton, NJ 08625-0809

ID
2425583

ASSESSMENT DESCRIPTION
FIRE Inspection Violation Penalty

AMOUNT CHARGED
\$2,000.00

TOTAL INVOICE CHARGES ASSESSED	\$2,000.00
TOTAL INVOICE CHARGES PAID	\$0.00
TOTAL INVOICE BALANCE	\$2,000.00

Detach and return ONLY this portion with your check made payable to Treasurer, State of New Jersey. Please write your Registration # on your check.

Invoice #: 4156325

BFCE

www.dep.nj.gov
McCann's at the Meadow

Registration #: 1352-049979.001

Payment Amount _____
Current Charge: \$2,000.00

4185 ATLANTIC AVE
07727-3713
Farmingdale, NJ 07727
United States of America

Mail payment to:
State of New Jersey
DCA BFCE - DORES
P.O. Box 663
Trenton, NJ 08646-0663B

Please pay this amount by:
12/30/2020

CAF90004156325001352049979001400002000003

ADMINISTRATIVE APPEAL RIGHTS:

The owner of the premises or of the use, or an authorized agent of the owner MAY CONTEST THIS ORDER at an Administrative Hearing. The request for a hearing must be made in writing within 15 days (24 hours for imminent hazards) after receipt of this order. Request may be made online at the Division of Fire Safety's website <https://www.nj.gov/dca/divisions/dfs> under the DCA Service Portal link or addressed to:

Department of Community Affairs
Hearing Coordinator
P0 Box 809
Trenton, New Jersey 08625-0809

In accordance with N.J.A.C. 5:70-2.19 an appeal shall be signed by a proper party and shall include:

- a) The date of the act, which is the subject of the appeal.
- b) The name and status of the person submitting the appeal.
- c) The specific violations of other act claimed to be in error; and
- d) A concise statement of the basis for the appeal

You are advised that only matters deemed to be CONTESTED CASES, as defined by the Administrative Procedures Act, will be scheduled for a Hearing. If a hearing is scheduled, you will be notified in advance of the time and place. At a hearing a corporation may be represented only by a licensed attorney, unless approval is given by the Office of Administrative Law. If you elect to submit an appeal online, you will be asked to supply your **Registration Number**, which is **1352-049979.001** and **Invoice Number**, which is **4156325**. Please enter these fields when requesting your appeal.



State of New Jersey
Department of Community Affairs
Bureau of Fire Code Enforcement
101 South Broad St, P.O. BOX 809
Trenton, NJ 08625-0809

www.dep.nj.gov
McCann's at the Meadow

4185 ATLANTIC AVE
07727-3713
Farmingdale, NJ 07727
United States of America

Type: FIRE Inspection Violation Penalty
Issue Date: 11/30/2020
Invoice#: 4156326
Invoice Year: 2020
Due Date: 12/30/2020

General Information:

Pursuant to Section 10 of the Uniform Fire Safety Act (N.J.S.A. 52:27D-201) you are in violation for failure to pay annual your Life Hazard Use registration fee. Therefore, you are hereby ORDERED to pay annual Life Hazard Use registration fee(s) AND fee penalty pursuant to N.J.A.C. 5:70-2.12 in the amount of \$1,000.00 within 30 days of receipt of this Order.

BUSINESS ADDRESS:
McCann's at the Meadow
4185 Atlantic Avenue
WALL TWP, MONMOUTH COUNTY

Be advised that the Act states: "The owner of a life hazard use or high-rise structure shall pay the annual fee within 30 days of the day on which it is demanded by the department or the local enforcing agency. " Having failed to comply, a PENALTY has been assessed pursuant to N.J.A.C. 5:70-2.12 which states; "Failure to pay the required annual registration fee after having been ordered to do so – an amount equal to the unpaid registration fee for each registration may be assessed." Payment of the fee and/or judgment after imposition of the penalty shall not absolve the owner from responsibility for the penalty nor shall payment of the penalty be deemed to absolve the owner from the obligation to pay the fee. If you believe that the content of the billing information is incorrect, you may provide documentation supporting a bill modification; however, providing such documentation does not alleviate your obligation to pay the remaining balance of the Order within the stated timeframe.

Payment Information: Payments may be made online at the Division of Fire Safety's website (<http://www.nj.gov/dca/divisions/dfs/>) under the **DCA Service Portal link**. All payments made by mail should include check and stub. The stub should clearly indicate the payment amount. If you have any questions or concerns regarding this bill, please call (609) 633-6132 before the due date.

Correspondence: All correspondence regarding this bill should be emailed to bfcecodeadmin@dca.nj.gov or mailed to the address noted before the due date. Do not mail correspondence with payment, as this will delay delivery.

Correspondence Address:
Bureau of Fire Code Enforcement
PO Box 809
Trenton, NJ 08625-0809

ID
2429339

ASSESSMENT DESCRIPTION
FIRE Inspection Violation Penalty

AMOUNT CHARGED
\$1,000.00

TOTAL INVOICE CHARGES ASSESSED	\$1,000.00
TOTAL INVOICE CHARGES PAID	\$0.00
TOTAL INVOICE BALANCE	\$1,000.00

Detach and return ONLY this portion with your check made payable to Treasurer, State of New Jersey. Please write your Registration # on your check.

Invoice #: 4156326

BFCE

www.dep.nj.gov
McCann's at the Meadow

Registration #: 1352-049979.001

Payment Amount _____
Current Charge: \$1,000.00

4185 ATLANTIC AVE
07727-3713
Farmingdale, NJ 07727
United States of America

Mail payment to:
State of New Jersey
DCA BFCE - DORES
P.O. Box 663
Trenton, NJ 08646-0663B

Please pay this amount by:
12/30/2020

CAF90004156326001352049979001400001000003

ADMINISTRATIVE APPEAL RIGHTS:

The owner of the premises or of the use, or an authorized agent of the owner MAY CONTEST THIS ORDER at an Administrative Hearing. The request for a hearing must be made in writing within 15 days (24 hours for imminent hazards) after receipt of this order. Request may be made online at the Division of Fire Safety's website <https://www.nj.gov/dca/divisions/dfs> under the DCA Service Portal link or addressed to:

Department of Community Affairs
Hearing Coordinator
P0 Box 809
Trenton, New Jersey 08625-0809

In accordance with N.J.A.C. 5:70-2.19 an appeal shall be signed by a proper party and shall include:

- a) The date of the act, which is the subject of the appeal.
- b) The name and status of the person submitting the appeal.
- c) The specific violations of other act claimed to be in error; and
- d) A concise statement of the basis for the appeal

You are advised that only matters deemed to be CONTESTED CASES, as defined by the Administrative Procedures Act, will be scheduled for a Hearing. If a hearing is scheduled, you will be notified in advance of the time and place. At a hearing a corporation may be represented only by a licensed attorney, unless approval is given by the Office of Administrative Law. If you elect to submit an appeal online, you will be asked to supply your **Registration Number**, which is **1352-049979.001** and **Invoice Number**, which is **4156326**. Please enter these fields when requesting your appeal.



STATE OF NEW JERSEY
DEPARTMENT OF COMMUNITY AFFAIRS
BUREAU OF FIRE CODE ENFORCEMENT
101 S BROAD ST, PO BOX 809
TRENTON NJ 08625-0809

McCann's at the Meadow

Type: FIRE Permit Fee
10/12/2021
Issue Date: 2573690
Bill #: 10/15/2021
Due Date:

Registration #: 1352-049979.001

REGISTRATION NUMBER	USE CODE	ASSESSMENT DESCRIPTION	FEE	AMOUNT CHARGED
				\$54.00
TOTAL INVOICE CHARGES ASSESSED				\$54.00
TOTAL INVOICE CHARGES PAID				\$0.00
TOTAL INVOICE BALANCE				\$54.00

Payments may be made online at the Divisions of Fire Safety's website - <https://nj.gov/dca/divisions/dfs/> under the DCA Service Portal link.
Pay the amount indicated and mail invoice stub below with your check made payable to Treasurer, State of New Jersey
Do not mail correspondence with payment as this will delay delivery and a response.

Cut along line and return this portion with your check made payable to Treasurer, State of
New Jersey. Please write your Registration number on your check. See EFT Notice.

BFCE

McCann's at the Meadow
4185 Atlantic Avenue
WALL TWP
07727

Bill #: 2573690
Reg #: 1352-049979.001
Mail Payment to:
State of New Jersey
DCA BFCE -- DORES
P.O. Box 663
Trenton, NJ 08646-0663

Issue Date: 10/12/2021
Amount Due: \$54.00
Please pay this amount by:
10/15/2021



State of New Jersey
Department of Community Affairs
Bureau of Fire Code Enforcement
101 South Broad St, P.O. BOX 809
Trenton, NJ 08625-0809

www.dep.nj.gov
McCann's at the Meadow

4185 ATLANTIC AVE
07727-3713
Farmingdale, NJ 07727
United States of America

Type: FIRE Inspection Violation Penalty
Issue Date: 1/4/2023
Invoice#: 4161700
Invoice Year: 2023
Due Date: 2/3/2023

General Information:

Pursuant to Section 10 of the Uniform Fire Safety Act (N.J.S.A. 52:27D-201) you are in violation for failure to pay annual your Life Hazard Use registration fee. Therefore, you are hereby ORDERED to pay annual Life Hazard Use registration fee(s) AND fee penalty pursuant to N.J.A.C. 5:70-2.12 in the amount of \$1,500.00 within 30 days of receipt of this Order.

BUSINESS ADDRESS:
McCann's at the Meadow
4185 Atlantic Avenue
WALL TWP, MONMOUTH COUNTY

Be advised that the Act states: "The owner of a life hazard use or high-rise structure shall pay the annual fee within 30 days of the day on which it is demanded by the department or the local enforcing agency. " Having failed to comply, a PENALTY has been assessed pursuant to N.J.A.C. 5:70-2.12 which states; "Failure to pay the required annual registration fee after having been ordered to do so – an amount equal to the unpaid registration fee for each registration may be assessed." Payment of the fee and/or judgment after imposition of the penalty shall not absolve the owner from responsibility for the penalty nor shall payment of the penalty be deemed to absolve the owner from the obligation to pay the fee. If you believe that the content of the billing information is incorrect, you may provide documentation supporting a bill modification; however, providing such documentation does not alleviate your obligation to pay the remaining balance of the Order within the stated timeframe.

Payment Information: Payments may be made online at the Division of Fire Safety's website (<http://www.nj.gov/dca/divisions/dfs/>) under the **DCA Service Portal link**. All payments made by mail should include check and stub. The stub should clearly indicate the payment amount. If you have any questions or concerns regarding this bill, please call (609) 633-6132 before the due date.

Correspondence: All correspondence regarding this bill should be emailed to bfcecodeadmin@dca.nj.gov or mailed to the address noted before the due date. Do not mail correspondence with payment, as this will delay delivery.

Correspondence Address:
Bureau of Fire Code Enforcement
PO Box 809
Trenton, NJ 08625-0809

ID
2528873

ASSESSMENT DESCRIPTION
FIRE Inspection Violation Penalty

AMOUNT CHARGED
\$1,500.00

TOTAL INVOICE CHARGES ASSESSED	\$1,500.00
TOTAL INVOICE CHARGES PAID	\$0.00
TOTAL INVOICE BALANCE	\$1,500.00

Detach and return ONLY this portion with your check made payable to Treasurer, State of New Jersey. Please write your Registration # on your check.

Invoice #: 4161700

BFCE

www.dep.nj.gov
McCann's at the Meadow

Registration #: 1352-049979.001

Payment Amount _____
Current Charge: \$1,500.00

4185 ATLANTIC AVE
07727-3713
Farmingdale, NJ 07727
United States of America

Mail payment to:
State of New Jersey
DCA BFCE - DORES
P.O. Box 663
Trenton, NJ 08646-0663B

Please pay this amount by:
2/3/2023

CAF90004161700001352049979001400001500004

ADMINISTRATIVE APPEAL RIGHTS:

The owner of the premises or of the use, or an authorized agent of the owner MAY CONTEST THIS ORDER at an Administrative Hearing. The request for a hearing must be made in writing within 15 days (24 hours for imminent hazards) after receipt of this order. Request may be made online at the Division of Fire Safety's website <https://www.nj.gov/dca/divisions/dfs> under the DCA Service Portal link or addressed to:

Department of Community Affairs
Hearing Coordinator
P0 Box 809
Trenton, New Jersey 08625-0809

In accordance with N.J.A.C. 5:70-2.19 an appeal shall be signed by a proper party and shall include:

- a) The date of the act, which is the subject of the appeal.
- b) The name and status of the person submitting the appeal.
- c) The specific violations of other act claimed to be in error; and
- d) A concise statement of the basis for the appeal

You are advised that only matters deemed to be CONTESTED CASES, as defined by the Administrative Procedures Act, will be scheduled for a Hearing. If a hearing is scheduled, you will be notified in advance of the time and place. At a hearing a corporation may be represented only by a licensed attorney, unless approval is given by the Office of Administrative Law. If you elect to submit an appeal online, you will be asked to supply your **Registration Number**, which is **1352-049979.001** and **Invoice Number**, which is **4161700**. Please enter these fields when requesting your appeal.

2022

☒ System is Compliant with NJAC 5:70-3

☐ System is Non-Compliant

THIS FORM WILL BE FILED WITH THE LOCAL AHJ



Jersey Coast Fire Equipment
377 Asbury Road
Farmingdale, N.J. 07727
(732)938-2020

NJ CERT# P00206

KITCHEN SYSTEM REPORT - PAGE 1

WORK ORDER NO.	DATE	HAZARD AREA PROTECTED	
	9/13/2022	Main Kitchen Hood	
SYSTEM INFO.	SYSTEM CAPACITY	SYSTEM TYPE	NUM of CYLS
Protex	L4600	Wet	1

COMPANY	CONTACT		
MCCANN'S AT THE MEADOWS	BILLY EPP		
ADDRESS	CITY	STATE	ZIP
4185 ATLANTIC AVENUE	WALL	NJ	07719
AHJ / FIRE PROTECTION DISTRICT	CUSTOMER NUMBER		
WALL			
	INSPECTION TYPE		
	Semi Annual		

Initial Actions / Observations		System Functional Test	
	Y N N/A		Y N N/A
1 Last Serviced By?	Jersey Coast Fire equipment	21 System disarmed per manufacturer's recommendations?	Yes
2 Were building personnel notified of the inspection?	Yes	22 Mechanical detection line tested and found to operate properly?	Yes
3 Was the monitoring company notified?	Yes	23 Proper number and placement of detectors/links?	Yes
4 System found charged and functioning at time of technician's arrival?	Yes	24 Did the system operate properly from activation of a manual pull station?	Yes
5 System un-tampered with since last visit?	Yes	25 Gas shut-off valve installed and working properly?	Location: Behind stove
6 System found to be at proper pressure upon arrival?	Yes	26 Replaced links with proper temperature rating?	Yes
Visually Check System		_____ at 165 Degrees _____ at 360 Degrees	
7 Baffle-type filters installed in hood?	Yes	_____ at 212 Degrees <u>5</u> at 450 Degrees	
8 System (and appliance layout) appear unchanged since last service?	Yes	_____ at 280 Degrees _____ at 500 Degrees	
9 Were the nozzle caps in place at time of arrival?	Yes	27 Is the manual reset for electric gas valves operational?	Yes
10 Visible piping and nozzles properly connected, braced, and free of damage?	Yes	28 Did all electrical appliances shut off upon system operation?	Yes
11 Piping/conduit/cabling free from observable obstructions?	Yes	29 Did all gas appliances shut off upon system operation?	Yes
12 Nozzle(s) inspected and found to be clear of obstructions?	Yes	30 Did the make-up air shut down?	Yes
13 Correct nozzle type(s) for protected equipment, plenum and ducts?	Yes	31 Did the alarm system activate when the system tripped?	Yes
14 Nozzle(s) properly positioned over appliances?	Yes	32 Did control head(s)/cylinder releasing device(s) operate properly?	Yes
15 Nozzle(s) properly positioned in duct(s) and plenum(s)?	Yes	33 Was a pipe intergrity test performed per the mfg requirements?	
16 Is there a fan warning sign on hood?	Yes	Cylinders and Agent	
17 Flow points/extinguishing agent within mfg's allowed maximums?	Yes	34 Cylinder Pressure <u>Full</u> psi	Yes
Hazard Inspection		35 Hydrostatic test date of cylinder checked. Due: <u>2029</u>	Yes
18 Hazard configuration appeared to remained unchanged?	Yes	36 Were all cylinders free of signs of external corrosion and/or damage?	Yes
19 Are all observable penetrations to the hood and duct sealed?	Yes	37 Are all cylinders securely mounted?	Yes
20 No readily observable obstructions or interference that could impact effectiveness of the suppression system?	Yes	38 Cartridge inspected or replaced within mfg's recommended interval (if applicable)? Weight <u>58.9pm</u>	Yes

NOTIFICATION OF DEFICIENCIES

CUSTOMER INITIALS: _____

☐ A mark made in the adjacent box indicates that deficiencies exist with the current condition of the Fire Suppression System. If this is the case, the customer's authorized representative, by his or her signature and initials acknowledges these deficiencies represent an IMMEDIATE AND SERIOUS SAFETY CONCERN that the customer must correct. Service Company shall not be responsible if the Fire Suppression System malfunctions or fails to function. It is the owner's responsibility to ensure that all deficiencies are removed or repaired.



377 ASBURY ROAD
FARMINGDALE, N.J. 07727
732-938-2020
N.J. LIC. # P00206

JOB SITE EQUIPMENT PHOTOS

DATE: 9/13/2022		TECHNICIAN: MIKE LEMORE	
CUSTOMER: MCCANN'S AT THE MEADOWS		PHONE: [REDACTED]	
ADDRESS: 4185 ATLANTIC AVENUE		CITY: WALL	
EMAIL: [REDACTED]		CONTACT: BILLY EPP	

EQUIPMENT TYPE: KITCHEN SYSTEM

HOOD SIZE: 13'6"x4'	DUCT QUANTITY & SIZE: 2@18"x5"
---------------------	--------------------------------



EQUIPMENT LINE UP & SIZE LOOKING AT HOOD FROM LEFT TO RIGHT:

GRILL AND TWO BEEP FRYER AND 6 Bruner stove and oven and flattop
--

1. System Connected to Alarm? YES	4. Gas Valve: YES SIZE: 3 in
2. Nozzle Count: Duct: 2 Plenum: 2 Appliance: 1	5. Gas Valve Style: MECHANICAL
3. PCU UNIT: N/A	
4. Remote Pull: YES Location: Next to rest room	6. Gas Valve Location: Behind stove and oven PULL TYPE

Roberts Electronics & Security, Inc.

FA License# 34FA00068400

919 Highway 33 Suite #36
Freehold, NJ 07728-8454
Monmouth: (732) 431-1330
Ocean: (732) 929-0707

6184KR

FIRE ALARM INSPECTION & TESTING REPORT

PREMISES NAME: McCANN'S AT THE MEADOW	DATE: 9/15/22
PREMISES ADDRESS: 4185 Atlantic Ave	SERVICEMAN Mike
PREMISES ADDRESS: Farmingdale	SIGNATURE MJC
PREMISES PHONE: NY 07727	

This inspection report is solely based on the testing and inspection of the specific fire protection components as noted on this report. This report in no way constitutes a fire protection engineering or loss prevention survey and does not address the level of protection provided by the system, the acceptability of the equipment installed, or the overall design, engineering or fire code compatibility or acceptability of the system(s) and all related components.

This inspection and certification is strictly limited to those items specifically tested and the results of the tests noted at the time of the actual inspection.

CERTIFICATION

The results of this inspection indicate that the systems at the time of inspection were:

☒ Found to be in operational condition.

☐ In need of repairs to place the system in operational condition.

TYPE OF TRANSMISSION	INSPECTION / SERVICE	ALARM TRANSMISSION
<input type="checkbox"/> McCulloh	<input type="checkbox"/> Weekly	CENTRAL STATION: SECURALL
<input type="checkbox"/> Digital	<input type="checkbox"/> Monthly	PHONE NO.: [REDACTED]
<input type="checkbox"/> Multiplex	<input type="checkbox"/> Quarterly	
<input type="checkbox"/> Direct Connect	<input type="checkbox"/> Semi-Annually	<input type="checkbox"/> POLICE DEPT
<input type="checkbox"/> Long Range Radio (R/F)	<input checked="" type="checkbox"/> Annually	<input type="checkbox"/> FIRE DEPT
<input checked="" type="checkbox"/> Other (specify) LTE Cellular	<input type="checkbox"/> Other (specify) _____	OTHER:
PANEL MANUFACTURE: Simplex	MODEL NO.: B	
CIRCUIT STYLE: R	NO. OF CIRCUITS (ZONES): 10	
LAST DATE SYSTEM HAD SERVICE PERFORMED: / /		
LAST DATE THAT ANY SOFTWARE OR CONFIGURATION WAS REVISED: / /		
SIGNALING LINE CIRCUITS: QUANTITY 6 STYLE(S) B		
PRIMARY POWER SOURCE: <input checked="" type="checkbox"/> 110 VAC SINGLE PHASE <input type="checkbox"/> 220 VAC DOUBLE PHASE		
SECONDARY POWER SOURCE: <input type="checkbox"/> STANDBY GENERATOR <input checked="" type="checkbox"/> BATTERY		
IF SYSTEM IS EQUIPPED WITH A REMOTE ANNUNCIATOR, DO ALL INDIVIDUAL INDICATORS ILLUMINATE YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A		
ANNUNCIATOR LOCATION		
ANNUNCIATOR MANUFACTURE: MODEL NO:		

USER CONTROL FUNCTION TEST					PANEL VISUAL INDICATOR TEST				
		GOOD	N/A	INOP			GOOD	N/A	INOP
1	RESET	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1	AC POWER	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	TROUBLE SILENCE	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2	SYSTEM TROUBLE	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	CITY DISCONNECT	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	3	ZONE TROUBLES	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	ALARM SILENCE	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4	ZONE ALARMS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	LAMPS/LED'S	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5	GROUND FAULT	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	FUSES	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	6	CITY DISCONNECT	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

SECONDARY POWER SOURCE:

BATTERY TEST:	TOTAL-	2	VOLTS-	12	AMP HOUR RATING-	7	BATTERY TYPE-	Gell	-	SLA
CHARGER OUTPUT VOLTAGE-	VDC									
OPEN BATTERY VOLTAGE-	VDC									
BATTERY OPERATION UNDER PRIMARY POWER INTERRUPTION:										
BATTERY VOLTAGE	VDC (5 MINUTES)									
BATTERY VOLTAGE IN ALARM	VDC (5 MINUTES)									
DID RESULTS APPEAR SATISFACTORY	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO									
Passed A/H Testtesting YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>										

ALARM INITIATING DEVICES AND CIRCUIT INFORMATION

	QUANTITY OF	CIRCUIT STYLE
BELLS		
HORNS		
HORN/STROBE	4	B
STROBES	2	B
CHIMES		
SPEAKERS		
OTHER (SPECIFY)		

ALARM INITIATING DEVICES AND CIRCUIT INFORMATION

	QUANTITY OF	CIRCUIT STYLE
PHOTO SMOKE DETECTORS	11	B
ION SMOKE DETECTORS		
DUCT SMOKE DETECTORS	2	B
HEAT DETECTORS	7	B
MANUAL PULL STATIONS	4	B
BEAM TYPE SMOKE DETECTORS		
WATERFLOW SWITCHES (GATE)	1	B
SUPERVISORY SWITCHES (AIR)	1	B
AREA LOW TEMP.		
OTHER (SPECIFY) DSCY Temp	1	B

DEFECTS NOTED	REPAIRS/CORRECTED
1	
2	
3	
4	
5	
6	
7	
8	

McCann's AT THE MEADOW

2020

☒ System is Compliant with NJAC 5:70-3

☐ System is Non-Compliant

THIS FORM WILL BE FILED WITH THE LOCAL AHJ



Jersey Coast Fire Equipment
377 Asbury Road
Farmingdale, N.J. 07727
(732)938-2020

NJ CERT# P00206

KITCHEN SYSTEM REPORT - PAGE 1

WORK ORDER NUM.	DATE	HAZARD AREA PROTECTED	
	3/12/2020	Main Kitchen Hood	
SYSTEM INFO.	SYSTEM CAPACITY	SYSTEM TYPE	NUM of CYLS
Protex	L4600	Wet	1
PHONE		FAX	
[REDACTED]		[REDACTED]	
STATE	ZIP	CUSTOMER NUMBER	
NJ	07719	[REDACTED]	

COMPANY	CONTACT
BIRDIE'S & BOGIES, LLC	LOU
ADDRESS	CITY
4185 ATLANTIC AVENUE	WALL
AHJ / FIRE PROTECTION DISTRICT	INSPECTION TYPE
WALL	Semi Annual

Initial Actions / Observations	Y	N	N/A	System Functional Test	Y	N	N/A
--------------------------------	---	---	-----	------------------------	---	---	-----

1 Last Serviced By?				Jersey coast Fire			
2 Were building personnel notified of the inspection?	Yes			21 System disarmed per manufacturer's recommendations?	Yes		
3 Was the monitoring company notified?	No			22 Mechanical detection line tested and found to operate properly?	Yes		
4 System found charged and functioning at time of technician's arrival?	Yes			23 Proper number and placement of detectors/links?	Yes		
5 System un-tampered with since last visit?	Yes			24 Did the system operate properly from activation of a manual pull station?	Yes		
6 System found to be at proper pressure upon arrival?	Yes			25 Gas shut-off valve installed and working properly?	Yes		

Visually Check System	Y	N	N/A	_____ at 165 Degrees	_____ at 360 Degrees
7 Baffle-type filters installed in hood?	Yes			_____ at 212 Degrees	5 at 450 Degrees
8 System [and appliance layout] appear unchanged since last service?	Yes			_____ at 280 Degrees	_____ at 500 Degrees
9 Were the nozzle caps in place at time of arrival?	Yes			27 Is the manual reset for electric gas valves operational?	Yes
10 Visible piping and nozzles properly connected, braced, and free of damage?	Yes			28 Did all electrical appliances shut off upon system operation?	Yes
11 Piping/conduit/cabling free from observable obstructions?	Yes			29 Did all gas appliances shut off upon system operation?	Yes
12 Nozzle(s) inspected and found to be clear of obstructions?	Yes			30 Did the make-up air shut down?	Yes
13 Correct nozzle type(s) for protected equipment, plenum and ducts?	Yes			31 Did the alarm system activate when the system tripped?	
14 Nozzle(s) properly positioned over appliances?	Yes			32 Did control head(s)/cylinder releasing device(s) operate properly?	Yes
15 Nozzle(s) properly positioned in duct(s) and plenum(s)?	Yes			33 Was a pipe intergrity test performed per the mfg requirements?	
16 Is there a fan warning sign on hood?	Yes				
17 Flow points/extinguishing agent within mfg's allowed maximums?	Yes				

Hazard Inspection	Y	N	N/A	Cylinders and Agent	Y	N	N/A
18 Hazard configuration appeared to remained unchanged?	Yes			34 Cylinder Pressure 225 psi	Yes		
19 Are all observable penetrations to the hood and duct sealed?	Yes			35 Hydrostatic test date of cylinder checked. Due: 2029	Yes		
20 No readily observable obstructions or interference that could impact effectiveness of the suppression system?	Yes			36 Were all cylinders free of signs of external corrosion and/or damage?	Yes		
				37 Are all cylinders securely mounted?	Yes		
				38 Cartridge inspected or replaced within mfg's recommended interval (if applicable)? Weight 58 grams	Yes		

NOTIFICATION OF DEFICIENCIES

CUSTOMER INITIALS: _____

☐ A mark made in the adjacent box indicates that deficiencies exist with the current condition of the Fire Suppression System. If this is the case, the customer's authorized representative, by his or her signature and initials acknowledges these deficiencies represent an IMMEDIATE AND SERIOUS SAFETY CONCERN that the customer must correct. Service Company shall not be responsible if the Fire Suppression System malfunctions or fails to function. It is the owner's responsibility to ensure that all deficiencies are removed or repaired.



377 ASBURY ROAD
FARMINGDALE, N.J. 07727
732-938-2020
N.J. LIC. # P00206

JOB SITE EQUIPMENT PHOTOS

DATE: 3/12/2020		TECHNICIAN: TOM TURI	
CUSTOMER: BIRDIE'S & BOGIES, LLC		PHONE: [REDACTED]	
ADDRESS: 4185 ATLANTIC AVENUE		CITY: WALL	
EMAIL: [REDACTED]		CONTACT: LOU	
EQUIPMENT TYPE: KITCHEN SYSTEM			
HOOD SIZE: 13'6"		DUCT QUANTITY & SIZE: 2@18"X5"	



EQUIPMENT LINE UP & SIZE LOOKING AT HOOD FROM LEFT TO RIGHT:

Grill fryer 10 burner salamander

1. System Connected to Alarm? YES		4. Gas Valve: YES SIZE: 2"	
2. Nozzle Count: Duct: 2 Plenum: 2 Appliance: 5		5. Gas Valve Style: MECHANICAL	
3. PCU UNIT: N/A			
4. Remote Pull: YES Location: By bathroom near main floor door		6. Gas Valve Location: Behind stove toward floor PULL TYPE	

Jersey Coast Fire Equipment
377 Asbury Road
Farmingdale, NJ 07727
Phone: (732) 938-2020

Inspection Report
3/12/2020

Service Information

BIRDIE'S & BOGIES, LLC
4185 ATLANTIC AVENUE
INSIDE SPRING MEADOW
WALL, NJ 07719
Contact: LOU
Phone: [REDACTED]
E-mail: [REDACTED]

Job Name

KITCHEN SYSTEM INSPECTION

Job Type	PO #	Invoice #	Scheduled	Start	End
KITCHEN SYSTEM INSPECTION			03/12/2020	10:00 AM	11:00 AM

Item	Description	Quantity
L4600-SYSI	PROTEX L4600 SUPPRESSION SYSTEM INSPECTION	1.0000
FLK450	FUSIBLE LINK 450 DEGREES	5.0000
INSP	INSPECTION, SERVICE & TAG FIRE EXTINGUISHER	4.0000
NJFF	New Jersey State Mandatory Report Filing Fee	1.0000

KITCHEN SYSTEM INSPECTION Inspection Report (continued)

Job Notes and Instructions:

PROTEX L4600

HYDROTEST DATE:2017

HOOD SIZE:13'6"X 4'

DUCT SIZE:2@18"X5"

ALARM IS:CONNECTED

ALARM COMPANY

PLENUM NOZZLE:02

DUCT NOZZLE:02

CHARGRILLE NOZZLE:01

FRYER NOZZLE:01

10BURNER NOZZLE:03

SALAMANDER NOZZLE:01

FUSIBLE LINKS:5@450

**** OWNER INFORMED HE MUST REMOVE SALAMANDER BEFORE SYSTEM IS COMPLIANT*****

**** NO ONE FROM ENTIRE GOLF COURSE HAS ANY INFORMATION FOR ALARM*****

CLASS K. KITCHEN A-2017

CLASS K. KITCHEN. A-2017

10ABC. DINNING AREA BY BATHROOMS. FA-2015

10ABC. 2ND FL OFFICE A-2019

System inspection.	\$125.00
5 fusible links.	\$49.75
NJFF filing form.	\$7.50
4 ext. inspect.	\$23.50
Subtotal.	\$199.50
Tax.	\$13.10
Total.	\$218.35

TOM TURI - TOM TURI - Mar 12, 2020 10:52 AM

ALL APPLIANCES PROPERLY COVERED W/CORRECT NOZZLES?: YES
CHECK FOR CORRECT DUCT & PLENUM NOZZLES?: YES
HOOD / DUCT SEALED WITH UL LISTED DEVICE OR WELD?: YES
PROPER SEPARATION FROM FLAME & FRYERS?: YES
TANK HAS PROPER PRESSURE ON GAUGE?: YES
REPLACED FUSIBLE LINKS?: YES
TEST FOR PROPER OPERATION OF PULL STATION?: YES
CHECK FOR PROPER OPERATION OF GAS VALVE?: YES
DID YOU RESET GAS VALVE AND LIGHT APPLIANCES?: YES
DID YOU RESET SYSTEM AND RETAG & SEAL THE SAME?: YES
DID YOU SERVICE THE FIRE EXTINGUISHER?: YES
IS THE FIRE SUPPRESSION SYSTEM COMPLIANT?: YES

TOM TURI - TOM TURI - Mar 12, 2020 11:15 AM

ARE ALL EXTINGUISHERS PROPERLY HUNG?: YES
ARE ALL EXTINGUISHERS RETAGGED, SEALED & CLEANED?: YES -
DID YOU LEAVE LOANERS?: NO -

*JERSEY COAST FIRE NOW OFFERS SPRINKLER INSPECTIONS AND ALARM MONITORING AND INSPECTIONS. WE ARE YOUR "ONE STOP SHOP" IN FIRE PROTECTION! CALL US TODAY FOR INFORMATION.

*ALL INSPECTION REPORTS WILL BE AUTOMATICALLY E-MAILED TO YOUR TOWNSHIP FIRE OFFICIAL. THERE IS A \$7.50 FILING FEE ADDED TO YOUR INVOICE.

Signature: x



George

2019

☒ System is Compliant with NJAC 5:70-3

☐ System is Non-Compliant

THIS FORM WILL BE FILED WITH THE LOCAL AHJ



Jersey Coast Fire Equipment
377 Asbury Road
Farmingdale, N.J. 07727
(732)938-2020

NJ CERT# P00206

KITCHEN SYSTEM REPORT - PAGE 1

WORK ORDER NUM.	DATE	HAZARD AREA PROTECTED	
	8/9/2019	Main Kitchen Hood	
SYSTEM MFG.	SYSTEM CAPACITY	SYSTEM TYPE	NUM of CYLS
Protex	L4600	Wet	1

COMPANY	CONTACT	PHONE	FAX
BIRDIE'S & BOGIES, LLC	LOU	[REDACTED]	
ADDRESS	CITY	STATE	ZIP
4185 ATLANTIC AVENUE	WALL	NJ	07719
HAJ FIRE PROTECTION DISTRICT	INSPECTION TYPE	CUSTOMER NUMBER	
WALL	Semi Annual		

Initial Actions / Observations		System Functional Test	
Y	N/A	Y	N/A
1 Last Serviced By? <u>Dragon Fire</u>		21 System disarmed per manufacturer's recommendations?	Yes
2 Were building personnel notified of the inspection?	Yes	22 Mechanical detection line tested and found to operate properly?	Yes
3 Was the monitoring company notified?	Yes	23 Proper number and placement of detectors/links?	Yes
4 System found charged and functioning at time of technician's arrival?	Yes	24 Did the system operate properly from activation of a manual pull station?	Yes
5 System un-tampered with since last visit?	Yes	25 Gas shut-off valve installed and working properly? ^{Location} Right side of	Yes
6 System found to be at proper pressure upon arrival?	Yes	26 Replaced links with proper temperature rating?	Yes
Visually Check System		_____ at 165 Degrees _____ at 360 Degrees	
7 Baffle-type filters installed in hood?	Yes	_____ at 212 Degrees <u>5</u> at 450 Degrees	
8 System (and appliance layout) appear unchanged since last service?	Yes	_____ at 280 Degrees _____ at 500 Degrees	
9 Were the nozzle caps in place at time of arrival?	Yes	27 Is the manual reset for electric gas valves operational?	N/A
10 Visible piping and nozzles properly connected, braced, and free of damage?	Yes	28 Did all electrical appliances shut off upon system operation?	Yes
11 Piping/conduit/cabling free from observable obstructions?	Yes	29 Did all gas appliances shut off upon system operation?	Yes
12 Nozzle(s) inspected and found to be clear of obstructions?	Yes	30 Did the make-up air shut down?	Yes
13 Correct nozzle type(s) for protected equipment, plenum and ducts?	Yes	31 Did the alarm system activate when the system tripped?	Yes
14 Nozzle(s) properly positioned over appliances?	Yes	32 Did control head(s)/cylinder releasing device(s) operate properly?	Yes
15 Nozzle(s) properly positioned in duct(s) and plenum(s)?	Yes	33 Was a pipe intergrity test performed per the mfg requirements?	
16 Is there a fan warning sign on hood?	Yes	Cylinders and Agent	
17 Flow points/extinguishing agent within mfg's allowed maximums?	Yes	34 Cylinder Pressure <u>225</u> psi	Yes
Hazard Inspection		35 Hydrostatic test date of cylinder checked. Due: <u>2029</u>	Yes
18 Hazard configuration appeared to remained unchanged?	Yes	36 Were all cylinders free of signs of external corrosion and/or damage?	Yes
19 Are all observable penetrations to the hood and duct sealed?	Yes	37 Are all cylinders securely mounted?	Yes
20 No readily observable obstructions or interference that could impact effectiveness of the suppression system?	Yes	38 Cartridge inspected or replaced within mfg's recommended interval (if applicable)? Weight <u>58.7 grams</u>	Yes

NOTIFICATION OF DEFICIENCIES

CUSTOMER INITIALS: _____

☐ A mark made in the adjacent box indicates that deficiencies exist with the current condition of the Fire Suppression System. If this is the case, the customer's authorized representative, by his or her signature and initials acknowledges these deficiencies represent an IMMEDIATE AND SERIOUS SAFETY CONCERN that the customer must correct. Service Company shall not be responsible if the Fire Suppression System malfunctions or fails to function. It is the owner's responsibility to ensure that all deficiencies are removed or repaired.

KITCHEN SYSTEM REPORT - PAGE 2

COMPANY BIRDIE'S & BOGIES, LLC		CONTACT LOU		PHONE [REDACTED]		FAX	
ADDRESS 4185 ATLANTIC AVENUE		CITY WALL		STATE NJ	ZIP 07719	CUSTOMER/INSPECTOR	
System Read/Valve				Y II IUA Final		Y II IUA	
39	Test adapters/wks, keeper pins, etc., removed from system?	Yes		49	Operator's manual on site?	Yes	
40	Detection (link) line has proper tensioning?	Yes		50	Class K portable extinguisher available and properly serviced?	Yes	
41	Was the control head reset?	Yes		51	Remote manual release free from obstructions & operable?	Yes	
42	Were all fuel sources and power restored?	Yes		52	Has the system been placed back in service?	Yes	
43	Were all pilot lights supplied by the gas valve reset?	Yes		53	Monitoring company notified that the system is back in full service?	Yes	
44	Microswitch/relay(s) reset -- electric appliances "on"?	Yes		54	Were building personnel notified of the system condition?	Yes	
45	Are all nozzle caps in place?	Yes		55	Have you received a signature from the building personnel?	Yes	
46	Were all filters reinstalled?	Yes		56	Inspection tag affixed to system?	Yes	
47	Were all cartridges reinstalled? (if applicable)	Yes					
48	Tandem/slave releasing device(s) reset properly?	N/A					
Description of Deficiencies							
IF CHECKED SEE ATTACHED DEFICIENCY REPORT FOR MORE INFORMATION							
Comments and Recommendations							
****owner has been told the salamander must be removed before system is compliant and has agreed to remove today****							
NOTIFICATION OF EXHAUST SYSTEM GREASE BUILD UP							
						Customer Initials: <u>LF</u>	
<input checked="" type="checkbox"/> A mark made in the adjacent box indicates that we recommend that the entire exhaust and ventilation control system as well as all appliances be inspected by a properly trained, qualified, and certified company or person(s) acceptable to the authority having jurisdiction to determine if cleaning is required. Any visual observations or comments noted by our Service Technician regarding grease build up are for informational purposes only and are based on readily observable conditions at the time of service.							
Authorized Customer Representative				Authorized Company Representative			
SIGNATURE: <u>L. Farese</u>				SIGNATURE: <u>[Signature]</u>			
PRINT NAME: <u>Lou Farese</u>				PRINT NAME: <u>Sean Sagan</u>			
				N.J. DFS PERMIT #: P00206			



377 ASBURY ROAD
FARMINGDALE, N.J. 07727
732-938-2020
N.J. LIC. # P00206

JOB SITE EQUIPMENT PHOTOS

DATE: 8/9/2019		TECHNICIAN: Sean Sagan	
CUSTOMER: BIRDIE'S & BOGIES, LLC		PHONE: [REDACTED]	
ADDRESS: 4185 ATLANTIC AVENUE		CITY: WALL	
EMAIL:		CONTACT: LOU	

EQUIPMENT TYPE: KITCHEN SYSTEM

HOOD SIZE: 13'6"X4'	DUCT QUANTITY & SIZE: 2@18"X5"
---------------------	--------------------------------



EQUIPMENT LINE UP & SIZE LOOKING AT HOOD FROM LEFT TO RIGHT:

Convection oven, 32" CHARGRILLE, 14" fryer, 60" 10 burner range

1. System Connected to Alarm? YES		4. Gas Valve: YES SIZE: 5"	
2. Nozzle Count: Duct: 2 Plenum: 2 Appliance: 5		5. Gas Valve Style: MECHANICAL	
3. PCU UNIT: N/A			
4. Remote Pull: YES Location: Hall by rear exit		6. Gas Valve Location: Right of hood behind stove RELEASE TYPE	



State of New Jersey
Department of Community Affairs
P. O. Box 809
Trenton, NJ 08625-0809
609-633-6132

Page 1 of 5

NOTICE OF VIOLATION AND ORDERS OF THE COMMISSIONER

Business Name:	Mc Cann's at the Meadow	Registration #:	1352049979.1	Billing Customer #:	0551087
Inspection Date:	02/28/2019	Inspection Type:	Addendum	Inspector:	DWAYNE BREEDEN
Notice #:	30059600			Issuance Date:	February 28, 2019

Business	Primary Business Owner	Primary Property Owner	On Site Contact
Mc Cann's at the Meadow 4185 ATLANTIC Avenue Wall Twp. Monmouth County Registration #: 1352049979.1	Mc Cann's at the Meadow (ALLAIRE) GOLF RESTAUR c/o Thomas McCann Customer ID: 554087 4185 ATLANTIC AVE 07727-3713 Fairfield, NJ 07727	N/A Customer ID: N/A N/A Contact Number: N/A	N/A Customer ID: N/A N/A Contact Number: N/A

Use Group	LIU Codes
Eating/Drinking	BD05

YOU ARE HEREBY NOTIFIED THAT an inspection at the above referenced property by the New Jersey Division of Fire Safety disclosed violations of the Uniform Fire Code (N.J.A.C. 5:70-1 et seq.), promulgated pursuant to the New Jersey Uniform Fire Safety Act (N.J.S.A. 52:27D-192 et seq.). The violations are specified on the accompanying "fire code violations" page(s).

YOU ARE HEREBY ORDERED by the COMMISSIONER to correct the violations listed on the accompanying "violations" page(s) within the timeframe, or by the date specified. If a reinspection discloses that violations have not been corrected, you will be subject to penalties of up to \$5,000.00 per violation per day or as otherwise authorized by the Act and Department Regulations. IN ADDITION, the ACT imposes liability on the owner for the actual costs of fire suppression where a violation directly or indirectly results in a fire.

IA Governor
Sheila Y. Oliver, Commissioner, Department of Community Affairs

Louis B. Kilmer
By: Louis B. Kilmer, Chief, Bureau of Fire Code Enforcement
Division of Fire Safety

I hereby acknowledge receipt of a copy of this NOTICE OF VIOLATION and ORDER TO CORRECT.

Christina Riccardelli
Signature Printed Name Title Date
received by: Christina
Riccardelli
for Tom McCann.
05-09-19.



State of New Jersey
Department of Community Affairs
P. O. Box 809
Trenton, NJ 08625-0809
609-633-6132

NOTICE OF VIOLATION AND ORDERS OF THE COMMISSIONER

Page 2 of 5

Business Name:	Mc Cann's at the Meadow	Registration #:	1352049979.1	Billing Customer #:	0551087
Inspection Date:	02/28/2019	Inspection Type:	Addendum	Inspector:	DWAYNE DREEDEN
Notice #:	30089600			Issuance Date:	February 28, 2019

VIOLATIONS

ID	Bldg #	Item Description	Violation Location	Code Requirement	Corrective Action	Abate By	Status
4043571	1 - Mc Cann's	LHU Code: BD05 - Main	prev cited inv #226315 2/22/18 2,000	[N.J.A.C. 5:70-2.2.e] Subsequent owners or those succeeding to control over the premises shall be responsible for correcting unabated violations and for the payment of outstanding fees and/or penalties whether or not they have requested a certificate of fire code status.	Responsible party must comply with the violated provision(s) of the Code. [N.J.A.C. 5:70-2.2.e]	3/30/2019	Unabated
4043572	1 - Mc Cann's	LHU Code: BD05 - Main	prev cited inv #227613 4/18/18 500.00	[N.J.A.C. 5:70-2.2.e] Subsequent owners or those succeeding to control over the premises shall be responsible for correcting unabated violations and for the payment of outstanding fees and/or penalties whether or not they have requested a certificate of fire code status.	Responsible party must comply with the violated provision(s) of the Code. [N.J.A.C. 5:70-2.2.e]	3/30/2019	Unabated
4043573	1 - Mc Cann's	LHU Code: BD05 - Main	prev cited inv #2290120 6/17/18 500.00	[N.J.A.C. 5:70-2.2.e] Subsequent owners or those succeeding to control over the premises shall be responsible for correcting unabated violations and for the payment of outstanding fees and/or penalties whether or not they have requested a certificate of fire code status.	Responsible party must comply with the violated provision(s) of the Code. [N.J.A.C. 5:70-2.2.e]	3/30/2019	Unabated
4043574	1 - Mc Cann's	LHU Code: BD05 - Main	prev cited inv #2298372 6/30/18 500.00	[N.J.A.C. 5:70-2.2.e] Subsequent owners or those succeeding to control over the premises shall be responsible for correcting unabated violations and for the payment of outstanding fees and/or penalties whether or not they have requested a certificate of fire code status.	Responsible party must comply with the violated provision(s) of the Code. [N.J.A.C. 5:70-2.2.e]	3/30/2019	Unabated
4043575	1 - Mc Cann's	LHU Code: BD05 - Main	prev cited inv #2300583 7/18/18 641.00	[N.J.A.C. 5:70-2.2.e] Subsequent owners or those succeeding to control over the premises shall be	Responsible party must comply with the violated provision(s) of the Code. [N.J.A.C. 5:70-2.2.e]	3/30/2019	Unabated



State of New Jersey
Department of Community Affairs
P. O. Box 809
Trenton, NJ 08625-0809
609-633-6132

NOTICE OF VIOLATION AND ORDERS OF THE COMMISSIONER

Page 3 of 5

Business Name:	Mc Cann's at the Meadow	Registration #:	1352049979.1	Billing Customer #:	0554087
Inspection Date:	02/28/2019	Inspection Type:	Addendum	Inspector:	DWAYNE BREEDEN
Notice #:	30089600			Issuance Date:	February 28, 2019

ID	Bldg #	Item Description	Violation Location	Code Requirement	Corrective Action	Abate By	Status
				responsible for correcting unabated violations and for the payment of outstanding fees and/or penalties whether or not they have requested a certificate of fire code status.			



State of New Jersey
Department of Community Affairs
P. O. Box 809
Trenton, NJ 08625-0809
609-633-6132

NOTICE OF VIOLATION AND ORDERS OF THE COMMISSIONER

Page 4 of 5

Business Name:	Mc Cann's at the Meadow	Registration #:	1352049979.1	Billing Customer #:	0554087
Inspection Date:	02/28/2019	Inspection Type:	Addendum	Inspector:	DWAYNE BREEDEN
Notice #:	30089660			Issuance Date:	February 28, 2019

ADMINISTRATIVE APPEAL RIGHTS

The owner of the premises or of the use, or an authorized agent of the owner MAY CONTEST THIS ORDER at an Administrative Hearing. The request for a hearing must be made in writing within 15 days after receipt of this order. Request may be made online at the Division of Fire Safety's website (<http://www.nj.gov/dea/divisions/dfs/>) under the DCA RIMS Online Services link or addressed to:

Department of Community Affairs
Hearing Coordinator
PO Box 802
Trenton, New Jersey 08625-0802

In accordance with N.J.A.C. 5:70-2.19 an appeal shall be signed by a proper party and shall include:

- The date of the act, which is the subject of the appeal.
- The name and status of the person submitting the appeal.
- The specific violations or other act claimed to be in error, and
- A concise statement of the basis for the appeal

You are advised that only matters deemed to be CONTESTED CASES, as defined by the Administrative Procedures Act, will be scheduled for a Hearing. If a hearing is scheduled, you will be notified in advance of the time and place. At a hearing a corporation may be represented only by a licensed attorney, unless approval is given by the Office of Administrative Law.

EXTENSIONS

If a specified time has been given to abate a violation, YOU MAY REQUEST AN EXTENSION OF TIME by submitting a written request to the Division of Fire Safety. This request may be made online at the Division of Fire Safety's website (<http://www.nj.gov/dea/divisions/dfs/>) under the DCA RIMS Online Services link. To be considered, the request must be made before the compliance date specified and must set forth the work accomplished, the work remaining, the reason why an extension of time is necessary and the date by which all work will be completed.

TAKE NOTICE THAT, pursuant to N.J.A.C. 5:70-2.10(d) 2 an application for an extension shall be deemed to constitute an admission that the notice of violation is factually and procedurally correct and that the violations do or did exist. In addition, the request for an extension constitutes a waiver of the right to a hearing as to those violations for which an extension is applied.



State of New Jersey
Department of Community Affairs
P. O. Box 809
Trenton, NJ 08625-0809
609-633-6132

NOTICE OF VIOLATION AND ORDERS OF THE COMMISSIONER

Page 5 of 5

Business Name:	Mc Cann's at the Meadow	Registration #:	1352049979.1	Billing Customer #:	0554087
Inspection Date:	02/28/2019	Inspection Type:	Addendum	Inspector:	DWAYNE BREEDEN
Notice #:	30089600			Issuance Date:	February 28, 2019

PENALTIES

Pursuant to N.J.A.C. 5:70-2.12, a violation of the Code is punishable by monetary penalties of not more than \$5,000 per day for each violation. Each day a violation continues is an additional, separate violation except while an appeal is pending.

ALSO TAKE NOTICE THAT, pursuant to N.J.A.C. 5:70-2.12A, when an owner has been given notice of the existence of a violation and has not abated the violation, that owner shall, in addition to being liable to the penalty provided for by N.J.A.C. 5:70-2.12, be liable to a dedicated penalty in the like amount.

Pursuant to N.J.A.C. 5:70-2.12(e), a violation that is recurring justifies imposition of an immediate penalty without the necessity for an interval in which corrections can be made. A violation shall be deemed to be a recurring violation if a notice has been served within two years from the date that a previous notice was served and the violation, premises and responsible party are substantially the same.

Claims arising out of penalty assessments can be compromised or settled if it shall be likely to result in compliance. Moreover, no such disposition can be finalized while the violation continues to exist.

Any penalties assessed are in addition to others previously assessed. Penalties must be paid in full within 30 days after an order to pay. If full payment is not made within 30 days, the matter will be referred to the Office of the Attorney General for summary collection pursuant to "The Penalty Enforcement Law of 1999," P.L. 1999, C. 274 (C. 2A: 58-1 et seq.)

NOTICE

If you require guidance or advice concerning your legal rights, obligations or the course of action you should follow, consult your own advisor.