

Facility Table		
638 Gershal Avenue Warehouse		
1. Existing or proposed facility:	Proposed	
2. New Jersey Pollutant Discharge Elimination System Permit Number:	TBD	
3. Discharge to ground water (DGW) or surface water (DSW):	DGW	
4. Receiving water or aquifer:	Kirkwood-Cohansey Aquifer System (kcas)	
5. Classification of receiving water or aquifer:	B-A Aquifer	
6. Owner of facility:	Four Seasons Tree Service LLC	
7. Operator of facility:	TBD	
8. Co-Permittee of facility (<i>where applicable</i>):	N/A	
9. Location of facility:		
a. Municipality & County	Township of Pittsgrove, Salem County	
b. Street address	638 Gershal Avenue, Pittsgrove, NJ	
c. Block(s) and Lot(s)	Block 3101, Lot(s) 8-17	
10. Location of discharge (i.e. degrees, minutes, seconds):	a. Longitude : 75°05'19.92" W	
	b. Latitude : 39°29'03.72" N	
	c. State Plane Coordinates: X Coord: 325928.197UsFtE Y Coord: 237647.352UsFtN	
11. Present permitted flow or permit condition or daily maximum:	TBD	
12. Summary of population served/to be served including major seasonal fluctuations:	Present Population (Year 2024):	Build-out
Total	0	This facility will serve 934,500 SF of Warehouse use and 28,000 SF of Commercial Office use. The warehouse will consist of three (3) 8-Hour shifts with 187 employees per shift.
13. Summary of wastewater flow received/to be received expressed in million gallons per day (mgd) and as a 30-day average flow for DSW or a daily maximum flow for DGW:*	Present (Year 2024): Wastewater Flow (mgd)	Build-out: Wastewater Flow (mgd)
Commercial Flow: Warehouse	0	0.014025 mgd
Office Space	0	0.00028 mgd
Total Flow:	0	0.016825 mgd