



DEPARTMENT OF ENVIRONMENTAL PROTECTION AND ENERGY  
OFFICE OF LAND AND WATER PLANNING

REVISION TO THE UPPER RARITAN WATER QUALITY MANAGEMENT PLAN

TAKE NOTICE that on MAR 30 1994, pursuant to the provisions of the Water Quality Planning Act, N.J.S.A. 58:11A-1 et seq., and the Statewide Water Quality Management Planning Rules, N.J.A.C. 7:15-3.5, a revision to the Upper Raritan Water Quality Management Plan was adopted by the Department. The revision corrects the Tewksbury Township Wastewater Management Plan relative to the A.M. Best Sewage Treatment Plant (STP).

The A.M. Best STP NJPDES permit (#NJ0028452) was originally written to address both surface water discharge and ground water discharge to reflect the discharge to ground water from an unlined lagoon. Installation of a liner to the lagoon has eliminated the ground water discharge activity. The ground water discharge portion of the permit has been removed and the NJPDES permit will be modified to reflect the lined lagoon and discharge to surface water only.

  
Barry Chalofsky, P.P.  
Professional Planner in  
Responsible Charge

  
Martin A. Bierbaum  
Administrator  
Office of Land and Water  
Planning  
Department of Environmental  
Protection and Energy

3/30/94  
Date

MRD:AMBEST.DOC