DEPARTMENT OF ENVIRONMENTAL PROTECTION OFFICE OF LAND AND WATER PLANNING

REVISION TO THE UPPER RARITAN WATER QUALITY MANAGEMENT PLAN

AUG 2 2 1994 TAKE NOTICE that on , pursuant to the provisions of the Water Quality Planning Act, N.J.S.A. 58:11A-1 et seg., and the Statewide Water Quality Management Planning rules, N.J.A.C. 7:15-3.5, a revision to the Upper Raritan Water Quality Management Plan was adopted by the Department. This revision acknowledges the existing Valley View School in Lebanon Township (Block 8, Lot 21), Hunterdon County. The school facility includes a food preparation kitchen/cafeteria, but no laboratories or showers. are two existing separate disposal systems designed and approved in the 1970's under the jurisdiction of the New Jersey State Department of Health. The original subsurface sewage disposal system was designed and approved in 1970 to accommodate a flow of 5,250 gallons per day. A second subsurface sewage disposal system was designed and approved in 1975 to accommodate an additional 1,248 gallons per day in anticipation of additional school population.

Barry Chalofsky, P.P.
Professional Planner in
Responsible Charge

Martin/A. Bierbaum

Administrator

Office of Land and Water

Planning

Department of Environmental

Protection

Date

MRD: LEBANON. DOC